

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month February, 2022					Day : Tuesday				Date : 08.02.22				
Probable Maximum Demand : 9800 MW					Probable Maximum Generation : 12674 MW					Rule Curve = 96.02 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 92.97 ft Today = 92.93 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.02.22 (Yesterday)		08.02.22 (Today)		07.02.22 (Yesterday)		08.02.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	210	220	220	220				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365			Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0			360	Under maintenance
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	200	200	200	200	250			Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	221	270	280				
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217		118	Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	47	50	60	60				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.3	80	80	34	34	50	50				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	25				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	34	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	100	100				
23	Kodda 150MW PP	HFO (BPD-BRPCL)	9x17.06	149	149	16	82	150	150				
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	280	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.15+1x8.97	149	149	149	144	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	11	200	300				
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	70	100	100				
29	Aurath 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	71	100	100				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	128	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	36	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55				
36	Katpotti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	51	51	51				
Dhaka Zone Total					5853	5696	1627	2220	2738	2818	1695	958	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184			Low water level & maint.
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	40	40	40				
43	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	68	99	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			HGPI awaiting
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	280	266	260	300				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	76	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hafthazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98			Environment issue
51	Barabikunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	20	10	25				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	84	91	97	97				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	16	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	40	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	70	100	100				
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	116	111	116	116				
Chattogram Zone Total					2442	2382	763	961	1239	1269	544	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	26	30	30	19			Gas Shortage
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	212	184	200	200				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	350	305	360	360	55			Gas Shortage
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	10	165	360	360	195			Gas Shortage
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	25	56	56				
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	45	26	8	8	169			Gas Shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	142	150	150	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	50	50				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	135	135	135				
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	21	21				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	11	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	25	25	25				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	12	9	9				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.015+15x1.088	200	200	0	0	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	107	113	113				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				119	119	0	0				On Test
**	Import (Tripura)	India		160	160	92	98	138	164				
Cumilla Zone Total					2944	2899	1420	1615	2200	2326	701	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	95	90	135	135	112			Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				Dependable cap. - 8MW
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	91	110	110				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	160	194	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutakbahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0				
85	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22				
Mymensingh Zone Total					717	622	410	419	541	489	112	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.02.22 (Yesterday)		08.02.22 (Today)		07.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		GT 1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	32	42	42	42		GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	51	51	51			
89	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53	Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	64	70	70			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	160	162	162	170	Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	53	59	75	80			
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54	Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20	Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9	Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	330	330			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		Under project work	
Sylhet Zone Total					2422	2377	1383	1420	1505	1510	306	88
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	33	0	35			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220			
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	80	100			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105			
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	87	0	50	0			
**	Bheramara (HVDC)	India		1000	1000	726	726	741	741			
Khulna Zone Total					2233	2229	922	874	1026	1341	410	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	21	20	24			
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	91	90	92	103	Gas Shortage	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	76	76			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	390	620	620		854	Line Overload
116	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150			
117	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	190	213	220	220			
Barisal Zone Total					2046	2046	587	726	1136	1292	103	854
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
119	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	8	34	34	34			
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	10	200	200			
122	Bere 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	32	49	50	50			
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	100	90	100			
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	0	40			
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50			
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	30	31			
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	122	130	140	140	90	Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	315	230	350	360	184	Gas Shortage	
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52			
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	90	113	113	113			
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	74	110	113	113			
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0			
Rajshahi Zone Total					2129	2129	791	930	1261	1316	875	0
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal shortage	
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74	Coal shortage	
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode	
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	72	113	113	113			
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode	
143	Majpara, Talata 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
144	Energypac Power Venture Thakurgonj Ltd.	HFO (IPP)				1.7	0	0	0			
Rangpur Zone Total					685	605	295	313	321	313	159	85
Sub-total: Plants in operation					21471	20985	8198.0	9478	11967	12674	4905	2458
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					8238	9524	12025	12736				
(B) Plants under long term maintenance/ contract expired												
145	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		Forced Outage	
146	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired	
147	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
148	Bogra 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020	
149	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired on 07/05/2021	
150	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0		Contract Expired on 31/05/2021	
151	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0		Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					595	50	0	0	0	0		
Gross Total					22066	21035	8198	9478	11967	12674	4905	2458
(C) Actual data of 07.02.22 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	9478.00	MW,	at = 19:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9524.00	MW,	at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	9478.00	MW,	at = 19:00 hrs							Load Shed MW
04.	Minimum Generation (Generation end)	:	5871.00	MW,	at = 5:00 hrs	Dhaka	3678	3678	0	Mymensingh	785	785
05.	Day-peak Generation (Generation end)	:	8198.00	MW,	at = 12:00 hrs	Chattogram	1079	1079	0	Sylhet	333	333
06.	Evening-peak Generation (Generation end)	:	9478.00	MW,	at = 19:00 hrs	Khulna	1091	1091	0	Barisal	247	247
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at = 19:00 hrs	Rajshahi	915	915	0	Rangpur	655	655
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5844.00	MW,	at = 5:00 hrs	Cumilla	741	741	0			
09.	Generation shortfall at evening peak due to :	:								Total	9524	9524
a)	Gas limitation	:	4562	MW		13.	Fuel cost :	(a) Gas = 91348904	Taka	(c) Coal = 63507418	Taka	
d)	Coal supply Limitation	:	159	MW				(b) Oil = 402714991	Taka	Total = 557571313	Taka	
b)	Low water level in Kaptai lake	:	184	MW								
c)	Plants under shut down/ maintenance	:	2458	MW								
10.	Total Energy (Generation + India Import)	:	186.07	MKWh		14.	Maximum Temperature in Dhaka was :	23.6° C				
	By Gas = 90.463 MKWH			By Oil = 60.459 MKWh		15.	Export through East-West interconnections :					
	By Coal = 1.3.325 MKWH			By Hydro = 1.111 MKWh			At evening peak-hour :	-220	MW,	at 19:00 hrs		
	By Solar= 1.386 MKWH						Maximum :	-290	MW,	at 20:00 hrs		
11.	Total Gas Supplied	:	746.70	MMCFD			Energy :	0.265	MKWh			
(D) Forecast of 08.02.22 (Today) Tuesday :												
01.	Maximum Demand	:	9800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12674	MW	(Generation end)	05.	Total Generation	:	192.39	MKWh		
03.	Maximum Shortage	:	-2874	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	24.6° C			

* Captive Power: ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation