

20:00 Hrs on 27-Apr-21

Today's Actual Min Gen. & Probable Gen. & Demand

[illegible]

Planned Shut- Down	Forced Shut-Down
--------------------	------------------

--	--

Additional Information of Machines, lines, Interruption / Forced Load shed etc.	
---	--

r) Patuakhali 33 kV Bus was under shut down from 08:18 to 11:49 for C/M.	<p>Jashore S/S area from 08:58 to 15:06.</p> <p>About 40 MW power interruption occurred under Patuakhali S/S area from 08:18 to 11:49.</p>
--	--

<p>s) Narail 132/33 kV T-1 transformer was under shut down from 08:32 to 09:36 for C/M.</p> <p>t) Khulna(S)-Satkhira 132 kV Ckt-1 was under shut down from 09:08 to 13:07 for C/M.</p>	<p>1. Narail 132/33 kV T-1 transformer was under shut down from 08:32 to 09:36 for C/M.</p> <p>2. Khulna(S)-Satkhira 132 kV Ckt-1 was under shut down from 09:08 to 13:07 for C/M.</p>
--	--

u) Faridpur-Gopalganj 132 kV Ckt-1 was under shut down from 11:05 to 12:13 due to R/H maintenance.
v) Ishwardi-Baghabari P.P. 132 kV Ckt was under shut down from 08:40 to 19:07 for C/M.
w) Chapainawabganj 132/33 kV T-1 transformer was under shut down from 09:25 to 13:36 for C/M.

y) Haripur 412 MW CCPP ST was synchronized at 14:22.

z) Ashuganj(N) 400/230 kV T-01 transformer tripped at 18:12 and was switched on at 23:50.	
aa) Tripura-Cumilla(S) 132 kV Ckt-1&2 tripped at 06:26(13/02/2022) from Tripura end showing 86A, 86B,	About 72 MW power interruption occurred under

BB96, SPS.	Cumilla(S) S/S area from 06:26(13/02/2022) to 08:08
ab) Ashuganj(N) 400/230 kV T-01 transformer tripped at 23:58 showing over flux.	

ad) Kulaura 132/33 kV T-1 transformer was under shut down from 22:22 to 23:19 due to R/H maintenance.

Sub Divisional Engineer	Executive Engineer	Superintendent Engineer
-------------------------	--------------------	-------------------------

Senior Electrical Engineer	Senior Electrical Engineer	Superintendent Engineer
Network Operation Division	Network Operation Division	Load Dispatch Circle