POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date : 21-Feb-22 Till now the maximum generation is: 27-Apr-21 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 5:00 6020 MW Available Max Generation : 12555 MW The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : 20-Feb-22 9002.0 MW Hour Hour 12:00 9542.0 MW 9542.0 MW 19:30 19:30 12555 MW 9200 MW E.P. Demand (at gen end) Hour Max Demand (Evening) Maximum Generation 9542.0 MW Hour 19:30 Reserve(Generation end) 3355 MW Total Gen. (MKWH) System Load Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum Level of Kaptai Lake at 6:00 A M on Energy Energy -442 MW 8.00 MKWHR MKWHR 21-Feb-22 Actual : 91.51 Ft.(MSL) Rule curve 94.20 Ft.(MSL) 737.74 MMCFD. Oil Consumed (PDB): Gas Consumed : Total = HSD Liter FO Liter Cost of the Consumed Fuel (PDB+P) Tk99.914.362 Gas Coal Tk62,513,423 Oil : Tk415,494,288 Total : Tk577,922,073 Load Shedding & Other Information Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW 3244 MW (On Estimated Demand) Chittagong Area 0 0:00 1098 0% Khulna Area ٥ 0.00 983 0% Rajshahi Area Cumilla Area 0:00 888 802 0% 0% Mymensingh Area Sylhet Area 0% 0% 0% 0:00 647 0 0:00 369 167 Barisal Area Rangpur Area Total 0:00 499 0% Information of the Generating Units under shut down Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-1,2 2) Ghorasal-3,4,5 3) Ashuganj-4,5 10) Meghnaghat Summit 305 MW CCPP 11) Siddhirganj peaking 12) Meghnaghat 450 MW CCPP GT-2 4) Baghabari-71 MW & 100 MW 13) Siddhirgani 335 MW 5) Shajibazar 330 MW GT-1 6) Raozan unit- 1,2 7) Sirajganj Unit 1 & 3 8) Summit Bibiyana-3 9) Siddhirganj 210 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) Norsingdi-B Baria 132 kV Ckt-2 was under shut down from 08:16 to 12:49 for A/M b) Cumilla(N)-Shahjibazar 230 kV Ckt-2 was under shut down from 08:53 to 18:42 for A/M. c) Siddirganj-Siddirganj EGCB 230 kV Ckt was under shut down from 09:02 to 15:32 for A/M. d) Chowmuhani-Ramganj 132 kV Ckt-2 was under shut down from 08:59 to 16:06 for A/M. e) Mongla 132/33 kV T-1 & T-2 transformers were under shut down from 08:27 to 09:38 due to flashing at LT bus section DS for REB feeder fault. About 8 MW power interruption occurred under Mongla S/S area from 08:27 to 09:38. f) Tongi-Tongi P/S 132 kV Ckt was under shut down from 09:58 to 17:10 for C/M. g) Tongi 132/33 kV T-3 transformer was under shut down from 09:28 to 19:44 for C/M. h) Khagrachari 132/33 kV T-2 transformer was under shut down from 09:12 to 17:55 for A/M. i) Sunamganj 132/33 kV T-1 transformer was under shut down from 09:39 to 17:29 for D/W. j) Kishorganj 132/33 kV T-2 transformer was under shut down from 09:25 to 15:56 for C/M k) Ishurdi 132/33 kV T-2 transformer was under shut down from 10:10 to 16:30 for C/M. I) Bogura-B.Pukuria 230 kV Ckt-1 was under shut down at 10:48 for D/W. n) Chapainawabganj 132/33 kV T-1 transformer was under shut down from 09:20 to 15:03 for C/M. n) Rajshahi 132/33 kV T-2 transformer was under shut down from 11:11 to 14:25 for C/M. o) Bhulta-Haripur 230 kV Ckt-2 was under shut down from 11:55 to 13:20 due to red hot maintenance at hoop conductor CT to DS B-phase at Bhulta end. p) Bashundhara-Purbachal 132 kV Ckt was under shut down from 12:51 to 14:07 for maintenance work. q) Tongi 132/33 kV T-1 transformer was under shut down from 12:57 to 13:02 for D/W. in Norsingdi-B.Baria 132 kV Ckt-1 was under shut down from 13:05 to 16:17 for A/M. s) Aurahati-Keraniganj 132 kV Ckt was under shut down from 13:57 to 19:46 for A/M. t) Sherpur 132/33 kV T-1 transformer was under shut down from 16:52 to 18:11 for C/M. u) Jashore-Jhenaidah 132 kV Ckt-1 tripped at 16:29 showing dist.Z1,3-phase from both end and was switched on at 17:48. y) Sreenagar 132/33 kV T-2 transformer was under shut down from 19:04 to 19:30 due to red hot maint. About 5 MW power interruption occurred under at 33 kV R-phase bus DS of Sreenagar sadar feeder. w) Cumilla(N) 132/33 kV T-3 transformer tripped at 03:21(21/2/22) showing differential relay due to 33 kV Sreenagar S/S area from 19:04 to 19:30. R-phase cable burst. x) Haripur EGCB-412 MW was shut down at 00:53(21/2/22) for gas shortage y) Haripur-360 MW GT was synchronized at 22:50. Sub Divisional Engineer **Executive Engineer** Superintendent Engineer

Network Operation Division

Load Despatch Circle

Network Operation Division