

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2022					Day : Wednesday				Date : 23.02.22				
Probable Maximum Demand : 10100 MW					Probable Maximum Generation : 12218 MW				Rule Curve = 93.90 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 91.27 ft.				Today = 91.12 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.22 (Yesterday)		23.02.22 (Today)		22.02.22 (Yesterday)		23.02.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	340	340	340	340	25		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	347	341	350	350	19		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	14	11	30	30				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	85	90	93				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	19	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x3.73	80	80	53	55	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	30	25	30	30				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
23	Kodda 150MW PP	HFO (BPD-RPCL)	9x17.06	149	149	16	150	150	150				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	290	298	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	106	200	300				
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
29	Aurath 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	91	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	144	144				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	33	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55				
36	Katpotti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
Dhaka Zone Total					5853	5696	2232	2702	2882	2955	2001	598	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	73	70	72	72	160	Low water level & maint.		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	2	25	25	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	12	40	40				
43	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	51	98	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	260	300	300	300				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	6	8	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	80	98	90	96				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	6	29	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	60	100	100				
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	110	113	113	113				
Chattogram Zone Total					2442	2382	751	987	1301	1304	520	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	6	26	26	26	19	Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	224	189	221	221				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	305	320	320				
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	345	320	340	350				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	42	42	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	147	150	150	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	42	50	50				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	124	123	125	125				
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	57	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	0	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	49	52	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	21	20	21				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	98x1.4+63x1.015+15x1.038	200	200	0	0	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	8	8	8				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			0	0	115	0		On Test		
**	Import (Tripura)	India		160	160	110	116	138	163				
Cumilla Zone Total					2944	2899	1534	1624	2123	2147	519	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	175	157	160	155				
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW		
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	103	110	115				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	192	192	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutakbahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0				
85	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22				
Mymensingh Zone Total					717	622	569	496	566	514	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.22 (Yesterday)		23.02.22 (Today)		22.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT 1 Under maint.
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	45	45	45			
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	5	5			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	66	67	66	66			
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	272	270	270	270	60		Gas Shortage
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	81	81			
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGPI
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	305	330	330			
99	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			
100	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work
Sylhet Zone Total					2422	2377	1377	1390	1405	1405	353	108
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	45	0	0	365		Gas Shortage
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	12	40	0	40			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	4	0	40			
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220			
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	28	80	100			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	92	75	105	105			
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	50	0			
**	Bheramara (HVDC)	India		1000	1000	715	715	759	759			
Khulna Zone Total					2233	2229	913	907	1044	1364	365	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	14	25	25	30			
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	91	91	91	91			
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	84	81	81			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	400	620	620	844		Line Overload
116	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150			
117	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110			
Barishal Zone Total					2046	2046	526	710	1087	1192	0	844
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
119	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	43	43			
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	30	200	200			
122	Bere 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	7	44	40	40			
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	49	100	100	100			
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	0	37			
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	43	43	43			
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	29	31	30	30			
127	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
128	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	223	189	220	220	31		Gas Shortage
129	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
130	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414		Gas Shortage
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	40	113	113	113			
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	112	112	113	113			
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total					2129	2129	612	819	993	1024	1046	0
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113			
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
143	Majpara, Talata 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
144	Energypac Power Venture Thakurgonj Ltd.	HFO (IPP)				0	0	0	0			
Rangpur Zone Total					685	605	318	312	321	313	160	85
Sub-total: Plants in operation					21471	20985	8832.0	9947	11722	12218	4964	2108
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8527	9604	11317	11797		
(B) Plants under long term maintenance/ contract expired												
145	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
146	Siddhirganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
147	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
148	Bogra 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
149	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
150	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
151	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired					595	0	0	0	0			
Gross Total					22066	20985	8832	9947	11722	12218	4964	2108
(C) Actual data of 22.02.22 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)		9947.00	MW, at = 19:00 hrs								
02.	Max. Demand at eve. peak (Sub-station end)		9604.00	MW, at = 19:00 hrs								
03.	Highest Generation (Generation end)		9947.00	MW, at = 19:00 hrs								
04.	Minimum Generation (Generation end)		5726.00	MW, at = 5:00 hrs								
05.	Day-peak Generation (Generation end)		8832.00	MW, at = 12:00 hrs								
06.	Evening-peak Generation (Generation end)		9947.00	MW, at = 19:00 hrs								
07.	Evening Peak Load-shed (Sub-station end)		0.00	MW, at = 19:00 hrs								
08.	Minimum Generation Forecast up to 8:00 hrs.		6502.00	MW, at = 5:00 hrs								
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation		4644	MW								
b)	Coal supply Limitation		160	MW								
c)	Low water level in Kaptai lake		160	MW								
d)	Plants under shut down/ maintenance		2108	MW								
10.	Total Energy (Generation + India Import)		194.52	MKWh								
	By Gas =	101.534	MKWh	By Oil =	56.702	MKWh						
	By Coal =	13.993	MKWh	By Hydro =	1.606	MKWh						
	By Solar=	1.282	MKWh									
11.	Total Gas Supplied		762.32	MMCFD								
(D) Forecast of 23.02.22 (Today) Wednesday :												
01.	Maximum Demand		10100	MW (Generation end)								
02.	Maximum Generation		12218	MW (Generation end)								
03.	Maximum Shortage		-2118	MW (Generation end)								
04.	Maximum Load-shed		0	MW At evening peak (Sub-station end)								
05.	Total Generation		197.51	MKWh								
06.	Probable Max. Temperature in Dhaka :		28.8° C									

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation