

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month March, 2022		10800 MW		Day: Thursday		Date: 03.03.22						
Probable Maximum Demand:		10800 MW		Probable Maximum Generation: 12360 MW		Rule Curve = 92.68 ft.						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 90.29 ft.		Today = 90.17 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.03.22 (Yesterday)		03.03.22 (Today)		02.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:			
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	340	340	340	340			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Under maint.	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	221	220	200	220	217	118	Gas Shortage, ST maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	11	21	25	25			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	93	93	93	93			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.97+8x7.3	80	80	47	49	55	55			
19	Masona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.7	33	33	33	33	33	33			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.7	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.50	52	52	50	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	100	105	105			
23	Kooda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kooda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	280	283	300	300			
26	Kooda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	244	200	300			
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100			
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	144	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
Dhaka Zone Total			5853	5696	2355	2828	2826	2916	1470	1370		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	42	46	46	46	184	Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	24	25	24			
41	Tekinaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	20	20	20	20			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	25	25	25			
43	Sikalbaha 105 MW PP (Baraka Sikalbi)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
44	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	0	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	265	283	300	300			
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	92	100	100			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	84	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment Issue	
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	20	20	20			
	* Malancha, Cig.EPZ (United)	Gas	5x8.73+3x3.34			2	16	10	15			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	83	99	100	100			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	41	54	54	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	40	100	100	100			
56	Chattogram 116 MW PP (Anilma Enen)	HFO (IPP)	6x21.06	116	116	113	113	113	113			
Chattogram Zone Total			2442	2382	927	1228	1268	1253	544	473		
57	a) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	29	29			
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+17x5	221	221	128	177	200	200			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	310	320	340			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x360	360	360	280	315	320	340			
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	5	5	5	50	Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	55	8	8	8	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	24	24	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	137	137	140	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	33	33	33			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	181	198	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	10	11			
71	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	23	25	25	25			
72	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	21	21			
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+60x1.515+15x1.059	200	200	0	20	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	108	108	114	114			
76	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	5	0	8			
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			17	68	115	115		On Test	
**	Impoort (Tajpara)	India		160	160	100	124	138	163			
Cumilla Zone Total			2944	2899	1560	1702	1920	2104	500	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	66	70	90	100	132	Gas Shortage	
79	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.524	95	8	0	0	0	0		Dependable cap. : 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	172	180	180	180			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Suttheshal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total			717	622	448	407	461	439	132	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.03.22 (Yesterday)		03.03.22 (Today)		02.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40		GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30	60		GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	45	52	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	60	66	66				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	149	148	150	150	182		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	84	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	20	0	0	0	0		20	Under HGPI	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x8.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	330	330				
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	140	140	140	140				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	396	400	400	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total					2422	2377	1366	1390	1427	1429	475	120	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	240	225	250	280	185		Gas Shortage	
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	4	0	40				
106	Khulna 225 MW CCPP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	100	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	715	716	730	730				
Khulna Zone Total					2233	2229	1149	1110	1285	1615	185	0	
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	9	9	10	10				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	91	90	91				
114	Bhola 35 MW PP (Aggreko)	Gas (QRPP)	1.1x66	95	95	11	11	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	310	410	620	620		834	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150				
117	Bhola 220MW CCPP (Nutan Bidyt BE)	Gas/HSD (IPP)	2x75+1x70	220	220	222	222	225	225				
Barishal Zone Total					2046	2046	643	743	1116	1217	0	834	
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	20	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	28	41	40	41				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	98	100	100				
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40				
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	22	22				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	170	175	185	200	45		Gas Shortage	
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
131	Ullaspara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	43	25	40	43				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	6	0	6	0				
Rajshahi Zone Total					2129	2129	544	745	929	989	1060	0	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	90	85	82	85	0		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	106	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Maipara, Tabula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgaon Ltd.	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					695	605	499	514	523	398	74	85	
Sub-total: Plants in operation					21471	20985	9491.0	10667	11775	12360	4440	3045	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					9164	10300	11369	11935					
(B) Plants under long term maintenance/ contract expired													
142	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Mehraghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					595	0	0	0	0				
Gross Total					22066	20985	9491	10667	11775	12360	4440	3045	
(C) Actual data of 02.03.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	: 10667.00 MW, at = 19:00 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 10300.00 MW, at = 19:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 10667.00 MW, at = 19:00 hrs		MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	: 6945.00 MW, at = 5:00 hrs		Dhaka	3861	3861	0	Mymensingh	900	900	0		
05.	Day-peak Generation (Generation end)	: 9491.00 MW, at = 12:00 hrs		Chattogram	1124	1124	0	Sylhet	348	348	0		
06.	Evening-peak Generation (Generation end)	: 10667.00 MW, at = 19:00 hrs		Khulna	1175	1175	0	Barishal	258	258	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs		Rajshahi	1079	1079	0	Rangpur	711	711	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6983.00 MW, at = 5:00 hrs		Cumilla	844	844	0						
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 4182 MW		13.		Fuel cost :		Total		10300	10300	0	
	d) Coal supply Limitation	: 74 MW		(a) Gas =		92708657 Taka		(c) Coal =		78804514	Taka		
	b) Low water level in Kaptai lake	: 184 MW		(b) Oil =		547541629 Taka		Total =		719054800	Taka		
	c) Plants under shut down/ maintenance	: 3045 MW		14.		Maximum Temperature in Dhaka was :		30.8° C					
10.	Total Energy (Generation + India Import)	: 214.03 MWh		15.		Export through East-West interconnections :							
	By Gas = 98.542 MKWh	By Oil = 77.251 MKWh		At evening peak-hour		: -234 MW, at 19:00 hrs							
	By Coal = 16.065 MKWh	By Hydro = 1.079 MKWh		Maximum		: -234 MW, at 19:00 hrs							
	By Solar = 1.449 MKWh			Energy		: 0.443 MKWh							
11.	Total Gas Supplied	: 763.77 MMCFD											
(D) Forecast of 03.03.22 (Today) Thursday :													
01.	Maximum Demand	: 10800 MW (Generation end)		04.		Maximum Load-shed		: 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	: 12360 MW (Generation end)		05.		Total Generation		: 216.70 MKWh					
03.	Maximum Shortage	: -1560 MW (Generation end)		06.		Probable Max. Temperature in Dhaka		: 31.5° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation