

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2022					Day : Friday				Date : 04.03.22				
Probable Maximum Demand : 10000 MW					Probable Maximum Generation : 12360 MW					Rule Curve = 92.52 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 90.17 ft Today = 90.05 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.22 (Yesterday)		04.03.22 (Today)		03.03.22 (Yesterday)		04.03.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	340	340	340	340				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360			Under maint.
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115			Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Under maint.
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	213	219	200	200	217	118		Gas Shortage,ST maint.
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	23	25	25				
16	Gargagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93				
17	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	22	22	22				
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.97+7x8.73	80	80	55	49	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150				
24	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	35	35	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	280	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	300	200	300				
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	34	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	37	43	55	55				
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
Dhaka Zone Total					5853	5696	2302	2841	2826	2896	1470	1370	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184			Low water level & maint.
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	24				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	32	39	42	42				
43	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	89	105	105	105				
44	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			HGPI awaiting
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	280	290	300	300				
47	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	20	70	100	100				
48	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98			Environment Issue
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	20	20				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	24	35	35				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	70	85	100	100				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	102	110	110	110				
55	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	55	100	100	100				
56	Chattogram 116 MW PP (Anlima Enen	HFO (IPP)	6x21.06	116	116	94	115	113	113				
Chattogram Zone Total					2442	2382	964	1222	1316	1290	544	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	5	5	40			Gas Shortage
59	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	205	218	190	190				
60	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	300	300	330	310				
61	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	300	260	340	320				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50			Gas Shortage
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187			Gas Shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	17	24	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	137	135	140	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	31	33	33				
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163			Under maint.
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	140	170	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	10	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	16	21	21				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+60x1.315+15x1.058	200	200	0	70	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	114	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	0	0	8				
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			53	72	115	115				On Test
**	Impoport (Tripura)	India		160	160	124	128	138	163				
Cumilla Zone Total					2944	2899	1573	1682	1916	2020	540	163	
78	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	67	84	140	125	118			Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				Dependable cap. : 8MW
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	109	109	115	115				
82	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	186	197	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutiaikali 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0				
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	22	18	22	22				
Myensingh Zone Total					717	622	454	428	551	484	118	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.22 (Yesterday)		04.03.22 (Today)		03.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance								
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date							
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)									
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.								
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.								
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	53	50	50											
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	140	110	110	23		Gas Shortage								
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11											
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	66	66											
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	159	159	160	160	171		Gas Shortage								
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	84	86											
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage								
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGP1								
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10											
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	14	24	16	16											
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	330	330											
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	140	140	140	140											
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	400	400	400											
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work								
Sylhet Zone Total						2422	2377	1378	1443	1437	1439	425	120							
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0											
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	230	215	300	300	195		Gas Shortage								
104	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	40											
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	12	0	40											
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220											
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	83	100	100											
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105											
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100											
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	50	0											
**	Bheramara (HVDC)	India		1000	1000	712	713	733	733											
Khulna Zone Total						2233	2229	1136	1161	1338	1638	195	0							
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110											
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	8	9	10	10											
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	92	91	90	91											
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11											
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	440	620	620		804	Line Overload								
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150											
117	Bhola 220MW CCPP (Nutan Bidyut BE)	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	225	225											
Barishal Zone Total						2046	2046	632	771	1116	1217	0	804							
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage								
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage								
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34											
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	100	200	200											
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	41											
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	99	100	100											
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	0	40											
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	50											
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	14	28	22	22											
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage								
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage								
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	179	163	180	180	57		Gas Shortage								
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0		414	under maint.								
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22											
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11											
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	52	52	52											
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113											
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113											
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0											
Rajshahi Zone Total						2129	2129	537	787	936	978	658	414							
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	82	85	5		Coal shortage								
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling								
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage								
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode								
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113											
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode								
141	Maipara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0											
	Energypac Power Venture Thakurgaon Ltd.	HFO (IPP)				111	116	120	0											
Rangpur Zone Total						685	605	510	509	523	398	79	85							
Sub-total: Plants in operation						21471	20985	9486.0	10844	11959	12360	4029	3429							
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						9102	10405	11474	11860											
(B) Plants under long term maintenance/ contract expired																				
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage								
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired								
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0											
145	Bogura 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020								
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021								
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021								
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022								
Sub-Total: Plants under long term maintenance/ contract expired						595	0	0	0	0	0									
Gross Total						22066	20985	9486	10844	11959	12360	4029	3429							
(C) Actual data of 03.03.22 (Yesterday) Thursday :																				
01.	Max. Demand at eve. peak (Generation end)	:	10844.00	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
02.	Max. Demand at eve. peak (Sub-station end)	:	10405.00	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed							
03.	Highest Generation (Generation end)	:	10844.00	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW							
04.	Minimum Generation (Generation end)	:	6983.00	MW, at =	5:00 hrs	Dhaka	3847	3847	0	Mymensingh	921	921	0							
05.	Day-peak Generation (Generation end)	:	9486.00	MW, at =	12:00 hrs	Chattogram	1173	1173	0	Sylhet	364	364	0							
06.	Evening-peak Generation (Generation end)	:	10844.00	MW, at =	19:00 hrs	Khulna	1203	1203	0	Barishal	258	258	0							
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	19:00 hrs	Rajshahi	1078	1078	0	Rangpur	703	703	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6980.00	MW, at =	5:00 hrs	Cumilla	858	858	0											
09.	Generation shortfall at evening peak due to :	:																		
	a) Gas limitation	:	3766	MW		13.	Fuel cost :		(a) Gas =	93109875 Taka	(c) Coal =	79909782 Taka								
	d) Coal supply Limitation	:	79	MW			(b) Oil =		561043672 Taka	Total =	734063328 Taka									
	b) Low water level in Kaptai lake	:	184	MW																
	c) Plants under shut down/ maintenance	:	3429	MW		14.	Maximum Temperature in Dhaka was : 31.2° C													
10.	Total Energy (Generation + India Import)	:	217.27	MKWh		15.	Export through East-West interconnections :													
	By Gas = 100.095 MKWh			By Oil =	78.499 MKWh		At evening peak-hour :													
	By Coal = 16.323 MKWh			By Hydro =	1.095 MKWh		Maximum :													
	By Solar = 1.484 MKWh						Energy :													
11.	Total Gas Supplied	:	761.80	MMCFD																
(D) Forecast of 04.03.22 (Today) Friday :																				
01.	Maximum Demand	:	10000	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)													
02.	Maximum Generation	:	12360	MW	(Generation end)	05.	Total Generation : 200.36 MKWh													
03.	Maximum Shortage	:	-2360	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 31.4° C													