

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2022				Day : Saturday				Date : 05.03.22							
Probable Maximum Demand :				10500	MW	Probable Maximum Generation :				12720	MW	Rule Curve = 92.36			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 90.05		ft		Today = 89.93		ft		Gen. shortfall for :			
Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.03.22 (Yesterday)		05.03.22 (Today)		04.03.22 (Yesterday)		05.03.22 (Today)		Status of Machines under shut-down/ Maintenance
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:															
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas	(PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas	(PDB)	1 x 210	210	180	0	0	0	0	240			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	340	340	340	340					
4	Ghorasal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	0	0	0	0	105			Under maint.	
6	Haripur GTPP	Gas	(PDB)	1 x 32	32	20	0	0	0	0	20			Gas Shortage	
7	Haripur 360MW CCGP(HPL)	Gas	(IPP)	1x235+1x125	360	360	0	0	0	0	360			Under maint.	
8	Meghnaghat 450 MW CCGP(MPL)	Gas	(IPP)	2x140+1x170	450	450	300	300	300	300	150			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas	(PDB)	1 x 210	210	115	0	0	0	0	115			Under Overhauling	
10	Haripur 412 MW CCGP	Gas	(EGCB)	1x273+1x139	412	412	0	0	0	0	412			Under maint.	
11	Siddhirganj 2*120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	0	91	95	95	119			Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas	(EGCB)	1 x 217+1x118	335	335	203	153	200	200	217	118		Gas Shortage,ST maint.	
13	Meghnaghat CCGP(Summit)	GAS	(IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO	(IPP)	5x17.08+1x11.3	55	55	20	45	55	55					
15	Keraniganj 100 MW PP (Powerpac)	HFO	(QRPP)	8x13.45	100	100	0	22	25	25					
16	Gagnagar 102 MW PP (Digital Power)	HFO	(IPP)	12x8.924	102	102	40	93	93	93					
17	Narsinghdi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90	22	22	22	22	22	22					
18	Summit Power,(Madhabadi-Ashulia)	Gas	(SIPP, REB)	6x3.67+7x8.73	80	80	42	42	55	55					
19	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	25	23	25	25					
20	Rugganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	33	33	33	33					
21	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	0	20	51	51					
22	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	65	84	105	105					
23	Kodda 150MW PP	HFO	(BPDB-RPCL)	9x17.06	149	149	0	49	150	150					
24	Kamalaghat 54 MW PP (Barco Energy)	HFO	(IPP)	3x18.69	54	54	54	54	54	54					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	168	265	300	300					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO	(IPP)	8x18.415+1x8.97	149	149	124	125	149	149					
27	Keraniganj 300 MW PP (APR)	HSD	(IPP)	256x1.4	300	300	0	0	200	300					
28	Bramhangon 100 MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	100	100					
29	Aurahat 100MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	100	100					
30	Nababganj 55 MW PP (Southern powe	HFO	(IPP)	3x19.3	55	55	55	55	55	55					
31	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	17	55	55	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO	(IPP)	6x18.5	104	104	91	100	104	104					
33	Manikganj 162MW PP(MPGL)	HFO	(IPP)	9x18	162	162	162	162	162	162					
34	Manikganj 35MW Solar PP (Inspectra	Solar	(IPP)	1x35	35	35	29	0	30	0					
35	Kanchan Purbachal Power Generation	HFO	(IPP)	3x19.404	55	55	55	55	55	55					
36	Katpott 52 MW PP (Sinha)	HFO	(IPP)	7x7.90	51	51	0	0	0	0					
Dhaka Zone Total				5853	5696	1845	2188	2913	2983	1379	1370				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	46	46	46	46	184			Low water level & maint.	
38	a) Chattogram TPP-1	Gas	(PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas	(PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar	(PDB)	7	7	7	5	0	5	0					
40	Razzan 25 MW PP	HFO	(RPCL)	3x8.9	25	25	0	8	25	24					
41	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	20	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	0	42	42	42					
43	Sikalbaha 105 MW PP (Baraka Sikab	HFO	(IPP)	6x18.415	105	105	0	43	105	105					
44	Sikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.	
45	Sikalbaha 225 MW CCGP	Gas	(PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+ 3x8.04	300	300	283	283	300	300					
47	Julda 100 MW Unit-1 (Acom)	HFO	(QRPP)	8x13.45	100	100	0	10	100	100					
48	Julda 100 MW PP Unit-3 (Acom)	HFO	(IPP)	8x13.45	100	100	76	90	90	90					
49	Dohazari -Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	102	0	51	51	51					
50	Hathazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	0	0	0	0	98			Environment Issue	
51	Barabkunda 22 MW PP (Regent)	Gas	(SIPP, PDB)	8x2.90	22	22	19	19	19	19					
*	Malancha, Ctg.EPZ (United)	Gas		5x8.73+3x9.34			30	42	10	25					
52	Chattogram 108 MW PP (ECPV)	HFO	(IPP)	16x7.00	108	108	60	85	100	100					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	54	54	54	54					
54	Karnaphuli Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	92	92	110	110					
55	Julda Unit-2 (Acom)	HFO	(IPP)	8x13.6	100	100	46	92	100	100					
56	Chattogram 116 MW PP (Anlima Ener	HFO	(IPP)	6x21.06	116	116	68	109	113	113					
Chattogram Zone Total				2442	2382	799	1066	1290	1279	544	473				
57	a) Ashuganj TPP Unit- 4	Gas	(APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas	(APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
58	Ashuganj 50 MW PP	Gas	(APSCL)	14x3.968	53	45	5	29	5	29	16			Gas Shortage	
59	Ashuganj 225 MW CCGP	Gas	(APSCL)	1x142+175	221	221	213	182	190	190					
60	Ashuganj 450 MW CCGP(South)	Gas	(APSCL)	1x360	360	360	335	305	310	335					
61	Ashuganj 450 MW CCGP(North)	Gas	(APSCL)	1x361	360	360	345	280	310	335					
62	Ashuganj 55 MW PP (Precision)	Gas	(RPP)	15'4	55	55	5	25	5	5	30			Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas	(IPP)	20'9.73+1'116	195	195	8	8	8	8	187			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	51	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	98	97	140	140					
66	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	0	33	33	33					
67	Chandpur 150 MW CCGP	Gas	(PDB)	1X106+1x57	163	163	0	0	0	0	163			Under maint.	
68	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	3	45	200	200					
69	Feni 22MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	20	21	22	22					
70	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90	11	11	5	11	11	11					
71	Jangalia 33MW PP (Summit)	Gas	(SIPP, PDB)	4x8.73	33	33	25	25	25	25					
72	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	52	50	52	52					
73	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15					
74	Daudkandi 200 MW PP (B.Trac)	HSD	(IPP)	89x1.4+60x1.315+15x1.058	200	200	0	0	100	200					
75	Feni 114 MW Power Plant(Lakdanavi)	HFO	(IPP)	7*18.415+1*9.78	114	114	51	88	114	114					
76	Chowmuhani 113 MW	HFO	(IPP)	12'9.78+2'3.1	113	113	0	0	0	8					
77	Bharoi 54 MW PP	HFO	(IPP)	3x18.2	54	54	13	17	17	17					
	Chandpur 115(Doreen)	HFO	(IPP)	4x18.516+2x25.428			5	70	115	115				On Test	
**	Imoport (Tripura)	India			160	160	102	110	138	163					
Cumilla Zone Total				2944	2899	1351	1462	1861	2068	496	163				
78	RPCL 210MW CCGP	Gas	(IPP)	4x35+1x70	210	202	148	208	140	210					
79	Tangail 22 MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	20	20	20	20					
80	Jamalpur 95 MW PP(Powerpac)	HFO	(IPP)	12x8.924	95	8	0	0	0	0				Dependable cap. : 8MW	
81	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	68	103	115	115					
82	Myensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	168	185	200	200					
83	Sarishabari 3 MW Solar Plant	Solar	(IPP)	1x3	3	3	2	0	1.6	0					
84	Sutikhal 50 MW Solar PP	Solar	(IPP)	1x50	50	50	47	0	50	0					
85	Tangail 22 MW PP(PPL)	HFO	(IPP)	4x6.7	22	22	22	22	22	22					
Myensingh Zone Total				717	622	475	538	549	567	0					

No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.03.22 (Yesterday)		05.03.22 (Today)		04.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	48	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	157	160	160	160	170		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	89	86	89				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGP1	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	21	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	270	330	330				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	140	140	140	140				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	384	395	400	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total						2422	2377	1363	1377	1438	1444	454	120
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	410	360	410				
104	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	3	0	40				
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	718	717	731	731				
Khulna Zone Total						2233	2229	1283	1235	1396	1746	0	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	7	8	10	10				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	79	91	90	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	16	11	11				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	230	260	620	620		984	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150				
117	Bhola 220MW CCPP (Nutan Bidyut BE	Gas/HSD (IPP)	2x75+1x70	220	220	152	190	225	225				
Barishal Zone Total						2046	2046	479	565	1116	1217	0	984
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	40	41				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	100	100				
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	40				
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	43	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	22	22				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	183	200	220	37		Gas Shortage	
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0		414	Under maint.	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	24	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	100	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	428	672	956	1018	638	414
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	82	85	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	75	104	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Maipara, Tatula 8 MW Solar PP (Sympa Power Energyrac Power Venture Thakurgaon Ltd.	Solar (IPP)	1 x 8	8	8	6	0	8	0				
		HFO (IPP)				0	36	120	0				
Rangpur Zone Total						685	605	81	340	523	398	159	85
Sub-total: Plants in operation						21471	20985	8104.0	9443	12042	12720	3670	3609
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						7879	9181	11708	12367				
(B) Plants under long term maintenance/ contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						595	0	0	0	0	0		
Gross Total						22066	20985	8104	9443	12042	12720	3670	3609
(C) Actual data of 04.03.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	9443.00	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9181.00	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	9443.00	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	6980.00	MW, at =	5:00 hrs	Dhaka	3097	3097	0	Mymensingh	906	906	0
05.	Day-peak Generation (Generation end)	:	8104.00	MW, at =	12:00 hrs	Chattogram	1040	1040	0	Sylhet	346	346	0
06.	Evening-peak Generation (Generation end)	:	9443.00	MW, at =	19:00 hrs	Khulna	1092	1092	0	Barishal	237	237	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	19:00 hrs	Rajshahi	992	992	0	Rangpur	686	686	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6823.00	MW, at =	5:00 hrs	Cumilla	785	785	0				
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	3327	MW									
	d) Coal supply Limitation	:	159	MW									
	b) Low water level in Kaptai lake	:	184	MW									
	c) Plants under shut down/ maintenance	:	3609	MW									
10.	Total Energy (Generation + India Import)	:	195.17	MKWh									
	By Gas =	103.313	MKWh	By Oil =	57.022								
	By Coal =	12.908	MKWh	By Hydro =	1.063								
	By Solar =	1.335	MKWh										
11.	Total Gas Supplied	:	792.26	MMCFD									
(D) Forecast of 05.03.22 (Today) Saturday :													
01.	Maximum Demand	:	10500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12720	MW	(Generation end)	05.	Total Generation	:	217.02	MKWh			
03.	Maximum Shortage	:	-2220	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.6° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation