

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2022				Day : Sunday				Date : 06.03.22					
Probable Maximum Demand : 11400 MW				Probable Maximum Generation : 12790 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.93 ft		Today = 89.81 ft		Rule Curve = 92.20 ft					
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.22 (Yesterday)		06.03.22 (Today)		05.03.22 (Yesterday) Gen. shortfall for :	Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)					
						Day	Evening	Day	Evening				
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	340	340	340				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360		Under maint.	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Under maint.	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	97	98	95	95	112		Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	165	158	200	200	217	118	Gas Shortage,ST maint.	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	38	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	22	25	25				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93				
17	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
18	Summit Power,(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	56	55	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	25	30	30				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	51	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	150	150	150				
24	Kamalaghat 54 MW PP (Barako Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	265	278	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	141	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	134	200	300				
28	Bramhangon 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
29	Aurahi 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	162	162				
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	33	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55				
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
Dhaka Zone Total				5853	5696	2042	2720	2918	2988	1372	1370		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	24				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	42	42	42				
43	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	32	105	105	105				
44	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	283	263	300	300				
47	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	86	100	100				
48	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment Issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	19				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	14	10	10				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	108	99	100	100				
53	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
55	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	100	100	100				
56	Chattogram 116 MW PP (Anlima Ener	HFO (IPP)	6x21.06	116	116	62	114	113	113				
Chattogram Zone Total				2442	2382	840	1217	1290	1264	544	473		
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	29	29	29	16		Gas Shortage	
59	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	199	178	195	200				
60	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	300	305	330	335				
61	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	295	310	310	335				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50		Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	26	55	55	169		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	102	100	140	140				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	33	33	33				
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	42	160	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	25	25				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+60x1.315+15x1.058	200	200	0	60	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	114	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	8	0	8				
77	Bharoi 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
	Chandpur 115(Doreen)	HFO (IPP)	4x18.516+2x25.428			72	72	115	115			On Test	
**	Impoport (Tripura)	India		160	160	98	126	138	163				
Cumilla Zone Total				2944	2899	1428	1718	1957	2125	498	163		
78	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	200	198	210	210				
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	109	108	115	115				
82	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	175	184	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutiaikali 50 MW Solar PP	Solar (IPP)	1x50	50	49	0	50	0	0				
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	22	22	22	22				
Myensingh Zone Total				717	622	577	532	619	567	0	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.03.22 (Yesterday)		06.03.22 (Today)		05.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	51	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	160	160	160	170		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	89				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGP1	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
97	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	19	5	21	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	255	330	330				
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	140	79	140	140				
100	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	380	400	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total						2422	2377	1393	1270	1438	1444	454	120
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	310	410	360	410				
104	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	70	100	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	716	717	731	731				
Khulna Zone Total						2233	2229	1220	1336	1396	1746	0	0
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	8	9	10	10				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	79	91	90	91				
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	22	22	22	22				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	450	620	620		794	Line Overload	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150				
117	Bhola 220MW CCPP (Nutan Bidyut BE)	Gas/HSD (IPP)	2x75+1x70	220	220	183	190	225	225				
Barishal Zone Total						2046	2046	572	762	1127	1228	0	794
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	60	100	100	100				
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	20	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	42	44	40	41				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	96	100	100				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	37	0	40				
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	22	22				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	193	220	200	220				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0		414	Under maint.	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	43	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	112	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	673	910	1060	1115	501	414
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	105	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Maipara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
	Energypac Power Venture Thakurgaon Ltd.	HFO (IPP)				116	117	120	0				
Rangpur Zone Total						685	605	426	430	441	313	159	85
Sub-total: Plants in operation						21471	20985	9171.0	10895	12246	12790	3528	3419
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss						8769	10418	11709	12230				
(B) Plants under long term maintenance/ contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogura 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						595	0	0	0	0	0		
Gross Total						22066	20985	9171	10895	12246	12790	3528	3419
(C) Actual data of 05.03.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	10895.00	MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10418.00	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10895.00	MW, at =	19:30 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	6823.00	MW, at =	5:00 hrs	Dhaka	3814	3814	0	Mymensingh	914	914	0
05.	Day-peak Generation (Generation end)	:	9171.00	MW, at =	12:00 hrs	Chattogram	1146	1146	0	Sylhet	369	369	0
06.	Evening-peak Generation (Generation end)	:	10895.00	MW, at =	19:30 hrs	Khulna	1229	1229	0	Barishal	262	262	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	19:30 hrs	Rajshahi	1110	1110	0	Rangpur	704	704	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7301.00	MW, at =	5:00 hrs	Cumilla	870	870	0				
09.	Generation shortfall at evening peak due to :	:								Total	10418	10418	0
	a) Gas limitation	:	3185	MW		13.	Fuel cost :	(a) Gas = 104902443 Taka	(c) Coal = 63721104 Taka				
	d) Coal supply Limitation	:	159	MW			(b) Oil = 495784124 Taka	Total = 664407670 Taka					
	b) Low water level in Kaptai lake	:	184	MW									
	c) Plants under shut down/ maintenance	:	3419	MW		14.	Maximum Temperature in Dhaka was :	32.5° C					
10.	Total Energy (Generation + India Import)	:	213.43	MKWh		15.	Export through East-West interconnections :						
	By Gas = 107.510 MKWh			By Oil = 70.482 MKWh			At evening peak-hour	: -12	MW, at 19:30 hrs				
	By Coal = 13.378 MKWh			By Hydro = 1.095 MKWh			Maximum	: -318	MW, at 8:00 hrs				
	By Solar= 1.370 MKWh						Energy	: 0.58	MKWh				
11.	Total Gas Supplied	:	837.35	MMCFD									
(D) Forecast of 06.03.22 (Today) Sunday :													
01.	Maximum Demand	:	11400	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12790	MW	(Generation end)	05.	Total Generation	:	223.32	MKWh			
03.	Maximum Shortage	:	-1390	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.8° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation