

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month March, 2022				Day : Friday				Date : 11.03.22					
Probable Maximum Demand : 11000 MW				Probable Maximum Generation : 13053 MW				Rule Curve = 91.40 ft					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.22 ft				Today = 89.10 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.22 (Yesterday)		11.03.22 (Today)		10.03.22 (Yesterday)		11.03.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	320	320	320	320				
4	Ghorashtal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	102	105	108	108				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Under maint.	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	250	270	270	200		Dirty in gas	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	150	90	150	150	217	118	STG Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	260	240	305	305				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	8	0	0	0				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	53	45	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	30	30				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	50	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150				
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	282	290	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	157	252	200	300				
28	Bramhangson 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100				
29	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	100	100	100				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	88	90	93				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	154	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	34	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55				
36	Kalpoti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
Dhaka Zone Total			5853	5696	2880	2951	3097	3170	1077	1370			
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	20	46	46	46	184		Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	50	50	50				
43	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	280	283	300	300				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	86	100	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	19	19				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x8.34			2	12	26	26				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x107	108	108	84	98	100	100				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54				
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	11	100				
56	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	113	113	113	113				
Chattogram Zone Total			2442	2382	1110	1237	1225	1289	544	375			
57	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	29	29				
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	184	219	210	225				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	285	305	330	335				
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	315	310	325	335				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	50	55	55				
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	55	8	8	140		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	150	150	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	27	32	33	33				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	0	0	0				
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	190	200	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	23	25	25	25				
72	Jangalia 52 MW PP (Lakdenavi)	HFO (IPP)	6x8.92	52	52	53	52	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	20	20	21				
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.015+15x1.088	200	200	0	200	100	200				
75	Feni 114 MW Power Plant(Lakdenavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	114	114	114				
76	Chowmuhani 11.3 MW	HFO (IPP)	12*9.79+2*3.1	113	113	25	97	113	113				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	36	36	36				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	99	101	115	115				
**	Import (Tribuna)	India		160	160	128	128	138	163				
Cumilla Zone Total			3059	3014	1841	2207	2137	2293	403	0			
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	121	120	150	150	82		Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW	
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	109	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	172	182	190	190				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0				
86	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	18	22	22	22				
Mymensingh Zone Total			717	622	478	453	549	497	82	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.22 (Yesterday)		11.03.22 (Today)		10.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)					
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT 1 & GT Under maint.				
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	42	42		60	GT-4 Under maint.				
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50							
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11							
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60							
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	135	135	150	150	195		Gas Shortage				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	89	86	86							
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGPI				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10							
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	22	22							
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	260	330	330							
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	401	400	400							
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Filter replacement ongoing				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
Sylhet Zone Total						2422	2377	1242	1194	1301	479	120				
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	275	410	410	135		Gas shortage				
105	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	0	40							
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40							
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	158	0	220							
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	100	100							
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	94	105	105							
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100							
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	92	0	50	0							
**	Bheramara (HVDC)	India		1000	1000	719	721	734	734							
Khulna Zone Total						2233	2229	1205	1378	1449	135	0				
112	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110							
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	27	10	10							
114	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	89	90	90	92							
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11							
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	490	620	620		754	Line Overload				
117	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150							
118	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	216	220	225	225							
Barishal Zone Total						2046	2046	652	838	1116	1218	0	754			
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage				
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34							
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	164	200	200							
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	17	44	40	41							
123	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	48	97	100	100							
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	35	0	40							
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50							
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	7	30	25	30							
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage				
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	143	124	200	200							
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	220	140	200	220	80		Gas Shortage				
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0		414	Under maint.				
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22	22							
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8							
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52							
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113							
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	112	113	113	113							
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0							
Rajshahi Zone Total						2129	2129	690	1026	1163	1223	461	414			
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling				
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage				
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	106	113	113	113							
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	8	0	0			Condenser mode				
142	Majpara, Talula 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	6	0	8	0							
143	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)		115	115	56	117	120	0							
Rangpur Zone Total						800	720	368	438	441	313	159	85			
Sub-total: Plants in operation						21701	21215	10466.0	11722	12478	13053	3340	3118			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								9954	11148	11867	12414					
(B) Plants under long term maintenance/ contract expired																
144	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage				
145	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired				
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0							
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020				
148	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021				
149	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021				
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022				
Sub-Total: Plants under long term maintenance/ contract expired						595	0	0	0	0	0					
Gross Total						22296	21215	10466	11722	12478	13053	3340	3118			
(C) Actual data of 10.03.22 (Yesterday) Thursday :																
01.	Max. Demand at eve. peak (Generation end)	:	11722.00	MW, at = 19:30 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	11148.00	MW, at = 19:30 hrs			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	11722.00	MW, at = 19:30 hrs				Chhata	4112	4112	0	Mymensingh	974	974	0	
04.	Minimum Generation (Generation end)	:	8001.00	MW, at = 5:00 hrs				Dhaktogram	1170	1170	0	Sylhet	446	446	0	
05.	Day-peak Generation (Generation end)	:	10466.00	MW, at = 12:00 hrs				Khulna	1261	1261	0	Barishal	279	279	0	
06.	Evening-peak Generation (Generation end)	:	11722.00	MW, at = 19:30 hrs				Rajshahi	1168	1168	0	Rangpur	770	770	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:30 hrs				Cumilla	968	968	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8066.00	MW, at = 5:00 hrs												
09.	Generation shortfall at evening peak due to :	:														
	a) Gas limitation	:	2997	MW												
	d) Coal supply Limitation	:	159	MW												
	b) Low water level in Kapali lake	:	184	MW												
	c) Plants under shut down/ maintenance	:	3118	MW												
10.	Total Energy (Generation + India Import)	:	238.87	MKWh												
	By Gas =	111.980	MKWH	By Oil =	89.910	MKWh										
	By Coal =	14.621	MKWH	By Hydro =	0.987	MKWh										
	By Solar=	1.470	MKWH													
11.	Total Gas Supplied	:	856.49	MMCFD												
(D) Forecast of 11.03.22 (Today) Friday :																
01.	Maximum Demand	:	11000	MW (Generation end)		04.	Maximum Load-shed							0	MW	At evening peak (Sub-station end)
02.	Maximum Generation	:	13053	MW (Generation end)		05.	Total Generation							224.16	MKWh	
03.	Reserve / Shortage	:	2053	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :							34.2° C		

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation