

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month March, 2022					Day : Saturday				Date : 12.03.22				
Probable Maximum Demand : 11100 MW					Probable Maximum Generation : 12984 MW				Rule Curve = 91.24 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 89.10 ft.				Today = 88.98 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.03.22 (Yesterday)		12.03.22 (Today)		11.03.22 (Yesterday)		12.03.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	320	320	320	320				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	106	108	108				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Under maint.	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	240	260	270	270	190		Dirty in gas	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	90	95	150	150	217	118	STG Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	240	240	240	240				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	40	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	93	93	93				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	20	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	40	52	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	30	30				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	26	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	72	90	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	100	150	150				
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	274	280	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	134	145	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	200	300				
28	Bramrangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
29	Aurhatt 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	36	100	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	93	93	93				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	34	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	40	55	55	55				
36	Kalpoti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
Dhaka Zone Total					5853	5696	2053	2535	3035	3105	1067	1370	
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	28	46	46	202	Low water level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0				
40	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	4	25	25	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	50	50	50				
43	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	87	105	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	282	300	300	300				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	100	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
49	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
51	Barabubunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			16	40	15	30				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x107	108	108	89	97	95	100				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	55	54	54	54				
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	76	92	110	110				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	100	60	100				
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	95	113	113	113				
Chattogram Zone Total					2442	2382	951	1155	1239	1274	562	375	
58	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	26	29	29				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	182	214	220	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	270	345	350				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	325	335				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	52	16	55	55				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	55	55	55	55	140	Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	145	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	30	42				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	50	0	0				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	100	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	25	25	25				
73	Jangalia 52 MW PP (Lakdenavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.015+15x1.08	200	200	0	0	100	200				
76	Feni 114 MW Power Plant(Lakdenavi)	HFO (IPP)	7x18.415+1x9.78	114	114	52	114	114	114				
77	Chowmuhani 11.3 MW	HFO (IPP)	12x9.79+2x3.1	113	113	97	115	113	113				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	36	36				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	27	100	115	115				
80	Import (Tribuna)	India		160	160	100	116	138	163				
Cumilla Zone Total					3059	3014	1462	1789	2207	2364	403	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	105	141	150	150	61	Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	99	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	183	186	190	190				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0				
86	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	18	22	22	22				
Mymensingh Zone Total					717	622	484	468	549	497	61	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.03.22 (Yesterday)		12.03.22 (Today)		11.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30	40	GT 1 & GT Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	42	42	60	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	50	50	50				
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	0	0	53	Gas Shortage		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	57	60	60				
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	135	134	150	150	196	Gas Shortage		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	0	86	86				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231	Under maint.		
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Under HGPI		
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	22	22	22				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	330	330				
100	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	401	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0	383	Filter replacement ongoing		
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
Sylhet Zone Total				2422	2377	1221	1134	1191	1191	249	351		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	280	320	350	350	90	Gas shortage		
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	35				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
107	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	220	220				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	94	94	105	105				
110	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	50	100				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	719	720	734	734				
Khulna Zone Total				2233	2229	1183	1167	1609	1684	90	0		
112	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	26	10	10				
114	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	90	91	90	92				
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11				
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	470	620	620	774	Line Overload		
117	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150				
118	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	200	220	225	225				
Barishal Zone Total				2046	2046	612	818	1116	1218	0	774		
119	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	34	34	34				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	35	40	41				
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	94	100	100				
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	38	0	40				
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	29	25	30				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	136	140	200	200	80	Gas Shortage		
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	130	196	200	220				
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414	Under maint.		
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22	22				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	113	113				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total				2129	2129	670	905	1163	1223	461	414		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	199	200	200	75	Coal shortage		
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode		
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	99	110	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode		
142	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
143	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)		115	115	18	92	115	115				
Rangpur Zone Total				800	720	322	401	436	428	160	85		
Sub-total: Plants in operation				21701	21215	8958.0	10372	12545	12984	3053	3369		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						8543	9891	11963	12382				
(B) Plants under long term maintenance/ contract expired													
144	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		Forced Outage		
145	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired		
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020		
148	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0		Contract Expired on 07/05/2021		
149	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0		Contract Expired on 31/05/2021		
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0		Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired				595	0	0	0	0	0				
Gross Total				22296	21215	8958	10372	12545	12984	3053	3369		
(C) Actual data of 11.03.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	10372.00	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9891.00	MW, at = 19:30 hrs		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10372.00	MW, at = 19:30 hrs		Dhaka	3323	3323	0	Mymensingh	944	944	
04.	Minimum Generation (Generation end)	:	8066.00	MW, at = 5:00 hrs		Chattoogram	1067	1067	0	Sylhet	431	431	
05.	Day-peak Generation (Generation end)	:	8958.00	MW, at = 12:00 hrs		Khulna	1158	1158	0	Barishal	270	270	
06.	Evening-peak Generation (Generation end)	:	10372.00	MW, at = 19:30 hrs		Rajshahi	1060	1060	0	Rangpur	721	721	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 19:30 hrs		Cumilla	917	917	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7575.00	MW, at = 5:00 hrs						Total	9891	9891	
09.	Generation shortfall at evening peak due to :	:										0	
	a) Gas limitation	:	2691	MW	13.	Fuel cost :	(a) Gas = 113215488 Taka	(c) Coal = 66849409 Taka					
	d) Coal supply Limitation	:	160	MW		(b) Oil = 507261524 Taka	Total = 687326420 Taka						
	b) Low water level in Kapali lake	:	202	MW									
	c) Plants under shut down/ maintenance	:	3369	MW									
10.	Total Energy (Generation + India Import)	:	218.05	MKWh	14.	Maximum Temperature in Dhaka was : 32.8° C							
	By Gas = 108.279 MKWH			By Oil = 72.928 MKWh	15.	Export through East-West interconnections :							
	By Coal = 14.083 MKWH			By Hydro = 0.913 MKWh		At evening peak-hour	:	-126	MW, at 19:30 hrs				
	By Solar= 1.468 MKWH					Maximum	:	-244	MW, at 19:00 hrs				
11.	Total Gas Supplied	:	809.52	MMCFD		Energy	:	0.423	MKWh				
(D) Forecast of 12.03.22 (Today) Saturday :													
01.	Maximum Demand	:	11100	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	12984	MW (Generation end)	05.	Total Generation : 233.35 MKWh							
03.	Reserve / Shortage	:	1884	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 33.7° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation