

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month March, 2022					Day : Monday				Date : 14.03.22				
Probable Maximum Demand : 12400 MW					Probable Maximum Generation : 13055 MW				Rule Curve = 90.92 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 88.92 ft.				Today = 88.86 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.03.22 (Yesterday)		14.03.22 (Today)		13.03.22 (Yesterday)		14.03.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	320	300	320	320				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	101	102	108	108				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Under maint.	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	240	240	270	270	210		Dirty in gas	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	90	90	100	150	217	118	STG Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	215	265	285	300	70		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	45	55	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	30	30				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	50	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	103	105	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150				
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	281	298	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	300	302	200	300				
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100				
29	Aurath 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	92	93	93				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	29	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	37	48	55	55				
36	Kalptoti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
Dhaka Zone Total					5853	5696	2914	2990	3030	3165	1157	1370	
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184	Low water level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	3	0	5	0					
40	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	0	49	50	50				
43	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300				
47	Juldah 100 MW Unit-1 (Acon)	HFO (QRPP)	8x13.45	100	100	80	100	100	100				
48	Juldah 100 MW PP Unit-3 (Acon)	HFO (IPP)	8x13.45	100	100	76	90	90	90				
49	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	25	10	20				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x10.8	108	108	90	97	95	100				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	112	110	110				
56	Juldah unit-2 (Acon)	HFO (IPP)	8x13.6	100	100	90	100	100	100				
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	92	113	113	113				
Chattogram Zone Total					2442	2382	1093	1267	1274	1264	544	375	
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	29	29	29				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	164	219	220	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	0	0	0	360	Machine problem		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	315	360	360				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	40	55	55				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	73	55	55	122	Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	150	141	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	50	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	81	87	40	40				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	195	200	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	19	26	25	25				
73	Jangalia 52 MW PP (Lakdenavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	22	22				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+48x.315+15x1.388	200	200	200	200	100	200				
76	Feni 114 MW Power Plant(Lakdenavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	114	114	114				
77	Chowmuhani 11.3 MW	HFO (IPP)	12*9.78+2*3.1	113	113	109	115	113	113				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	36	36	36				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	98	99	100	100				
80	Import (Tribuna)	India		160	160	126	136	138	163				
Cumilla Zone Total					3059	3014	2038	2035	1943	2073	385	360	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	86	100	100	100	102	Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		Dependable cap. : 8MW		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	109	115	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	186	187	190	190				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0				
86	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22				
Mymensingh Zone Total					717	622	472	438	499	447	102	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.03.22 (Yesterday)		14.03.22 (Today)		13.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	42	42	60	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	48	50	50					
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Under maintenance			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	60	60	60					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	228	230	230	230	100	Gas Shortage			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231	Under maint.			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Under HGPI			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	21	22	22					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	280	330	330					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	364	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	230	230	383	Filter replacement ongoing			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work			
Sylhet Zone Total						2422	2377	1210	1143	1471	1471	100	544	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	140	385	410	270	Gas shortage			
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	0	35					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40					
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	140	220	220					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	67	99	100	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	91	105	105	105					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	50	0					
**	Bheramara (HVDC)	India		1000	1000	720	721	724	724					
Khulna Zone Total						2233	2229	973	1232	1634	1734	270	0	
112	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
113	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	27	10	10					
114	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	89	91	90	92					
115	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11					
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	550	620	620	694	Line Overload			
117	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	50	150					
118	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	215	217	225	225					
Barishal Zone Total						2046	2046	680	896	1116	1218	0	694	
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage			
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	43	43	43					
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	163	169	100	200					
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	6	44	44	44					
123	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	47	92	100	100					
124	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40					
125	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50					
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	25	30					
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage			
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	202	216	220	220					
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	210	220	200	220					
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414	Under maint.			
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52					
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	113	113					
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113					
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2129	2129	936	1193	1096	1255	381	414	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling			
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75	Coal shortage			
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode			
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	106	113	113	113					
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		Condenser mode			
142	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
143	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)	6*20	115	115	80	115	115	115					
Rangpur Zone Total						800	720	392	427	436	428	160	85	
Sub-total: Plants in operation						21701	21215	10708	11621	12499	13055	3099	3842	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								10190	11059	11894	12424			
(B) Plants under long term maintenance/ contract expired														
144	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
145	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
147	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
148	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
149	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						595	0	0	0	0				
Gross Total						22296	21215	10708	11621	12499	13055	3099	3842	
(C) Actual data of 13.03.22 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	11621.00 MW, at = 21:00 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11059.00 MW, at = 21:00 hrs				Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	11621.00 MW, at = 21:00 hrs											
04.	Minimum Generation (Generation end)	:	8149.00 MW, at = 5:00 hrs				Dhaka	4068	4068	0	Mymensingh	946	946	0
05.	Day-peak Generation (Generation end)	:	10708.00 MW, at = 12:00 hrs				Chattogram	1249	1249	0	Sylhet	434	434	0
06.	Evening-peak Generation (Generation end)	:	11621.00 MW, at = 21:00 hrs				Khulna	1243	1243	0	Barishal	288	288	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 21:00 hrs				Rajshahi	1161	1161	0	Rangpur	696	696	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8350.00 MW, at = 5:00 hrs				Cumilla	974	974	0				
09.	Generation shortfall at evening peak due to :	:					Fuel cost :		(a) Gas = 109818803 Taka	(c) Coal = 70412486 Taka				
	a) Gas limitation	:	2755 MW				(b) Oil = 819214350 Taka		Total = 999445639 Taka					
	d) Coal supply Limitation	:	160 MW											
	b) Low water level in Kapali lake	:	184 MW											
	c) Plants under shut down/ maintenance	:	3842 MW											
10.	Total Energy (Generation + India Import)	:	243.49 MKWh			14.	Maximum Temperature in Dhaka was : 34.2° C							
	By Gas = 105.478 MKWH	By Oil =	100.267 MKWh			15.	Export through East-West interconnections :							
	By Coal = 14.899 MKWH	By Hydro =	1.114 MKWh				At evening peak-hour : 122 MW, at 21:00 hrs							
	By Solar= 1.472 MKWH						Maximum Energy : 96 MW, at 7:00 hrs							
11.	Total Gas Supplied	:	816.90 MMCFD				Energy : 0.182 MKWh							
(D) Forecast of 14.03.22 (Today) Monday :														
01.	Maximum Demand	:	12400 MW (Generation end)			04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13055 MW (Generation end)			05.	Total Generation : 259.81 MKWh							
03.	Reserve / Shortage	:	655 MW (Generation end)			06.	Probable Max. Temperature in Dhaka : 35.3° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation