

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551055

Month March, 2022				Day : Saturday				Date : 26.03.22					
Probable Maximum Demand : 12600 MW				Probable Maximum Generation : 13901 MW				Rule Curve = 89.00 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 86.49 ft				Today = 86.25 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.03.22 (Yesterday)		26.03.22 (Today)		25.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
											Day	Evening	Day
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	200	200	40			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	190			Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	220	220	220	220				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	103	105	100	100				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0		105		Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	20			Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0		360		Under maint.	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	150			Dirty in gas	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0		412		Under maint.	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2x 105	210	210	0	97	97	97	113		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	0	0		118		STG Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	150	230	230	185		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	52	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	93	93	93				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	31	51	52	52				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	115	150	150	150				
24	Kamalganj 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	169	281	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	134	145	149	149				
27	Kariganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	200	300				
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	79	90	91				
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	157	144	144	162				
34	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	23	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
37	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	80	92	0	0				
38	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	49	83	0	0				
39	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	61	93	100	100				
Dhaka Zone Total					6155	5696	2589	2773	3173	3262	698	1370	
40	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	67	70	70	163		Low water level	
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30		Gas Shortage	
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25				
44	Teknaf 20MW PP (Soltarack)	Solar (IPP)	1x20	20	20	0	0	20	0				
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	25	25	25				
46	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	35	202	200	200				
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	281	300	300				
50	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	50	100	100	100				
51	Julda 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
52	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
54	Barabunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			11	40	15	30				
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	44	105	100	100				
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
57	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
58	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	80	100	100	100				
59	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	113	113	113	113				
Chattogram Zone Total					2442	2382	1241	1618	1633	1623	373	150	
60	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
61	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	29	29	29				
62	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	187	219	220	220				
63	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	280	280	310				
64	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	280	280	310				
65	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	53	55	55	55				
66	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	45	8	45	45	187		Gas Shortage	
67	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
68	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	133	150	150				
69	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	32	41				
70	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	136	137	137				
71	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	2	200	200	200				
72	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
73	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
74	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25				
75	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	29	43	43				
76	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	19	22	22				
77	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.315+15x1.358	200	200	0	0	100	200				
78	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	99	99	99				
79	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	105	115	113	113				
80	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
81	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	24	98	100	100				
**	Import (Tripura)	India		160	160	86	98	138	163				
Cumilla Zone Total					3059	3014	1617	1980	2147	2378	450	0	
82	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	100	140	100	140	62		Gas Shortage	
83	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
84	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : 8MW	
85	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	98	106	106				
86	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	179	190	200	200				
87	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
88	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	29	0	50	0				
89	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymensingh Zone Total					717	622	448	469	497	485	62	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.03.22 (Yesterday)		26.03.22 (Today)		25.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
90	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT1 Under maint.	
91	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
92	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	47	47	47				
93	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	10	70	163	163				
94	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11				
95	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	55	60	60				
96	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110-1x110	330	330	261	269	220	270	61		Gas Shortage	
97	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	87	86	86				
98	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.	
99	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGPI	
100	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
101	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	16	22	24				
102	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222-1x119	341	341	280	280	300	300				
103	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	316	403	400	400				
104	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252-1x131	383	383	0	0	0	0				
105	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
	Sylhet 50MW PP (EPL)	Gas (RPP)	2x27			5	5	0	0				
	Fenchugonj 44MW (Energyprime)	Gas (RPP)	12'3.3-5'2			6	12	0	0				
Sylhet Zone Total				2422	2377	1121	1325	1379	1431	61	451		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	225	220	225	225	190		Gas shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	120	215	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	7x61.4+7x1.515	100	100	0	0	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	92	105	105	105				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	85	0	50	0				
115	Khulna 115 MW PP (KPLCL-2)	HFO (QRPP)	7x17	115	0	0	30	0	0				
	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5'8.5			16	24	0	0				
**	Bheramara (HVDC)	India		1000	1000	710	712	729	729				
Khulna Zone Total				2348	2229	1248	1346	1434	1454	190	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	80				
117	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	29	25	30				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	60	67	65	65				
119	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	560	660	660		684	Line Overload	
121	Potakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyt B)	Gas/HSD	2x75+1x70	220	220	217	220	220	220				
Barishal Zone Total				2046	2046	617	892	970	1055	0	684		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	36	40	40				
127	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	90	90				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	42	43				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	25	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	200	214	220	220				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	175	211	220	220				
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	131	131	148	148	89		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	276	376	350	350				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	20	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	43	43	43				
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	95	95				
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	90	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2129	2129	1035	1511	1559	1704	260	0		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	77	81	77	81				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	93	109	113	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
146	Majpara, Talata 8 MW Solar PP (Sympha Powe	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)	6'20	115	115	115	115	115	115				
Rangpur Zone Total				800	720	491	504	513	509	75	85		
Sub-total: Plants in operation				22118	21215	10407.0	12418	13305	13901	2169	2740		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10113	12067	12928	13508				
(B) Plants under long term maintenance/ contract expired													
148	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Bogura 20 MW PP (Energyprime)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				178	0	0	0	0	0				
Gross Total				22296	21215	10407	12418	13305	13901	2169	2740		
(C) Actual data of 25.03.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	12418.00	MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12066.73	MW, at = 20:00 hrs		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12418.00	MW, at = 20:00 hrs		4194	4194	0	Mymensingh	1041	1041	0	
04.	Minimum Generation (Generation end)	:	9686.00	MW, at = 9:00 hrs		Chattoogram	1232	1232	0	Sylhet	450	450	0
05.	Day-peak Generation (Generation end)	:	10407.00	MW, at = 12:00 hrs		Khulna	1434	1434	0	Barishal	320	320	0
06.	Evening-peak Generation (Generation end)	:	12418.00	MW, at = 20:00 hrs		Rajshahi	1398	1398	0	Rangpur	859	859	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 20:00 hrs		Cumilla	1139	1139	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9708.00	MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :	:								Total	12067	12067	0
	a) Gas limitation	:	1931	MW									
	d) Coal supply Limitation	:	75	MW									
	b) Low water level in Kapata lake	:	163	MW									
	c) Plants under shut down/ maintenance	:	2740	MW									
10.	Total Energy (Generation + India Import)	:	267.82	MKWh									
	By Gas = 126.138 MKWH			By Oil = 101.076 MKWh									
	By Coal = 18.441 MKWH			By Hydro = 1.697 MKWh									
	By Solar= 1.076 MKWH												
11.	Total Gas Supplied	:	1050.74	MMCFD									
(D) Forecast of 26.03.22 (Today) Saturday :													
01.	Maximum Demand	:	12600	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13901	MW (Generation end)	05.	Total Generation : 267.05 MKWh							
03.	Reserve / Shortage	:	1301	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 38° C							