

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551055

Month March, 2022										Day : Tuesday		Date : 29.03.22	
Probable Maximum Demand :					13400 MW		Probable Maximum Generation : 14525 MW						
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 85.79		Today = 85.55						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.03.22		29.03.22		28.03.22		29.03.22		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	220	220	220				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	93	100	100				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		360	Under maint.	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	300	280	280	150		Dirt in gas	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	95	91	100	100	119		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	83	220	220	220		118	STG Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	150	150	150	185		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	84	93	93	93				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	22	22				
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	55	55	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	50	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	133	150	150	150				
24	Kamalganj 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	263	281	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	149	149	149				
27	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	126	200	300				
28	Bramhaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	70	100	100				
30	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	53	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	90	90	90				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	144	144				
34	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	33	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55				
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
37	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	58	91	70	100				
38	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	66	100	100	100				
39	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	40	80	84	84				
Dhaka Zone Total					6155	5696	2714	3316	3453	3553	664	1370	
40	Kamaghul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	71	70	70		159		Low water level
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	150	150	150	150	30		Gas Shortage	
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	6	25	25	25				
44	Teknaf 20MW PP (Soltartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	25	25	25				
46	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	87	87	105	105				
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	205	203	200	200				
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300				
50	Julidah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
51	Julidah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
52	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	2	34	0	50				
54	Barabunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	10	10	20				
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	89	103	100	100				
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
57	Kamaghul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	93	110	110				
58	Julidah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	93	100	100	100				
59	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	113	113	113	113				
Chattogram Zone Total					2442	2382	1419	1509	1528	1563	369	150	
60	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
61	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	29	29	29				
62	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	183	144	220	220				
63	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	265	300	310				
64	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	270	320	330				
65	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	50	37	5	5				
66	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	26	8	8	8	187		Gas Shortage	
67	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51				
68	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	132	150	150	150				
69	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	42	32	42				
70	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	137	137	137				
71	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	71	200	200	200				
72	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
73	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
74	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	0	25	25				
75	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	40	43	43	52				
76	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	22	22				
77	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.358	200	200	0	130	100	200				
78	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	81	99	99	99				
79	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	103	113	113	113				
80	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
81	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	63	99	100	100				
**	Import (Tripura)	India		160	160	150	86	138	163				
Cumilla Zone Total					3059	3014	1845	1975	2157	2321	450	0	
82	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	107	104	110	110	98		Gas Shortage	
83	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
84	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. : BMW	
85	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	78	107	106	107				
86	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	173	200	200	200				
87	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
88	Satkhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0				
89	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymensing Zone Total					717	622	444	452	507	456	98	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.03.22 (Yesterday)		29.03.22 (Today)		28.03.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
90	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT1 Under maint.	
91	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
92	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	47	50	50				
93	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
94	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11				
95	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60				
96	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	269	271	270	270				
97	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86				
98	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	100	100	100	100	131		Gas Shortage	
99	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under HGPI	
100	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
101	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
102	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	300	300				
103	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	387	399	400	400				
104	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0				
105	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
	Sylhet 50MW PP (EPL)	Gas (RPP)	2x27			18	20	20	20				
	Fenchugonj 44MW (Energyprime)	Gas (RPP)	12'3.3+5'2			26	26	20	25				
Sylhet Zone Total						2422	2377	1555	1580	1574	1579	131	220
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	175	270	240	240	140		Gas shortage	
108	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	35	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	140	210	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	7x61.4+7x1.515	100	100	0	50	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	79	94	105	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	50	0				
115	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	62	95	100	115				
	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5'8.5			32	32	32	32				
**	Bheramara (HVDC)	India		1000	1000	903	903	915	915				
Khulna Zone Total						2348	2229	1485	1689	1767	1802	140	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	80				
117	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	26	36	25	35				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	66	66	65	67				
119	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	0	0	0	0				
120	Payra 1320 MW TPP	Coal (BOCPL)	2x622	1244	1244	460	610	660	660		634	Line Overload	
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	100				
122	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220				
Barishal Zone Total						2046	2046	790	964	1002	1162	0	634
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	70	100	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	6	36	40	42				
127	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	90	93				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	12	32	0	32				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	42	43				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	30	36				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	200	214	150	150			Running on HSD	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	151	193	220	220				
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	140	140	140	220		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	282	290	270	280	124		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	34	43	43				
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	90	95	95	113				
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	891	1333	1406	1581	515	0
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	78	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200	200	74		Coal shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	17	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	103	109	113	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	10	0	0				
146	Majpara, Tatala 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)	6'20	115	115	115	115	115	115				
Rangpur Zone Total						800	720	499	529	516	508	74	85
Sub-total: Plants in operation						22118	21215	11642.0	13347	13910	14525	2441	2459
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								11241	12887	13430	14024		
(B) Plants under long term maintenance/ contract expired													
148	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Bogura 20 MW PP (Energyprime)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
150	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						178	0	0	0	0	0		
Gross Total						22296	21215	11642	13347	13910	14525	2441	2459
(C) Actual data of 28.03.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	13347.00	MW,	at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12887.03	MW,	at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	13347.00	MW,	at =	19:30 hrs							Load Shed MW
04.	Minimum Generation (Generation end)	:	10353.00	MW,	at =	7:00 hrs	Dhaka	4742	4742	0	Mymensingh	1059	1059
05.	Day-peak Generation (Generation end)	:	11642.00	MW,	at =	12:00 hrs	Chattoagram	1307	1307	0	Sylhet	405	405
06.	Evening-peak Generation (Generation end)	:	13347.00	MW,	at =	19:30 hrs	Khulna	1617	1617	0	Barishal	370	370
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	19:30 hrs	Rajshahi	1519	1519	0	Rangpur	869	869
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10314.00	MW,	at =	5:00 hrs	Cumilla	1000	1000	0			
09.	Generation shortfall at evening peak due to :	:									Total	12887	12887
	a) Gas limitation	:	2208	MW								96231770	Taka
	d) Coal supply Limitation	:	74	MW								1037349563	Taka
	b) Low water level in Kapali lake	:	159	MW									
	c) Plants under shut down/ maintenance	:	2459	MW									
10.	Total Energy (Generation + India Import)	:	284.00	MKWh									
	By Gas =	133.964	MKWh	By Oil =	102.392	MKWh							
	By Coal =	20.090	MKWh	By Hydro =	1.680	MKWh							
	By Solar=	1.245	MKWh										
11.	Total Gas Supplied	:	1105.40	MMCFD									
(D) Forecast of 29.03.22 (Today) Tuesday :													
01.	Maximum Demand	:	13400	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14525	MW	(Generation end)		05.	Total Generation	:	285.13	MKWh		
03.	Reserve / Shortage	:	1125	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.3° C			

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation