POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date : 3-Apr-22 Till now the maximum generation is:-13792.0 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 7:00 Available Max Generation : The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : Generation & Demand 10811.0 MW 2-Apr-22 Hour 12:00 10322 MW 21:00 21:00 13718.0 MW E.P. Demand (at gen end) 13718.0 MW Hour Max Demand (Evening) 13800 MW Maximum Generation 13730.0 MW Hour 22:00 Reserve(Generation end) 54 MW 278.8 System Load Factor : 84.62% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 8 MW 2.00 Energy MKWHR Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on MW 3-Apr-22 Ft.(MSL) Actual : 84.36 Rule curve 87.60 Ft.(MSL) Total = 1049.30 MMCFD. Oil Consumed (PDB): Gas Consumed HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk138.588.948 Tk95,090,941 Oil Tk780,023,760 Total: Tk1,013,703,649 **Load Shedding & Other Information** Area Yesterday Today Estimated Shedding (S/S end) Estimated Demand (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) 0% 4932 1684 0 Chittagong Area 0:00 0% 0% 0% 0% Khulna Area ٥ 0.00 1510 Rajshahi Area 1365 1234 0 0 Cumilla Area 0:00 Mymensingh Area Sylhet Area 995 547 256 0% 0% 0% 0:00 0 0 . Barisal Area 0:00 Rangpur Area Total 0:00 768 0% Information of the Generating Units under shut down Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-2 2) Ghorasal-3.5 3) Ashuganj-4,5 4) Baghabari-71.100 MW 5) Raozan unit- 1 6) Siddhirganj 210 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) Meghnaghat Summit GT-2 was forced shut down at 11:20 due to low gas pressure. a) weighnaginat outlinini G12 was noticed sint own at 11.20 due to low gap pessure. b) Jamalpur 132/33 kV T-3 transformer along with 33 kV Bus were under shut down from 08:11 to 11:53 for C/M. c) Kabirpur-Manikganj 132 kV Ckt-1 was under shut down from 08:43 to 11:28 for C/M. d) Khulshi-Sholoshahar 132 kV Ckt was under shut down from 09:03 to 15:35 for C/M. e) Sholoshahar-Madunaghat 132 kV Ckt was under shut down from 09:20 to 15:19 for C/M. f) Bogura(N)-Naogaon 132 kV Ckt-1 tripped at 09:10 from Bogura(N) end showing lock out,trip Ckt faulty, directional O/C AR block and was switched on at 09:35. g) Siddhiganj-Matuail 132 kV Ckt tripped at 08:36 from Matuail end showing Dist. Z1,C,E/F and was switched on at 08:47. h) BSRM 230/33 kV T02 transformer was under shut down from 09:30 to 7:36 for C/M. in Borkin 2003 V to 2 dailsoftner was under shut down from 11:31 to 13:46 for C/M. j) Panchagarh 132/33 kV T-3 transformer was under shut down from 08:13 to 11:57 for R/H maintenance. k) Barishal 230/132 kV ATR-2 transformer was under shut down from 11:20 to 14:52 for C/M. N Pagisa (2001) 24 V 114-2 talisationing was under state countries in 12-2 to 14-32 to 15-32. I) Payra (P)P-Gopalganj (new) 400 kV Ckt-1 was charged at 12-07 from Payra end. In) Gopalganj (new)-Rampal 400 kV Ckt-1 tripped at 14:20 showing Dist. Z1, C at Gopalganj (new) end and E/F relay at Rampal end and this Ckt was released at 17:28 for Maintenance work Joydevpur 132/33 kV T-2 transformer tripped at 18:55 due to Ct burst at 33 kV Sreepur PBS-2 feeder and was switched on at 19:29. About 100 MW power interruption occurred under Joydevpur S/S area from 18:55 to 19:29. p) Purbasadipur 132/33 kV T-2 transformer tripped at 15:34 due to 33 kV feeder fault and was switched on at 15:43 About 20 MW power interruption occurred under Madaripur S/S area from 14:11 to 17:43. About 20 MW power interruption occurred under q) Madaripur 132/33 kV T-3 transformer was under shut down from 14:11 to 17:43 for C/M.

r) Baraulia 132/33 kV T-2 transformer was under shut down from 14:50 to 17:16 for C/M.

s) Baghabari 132 kV both Bus tripped at 15:40 due to Baghabari-Shahjadpur 132 kV Ckt-2 Bay CT burst and were switched on at 16:17.

t) Baghabari-Bhangura 132 kV Ckt tripped at 15:40 due to Baghabari Bus fault and was switched on at 16:27.

u) Baghabari-Shahjadpur 132 kV Ckt-2 was under shut down from 15:40 to 22:28 for CT oil leakage maintenance.

y Payra-Gopaiganj(New) 400 kV Ckt-1 was shut down at 22:25 for flashing from CVT at Payra P/P and.
w) Cox'sbazar 132/33 kV T-1,T-2 & T-2 transformer were shut down at 22:40 for fire originated from 11 kV
PDB feeder and T-1 was switched on at 00:12(03/4/2022) and T-3 was switched on at 00:21.

x) Dohazari-Cox'sbazar 132 kV Ckt-2 tripped at 05:03(03/4/2022) from both ends showing Dist. Z1 at Dohazari end and Dist. 3-phase at Cox'sbazar end and was switched on at 05:33.

Sub Divisional Enginee

Network Operation Division

Executive Enginee Network Operation Division Superintendent Engineer Load Despatch Circle

Baraulia S/S area from 14:50 to 17:16.

About 27 MW power interruption occurred under Bhangura S/S area from15:40 to 16:27

About 100 MW power interruption occurred under Cox'sbazar S/S area from 22:40 to 00:21.