

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2022				Day : Monday				Date : 11.04.22					
Probable Maximum Demand : 14200 MW				Probable Maximum Generation : 15196 MW				Rule Curve = 86.00 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 82.39 ft.				Today = 82.00 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.04.22 (Yesterday)		11.04.22 (Today)		10.04.22 Gen. shortfall for : Gas/water/Coal limitation (MW)	11.04.22 Gen. shortfall for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening			Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	234	233	240	240				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	250	270	250	270				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	101	101	105	105				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	313	323	325	325				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	250	350	450	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	393	0	0	0				
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	60	60	110	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	1	280	280	334	Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	175	260	285	285	75	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	46	40	55	55				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	84	93	84	93				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22				
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	50	53	55	55				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	0	33	33				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	49	51	51				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	90	90	90				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	133	150	150	150				
23	Kamalghar 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	266	300	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
26	Kariganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	82	121	300	300				
27	Baramganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100				
29	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	35	35	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	35	144	162				
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	11	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	54				
35	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
36	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	100	100	100	100				
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	100	92	100	100				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	63	79	78	80				
Dhaka Zone Total				6055	5898	3216	3063	4072	4190	1179	590		
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	68	69	70	70	161	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
43	Teknaf 20MW PP (Soltartech)	Solar (IPP)	1x20	20	20	16	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	38	42	42				
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	105	105	105	105				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	203	230	230				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	285	300	300	300				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	51	85				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	40	0	42				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	16	30	40				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	81	87	100	100				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	113	113	113	113				
Chattogram Zone Total				2342	2282	1325	1434	1445	1506	521	150		
58	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	30	30				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	203	184	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	280	290	300	300	70	Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	150	150	300	300	210	Gas Shortage		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	135	130	135				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	40	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	30	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	42	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	21	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.315+15x1.056	200	200	40	70	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	80	80	80				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	108	115	113	113				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	36	78	78				
**	Impoport (Tripura)	India		160	160	162	160	143	166				
Cumilla Zone Total				3059	3014	1611	1712	1964	2092	780	0		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	133	163	160	160	39	Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	108	96	115				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	106	150	150	180				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0				
86	Sutahati 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	17	22	22				
Mymensingh Zone Total				717	622	405	458	500	497	39	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.04.22 (Yesterday)		11.04.22 (Today)		10.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	0	0	0	0		70	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	29	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	50	50				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	120	120	120				
92	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	60	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x100+1x110	330	330	0	0	0	0	330		Gas Shortage	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	85	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	60	173	200	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
99	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	19	23	24	24				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	305	320				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	372	370	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	17	26	28	29	24		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3-5*2	50	50	0	3	3	3	41		Gas Shortage	
Sylhet Zone Total						2522	2477	1372	1655	1738	1774	415	219
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	270	270	350	350	140		Gas shortage	
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	12	28	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	25	0	30				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	200	170	200	200				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	10	70	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	76	95	94	95				
113	Madhumati 100 MW PP	HSD (NWPGL)	6x18.415	105	105	15	85	100	100				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	50	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	93	115	115	115				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	31	40				
**	Bheramara (HVDC)	India		1000	1000	924	925	943	943				
Khulna Zone Total						2388	2384	1682	1823	1983	2013	140	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	64	32	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	27	38	25	35				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	88	90	90				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	300	540	550	660		704	Line Overload	
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	100			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	217	220	220	220				
Barishal Zone Total						1958	1958	661	967	934	1215	0	704
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	20	140	150	170				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	30	40	40				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	90	92				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	21	34	0	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	40	43				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	30	30				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	212	214	220	220			Running on HSD	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	193	161	170	170	59		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	381	415	400	415				
136	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	0	22	22	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	43	43	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total						2129	2129	1137	1497	1482	1574	440	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	80	80				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0				
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	17	0	17				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	84	104	113	113				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	8	0	10				
148	Majpara, Tabla 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
149	Thakurgaon 119MW PP (Energysec)	HFO (IPP)	6*20	115	115	115	115	115	115				
Rangpur Zone Total						800	720	204	244	316	335	0	85
Sub-total: Plants in operation						21970	21484	11613.0	12853	14434	15196	3514	1748
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								11264	12466	14000	14739		
(B) Plants under long term maintenance/ contract expired													
148	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
150	Jaldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						378	0	0	0	0	0		
Gross Total						22348	21484	11613	12853	14434	15196	3514	1748
(C) Actual data of 10.04.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	12853	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12466	MW, at = 19:30 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12853	MW, at = 19:30 hrs		Dhaka	4703	4703	0	Mymensingh	591	591	0
04.	Minimum Generation (Generation end)	:	10122	MW, at = 7:00 hrs		Chattogram	1347	1347	0	Sylhet	489	489	0
05.	Day-peak Generation (Generation end)	:	11613	MW, at = 12:00 hrs		Khulna	1685	1685	0	Barishal	393	393	0
06.	Evening-peak Generation (Generation end)	:	12853	MW, at = 19:30 hrs		Rajshahi	1382	1382	0	Rangpur	573	573	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 19:30 hrs		Cumilla	1303	1303	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9421	MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
a)	Gas limitation	:	3353	MW									
b)	Coal supply Limitation	:	0	MW									
c)	Low water level in Kapta lake	:	161	MW									
d)	Plants under shut down/ maintenance	:	1748	MW									
10.	Total Energy (Generation + India Import)	:	282.41	MKWh									
	By Gas = 125.809 MKWh			By Oil = 113.811 MKWh									
	By Coal = 13.958 MKWh			By Hydro = 1.673 MKWh									
	By Solar= 1.197 MKWh												
11.	Total Gas Supplied	:	988.00	MMCFD									
(D) Forecast of 11.04.22 (Today) Monday :													
01.	Maximum Demand	:	14200	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15196	MW (Generation end)	05.	Total Generation	:	312.01	MKWh				
03.	Reserve / Shortage	:	996	MW (Generation end)	06.	Probable Max. Temperature in Dhaka	:	34.1° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 14008 MW on 07-04-2022 at 22:00

(Md. Helakar Rahman)
Deputy Secretary, Generation