

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2022				Day : Wednesday				Date : 13.04.22					
Probable Maximum Demand : 14600 MW				Probable Maximum Generation : 15309 MW				Rule Curve = 85.60 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 81.76 ft.		Today = 81.37 ft.							
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.04.22 (Yesterday)		13.04.22 (Today)		12.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	233	232	230	230				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	220	250	250	250				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	102	100	100				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	308	324	150	300				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	350	350	225	225				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	365	396	400	400				
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		110		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	280	333	150	335				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	285	250	150	150		85	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	92	93	93				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	22	19	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	43	51	55	55				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.73	33	33	33	33	33	33				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.73	33	33	33	33	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	50	51	51				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	90	70	90				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	100	150	150	150				
23	Kamalganj 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	235	273	300	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
26	Karaganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	255	300	300				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100				
28	Aurabati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	80	100	100				
29	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	144	162				
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	32	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55	55				
35	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
36	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	50	100	100	100				
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	94	91	100	100				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	63	78	80	80				
Dhaka Zone Total				6055	5898	3459	4424	3940	4286	210	675		
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	68	69	70	70	161		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0					
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	25	25				
43	Teknaf 20MW PP (Soltartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	37	40	40				
45	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	105	105	105	105				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	211	204	215	215				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	282	300	300	300				
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	90	90				
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	85				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	34	0	35				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	25	10	25				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	81	81	80	86				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	111	113	113	113				
Chattogram Zone Total				2342	2282	1266	1432	1388	1453	341	330		
58	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	211	212	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	280	320	350				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	49	54	55	55				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	55	8	8	8	187		Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	80	140	130	150				
67	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	40	40				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	20	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	20	20	20				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.315+15x1.358	200	200	0	100	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	80	80	80				
77	Chowmuhan 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	116	113	113				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	101	90	100				
**	Impoport (Tripura)	India		160	160	142	164	143	166				
Cumilla Zone Total				3059	3014	1284	1737	1731	1914	450	523		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	106	108	90	80	94		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20				
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	95	106	106	115				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	158	179	190	190				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutahati 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22				
Mymensingh Zone Total				717	622	442	435	480	427	94	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.04.22 (Yesterday)		13.04.22 (Today)		12.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW Machines shut down (MW)		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	0	0	0	0		70	GT1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	10	10	10	10				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	55	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x100+1x110	330	330	0	264	270	270	66		Gas Shortage	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	86	86				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	219	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	23	24	24				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	290	310	320				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	370	370	370	370				
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	382	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	27	27	26	27	23		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	3	3	3	3	41		Gas Shortage	
Sylhet Zone Total						2522	2477	1662	1953	2003	2014	220	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	370	405	400	400				
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	30				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	210	200	200				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	16	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	105	94	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	32	105	67	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	42	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	97	115	115				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	40	40				
**	Bheramara (HVDC)	India		1000	1000	923	922	941	941				
Khulna Zone Total						2388	2384	1565	1936	2057	2076	0	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	32	48	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	39	33	33				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	86	90	90				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	420	550	660	824		Line Overload	
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	35	17	100			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyt BL)	Gas/HSD (IPP)	2x75+1x70	220	220	215	170	220	220				
Barishal Zone Total						1958	1958	728	782	958	1213	0	824
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	9	150	170				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	30	40	40				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	16	92	90	92				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	40	43				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	30	36				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	130	213	220	220			Running on HSD	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	170	209	180	180				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	355	418	414	414				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	43	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total						2129	2129	982	1426	1506	1589	381	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	79	80	82				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.	
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	98	104	113	113				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
148	Majpara, Tabla 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
149	Thakurgaon 119MW PP (Energysec)	HFO (IPP)	6*20	115	115	52	115	115	115				
Rangpur Zone Total						800	720	238	298	316	337	0	359
Sub-total: Plants in operation						21970	21484	11626.0	14423	14379	15309	1626	2931
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								11224	13924	13882	14780		
(B) Plants under long term maintenance/ contract expired													
148	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
150	Juidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						378	0	0	0	0	0		
Gross Total						22348	21484	11626	14423	14379	15309	1626	2931
(C) Actual data of 12.04.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14423	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13924	MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14423	MW, at = 21:00 hrs		Dhaka	4982	4982	0	Mymensingh	1087	1087	0
04.	Minimum Generation (Generation end)	:	10211	MW, at = 7:00 hrs		Chattogram	1375	1375	0	Sylhet	550	550	0
05.	Day-peak Generation (Generation end)	:	11626	MW, at = 12:00 hrs		Khulna	1841	1841	0	Barishal	391	391	0
06.	Evening-peak Generation (Generation end)	:	14423	MW, at = 21:00 hrs		Rajshahi	1585	1585	0	Rangpur	747	747	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 21:00 hrs		Cumilla	1366	1366	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10229	MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	1465	MW									
	b) Coal supply Limitation	:	0	MW									
	c) Low water level in Kapta lake	:	161	MW									
	d) Plants under shut down/ maintenance	:	2931	MW									
10.	Total Energy (Generation + India Import)	:	383.56	MKWh									
	By Gas = 243.426 MKWh			By Oil = 99.271 MKWh									
	By Coal = 12.327 MKWh			By Hydro = 1.661 MKWh									
	By Solar = 1.057 MKWh												
11.	Total Gas Supplied	:	1134.90	MMCFD									
(D) Forecast of 13.04.22 (Today) Wednesday :													
01.	Maximum Demand	:	14600	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15309	MW (Generation end)	05.	Total Generation	:	388.27	MKWh				
03.	Reserve / Shortage	:	709	MW (Generation end)	06.	Probable Max. Temperature in Dhaka	:	38.4° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 14423 MW on 12-04-2022 at 21:00

(Md. Helakar Rahman)
Deputy Secretary, Generation