

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2022				Day : Thursday				Date : 21.04.22					
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 15431 MW				Rule Curve = 84.00 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 79.01 ft.				Today = 78.93 ft.					
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.04.22 (Yesterday)		21.04.22 (Today)		20.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	248	245	245				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	280	280	280				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	89	100	100				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	192	345	320	340				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	320	380	380				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	336	385	400	400				
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		110		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	S/d for filter changing	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	130	150	150	205		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	40	84	84				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	25	53	55	55				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.73	33	33	0	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.73	33	33	0	33	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	52	52	52				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	32	132	132				
23	Kamalganj 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	30	280	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	2	0	149	149				
26	Karanganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	300	300				
27	Banranganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
28	Aurabati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	0	35	55	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	53	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	144	162	162				
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	11	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	17	32	55	55				
35	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
36	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	0	0	90	100				
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	96	90	100				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	15	64	80	80				
Dhaka Zone Total				6055	5898	1450	2739	4150	4180	415	925		
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	62	65	65	168		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0				
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25				
43	Teknaf 20MW PP (Soltartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	38	40	40				
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	0	34	105	105				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	202	215	215				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	80	300	300	300				
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	50	90	90	90				
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	51				
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	50	50				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			0	0	5	10				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	95	95	95				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54				
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	110	110	110				
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	10	100	100				
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	0	68	113	113				
Chattogram Zone Total				2342	2282	448	1102	1465	1445	348	330		
58	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	28	28	30	30				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	204	190	200	225				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	290	280	300	330				
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	57	15	55	55				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	10	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	101	100	100				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	12	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	6	20	21				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+15x1.058	200	200	0	0	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	60	62				
77	Chowmuhan 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	115	114	114				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	17	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	17	101	101				
**	Imphort (Tripura)	India		160	160	54	106	143	166				
Cumilla Zone Total				3059	3014	741	1014	1826	2007	450	0		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	70	106	106	106	96		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20				
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	15	115	100	115				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	150	190	200				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
86	Sutikahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	22	22	22				
Mymensingh Zone Total				717	622	113	413	490	463	96	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.04.22 (Yesterday)		21.04.22 (Today)		20.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	0	0	0	0				
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	18	20	41	41		70	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	22	22	22				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	60	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x100+1x110	330	330	127	158	160	160	172		Gas Shortage	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	76	76	81	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	140	140	140	91		Gas Shortage	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10				
99	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	24	22	22				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	300	310	330				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	325	400	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	401	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	15	15				
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	5	5	5	44		Gas Shortage	
Sylhet Zone Total						2522	2477	1423	1785	1840	327	170	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	290	300	330	120		Gas Shortage	
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	36				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	63				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	40	200	200				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	94	76	94				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	105	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	66	115				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	32	32				
**	Bheramara (HVDC)	India		1000	1000	919	484	937	937				
Khulna Zone Total						2388	2384	1446	940	1946	120	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	50	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	11	24	33	33				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	94	91	91				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	220	590	620	620				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	150	150			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyt BL	Gas/HSD (IPP)	2x75+1x70	220	220	154	223	220	220				
Barishal Zone Total						1958	1958	509	1014	1164	0	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	200				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	0	92	92				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	34				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	130	110	200	200				
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	200	210				
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	325	415	400	410				
136	Bogra 22 MW PP (QBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	5	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	35	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total						2129	2129	513	674	1477	391	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	77	80	76	80				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	65	110	110				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
149	Thakurgaon 119MW PP (Energysec)	HFO (IPP)	6*20	115	115	0	17	115	115				
Rangpur Zone Total						800	720	277	362	509	0	85	
Sub-total: Plants in operation						21970	21484	6920	10043	14867	15341	1510	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						6758	9808	14596	15069				
(B) Plants under long term maintenance/ contract expired													
148	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
149	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
150	Juddha 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	0	0	80	90				
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						378	0	0	80	90			
Gross Total						22348	21484	6920	10043	14947	15431	2147	1510
(C) Actual data of 20.04.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10043	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9808	MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13476	MW, at = 1:00 hrs		Dhaka	3710	3710	0	Myensingh	742	742	0
04.	Minimum Generation (Generation end)	:	4262	MW, at = 8:00 hrs		Chattogram	994	994	0	Sylhet	373	373	0
05.	Day-peak Generation (Generation end)	:	6920	MW, at = 12:00 hrs		Khulna	1354	1354	0	Barishal	309	309	0
06.	Evening-peak Generation (Generation end)	:	10043	MW, at = 21:00 hrs		Rajshahi	1017	1017	0	Rangpur	609	609	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 21:00 hrs		Cumilla	699	699	0				
08.	Minimum Generation Forecast up to 8.00 hrs.	:	7077	MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :	:								Total	9808	9808	0
a)	Gas limitation	:	1979	MW									
b)	Coal supply Limitation	:	0	MW									
c)	Low water level in Kapta lake	:	168	MW									
d)	Plants under shut down/ maintenance	:	1510	MW									
10.	Total Energy (Generation + India Import)	:	215.32	MKWh									
	By Gas = 126.337 MKWH			By Oil = 52.537 MKWH									
	By Coal = 14.732 MKWH			By Hydro = 1.435 MKWH									
	By Solar = 0.600 MKWH												
11.	Total Gas Supplied	:	984.52	MMCFD									
(D) Forecast of 21.04.22 (Today) Thursday :													
01.	Maximum Demand	:	14000	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15431	MW (Generation end)	05.	Total Generation	:	223.69	MKWh				
03.	Reserve / Shortage	:	1431	MW (Generation end)	06.	Probable Max. Temperature in Dhaka	:	33.7° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helakar Rahman)
Deputy Secretary, Generation