

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2022				Day : Wednesday				Date : 27.04.22				
Probable Maximum Demand : 14800 MW				Probable Maximum Generation : 15536 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 77.32 ft				Today = 76.97 ft				
				Rule Curve = 82.80 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.04.22 (Yesterday)		27.04.22 (Today)		26.04.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation (MW)	Machines shut down (MW)			
										Day		Evening
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0	260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	231	231	240	240				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	270	270				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	96	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	20		Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	300	301	300	320	59	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	290	290	300	300			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	404	400	400			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	110	110	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	335		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	130	120	150	150	215	Gas Shortage	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	84	84	85	85			
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	46	25	55	55			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	16	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	52	52			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105			
22	Kodda 150MW PP	HFO (BPDG-RPCL)	9x17.06	149	149	115	146	149	149			
23	Karnaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	258	296	280	300			
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	130	149	149	149			
26	Kirangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	111	301	300	300			
27	Branghanga 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	98	100	100			
28	Aurnah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	100	100	100			
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	144	144	144			
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	28	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	6	55	55			
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirgonj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	84	98	100	100			
37	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	54	24	100	100			
38	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	78	78	80	80			
Dhaka Zone Total				6055	5898	3415	3806	4052	4062	929	590	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	56	58	60	60	172		Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0		180		Under maint.
41	Kapali 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	31	32	25	35			
45	Sikabaha 105 MW PP (Baraka Sikabaha	HFO (IPP)	6x18.415	105	105	105	105	105	105			
46	Shikabaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0		150		Under maint.
47	Sikabaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	152	151	150	150			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	300	300	300	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
51	Halchazi 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	50	51	51			
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	26	5	25			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	84	96	95	95			
54	Sikabaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	110	110	110			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	90	92	90	90			
58	Chattogram 116 MW PP (Anlima Enen	HFO (IPP)	6x21.06	116	116	91	108	113	113			
Chattogram Zone Total				2442	2282	1325	1467	1471	1476	352	330	
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	129			Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	134			Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	28	28	28				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	212	216	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	360			Gas Shortage
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x360	360	360	310	325	300	360			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	53	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	45	45	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	150	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	47	50	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	91	100	100	100			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	180	185	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	42	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.058	200	200	30	200	200	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	98	96	96			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	28	113	113	113			
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	35	36			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	101	101	101	101			
**	Import (Tijura)	India		160	160	154	132	143	166			
Cumilla Zone Total				3059	3014	1545	1969	2022	2106	810	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	117	119	110	110	83		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	105	115	115	115			
85	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	183	186	190	190			
86	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
87	Sutishail 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0			
88	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	24	24	24			
Myensingh Zone Total				717	622	489	461	508	456	83	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.04.22 (Yesterday)		27.04.22 (Today)		26.04.22 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
89	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0				
90	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42		49	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
92	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
94	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	50	60	60				
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	156	155	160	160	175		Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	86	81	81				
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	221	220	220				
98	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	17	17	17				
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	310	310				
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	403	400	400				
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	400	400	400				
104	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1749	1836	1874	1874	346	149
107	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	190	185	200	200	225		Gas Shortage	
109	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	37	37				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	0	80				
111	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	140	200	150	200				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	17	100	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	95	105	105	105				
114	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	67	105	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	100	0				
116	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	15	16	115	115				
117	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5*8.5	40	40	0	21	32	32				
**	Bheramara (HVDC)	India		1000	1000	921	914	791	791				
Khulna Zone Total						2388	2384	1540	1747	1735	1765	225	0
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	38	33	37				
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	67	90	90				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	940	1080	1060	1080				
122	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	150	150				
123	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	210	206	220	220				
Barishal Zone Total						1958	1958	1292	1440	1603	1687	0	0
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	36	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	12	149	200	200				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	30	30				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	92	93				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	30	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	30	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	141	139	150	150	71		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	211	213	200	220			Running on HSD	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	414	400	410				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	43	52	52				
139	Bagura 113 MW PP (Confidence) Unit- 1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	1058	1496	1528	1578	462	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	70	72	70	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	17				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	99	107	110	110				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
147	Maipara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	108	115	115	115				
Rangpur Zone Total						800	720	482	494	503	532	0	85
Sub-total: Plants in operation						22070	21484	12895.0	14716	15296	15536	3207	1154
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						12448	14206	14766	14998				
(B) Plants under long term maintenance/ contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						278	0	0	0	0			
Gross Total						22348	21484	12895	14716	15296	15536	3207	1154
(C) Actual data of 26.04.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14716	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14206	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	14716	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	11491	MW, at =	8:00 hrs	Dhaka	5055	5055	0	Mymensingh	1112	1112	0
05.	Day-peak Generation (Generation end)	:	12895	MW, at =	12:00 hrs	Chattogram	1449	1449	0	Sylhet	576	576	0
06.	Evening-peak Generation (Generation end)	:	14716	MW, at =	21:00 hrs	Khulna	1876	1876	0	Barishal	431	431	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Rajshahi	1673	1673	0	Rangpur	668	668	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10409	MW, at =	5:00 hrs	Cumilla	1366	1366	0				
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	3035	MW		13. Fuel cost :		(a) Gas = 138612835 Taka	(c) Coal = 149917076 Taka				
	d) Coal supply Limitation	:	0	MW				(b) Oil = 1042653862 Taka	Total = 1331183774 Taka				
	b) Low water level in Kaptai lake	:	172	MW									
	c) Plants under shut down/ maintenance	:	1154	MW									
10.	Total Energy (Generation + India Import)	:	322.18	MKWh									
	By Gas = 140.179 MKWh			By Oil = 121.154 MKWh									
	By Coal = 32.383 MKWh			By Hydro = 1.348 MKWh									
	By Solar= 1.447 MKWh												
11.	Total Gas Supplied	:	1052.56	MMCFD									
(D) Forecast of 27.04.22 (Today) Wednesday :													
01.	Maximum Demand	:	14800	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15536	MW (Generation end)		05.	Total Generation	:	324.02	MKWh			
03.	Reserve / Shortage	:	736	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	40.1° C				