

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month May, 2022				Day : Wednesday				Date : 04.05.22				
Probable Maximum Demand : 8200 MW				Probable Maximum Generation : 14787 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.48 ft				Today = 75.30 ft				
				Rule Curve = 81.43 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.05.22 (Yesterday)		04.05.22 (Today)		03.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for Gas/water/Coal limitation (MW)			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	100	0	0	0				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	270	230	280			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	22	70	100			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	172	342	340	350			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	450	250	450			
9	210 MW Siddhirgon TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	275	398	400	400			
11	Siddhirgon 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	110	Gas Shortage
12	Siddhirgon 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	335	300	335			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	220	270	305	305	65		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	84	84			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.57+1x8.73	80	80	25	32	52	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	16	20	20			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	14	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	100	100			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	150	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	280	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	149	149			
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Nababganj 55 MW PP (Southern power)	HSD (IPP)	3x19.3	55	55	0	0	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	104	104			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	144	144			
33	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	0	35	35			
35	Katpotti 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	96	96			
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	0	0	90	90			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	78	78			
Dhaka Zone Total				6055	5898	1529	2159	4125	4440	385	590	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	35	35	195	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	90	90	90	90	90	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	37	37			
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	105	105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	183	213	200	200			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	15	15	300	300			
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	50	90	90			
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	51	51			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	51	51			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			42	42	42	42			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	0	96	96			
54	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54			
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	100	100			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
58	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	0	0	113	113			
Chattogram Zone Total				2442	2282	427	509	1546	1521	285	330	
59	a) Ashuganj TPP Unit- 4	Gas (APSCl)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	0	25	31	31			
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	132	198	225	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	280	310	330	350			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	55	55	55			
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	0	26	8	26	169	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	15	51	51	36	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	118	136	138	138			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	5	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	21	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	17	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+6x1.01+31x1.198	200	200	0	0	200	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	80	80			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	0	113	113			
79	Bhairat 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	51	101			
**	Imporpt (Tripura)	India		160	160	91	74	143	166			
Cumilla Zone Total				3059	3014	687	930	1971	2082	828	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	109	212	150	200			
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	17	17			
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	0	115	115			
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	0	190	190			
86	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
87	Sutiaikhai 50 MW Solar PP	Solar (IPP)	1x50	50	50	1	0	50	0			
88	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	0	24	24			
Mymensingh Zone Total				717	622	110	229	548	546	0	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.05.22 (Yesterday)		04.05.22 (Today)		03.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for .		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	20	30	20	20				
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	40	42	42	42		48	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	11	53	53				
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	100	163	163	163				
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	10	30	60	60				
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	42	111	110	110	219		Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	20	81	81				
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	220	220	220				
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	17	17				
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	155	300	310	310				
102	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	241	341	350	400				
103	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	266	400	400	400				
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	25	25	50		Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	50	50	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1014	1668	1922	1972	339	148
107	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	0	0	0	410		Gas Shortage	
109	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	37	37				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
111	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	120	120				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105				
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	18	0	100	0				
116	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	16	16				
117	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	32	32				
**	Bheramara (HVDC)	India		1000	1000	686	922	697	939				
Khulna Zone Total						2388	2384	884	922	1312	1514	410	0
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	28	17	33	33				
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	78	88	75	88				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	470	650	500	900				
122	Polukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
123	Bhola 220MW CAPP (Nutan Bidyut B)	Gas/HSD (IPP)	2x75+1x70	220	220	114	107	220	220				
Barisal Zone Total						1958	1958	690	862	878	1501	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	36	43				
127	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
128	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
129	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	24	90	90				
130	Katakhat 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	40	40				
131	Katakhat 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
132	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	30	38				
133	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	120	0	0	0	210		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	130	0	0	0	220		Gas Shortage	
135	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
136	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	220	102	0	0	312		Gas Shortage	
137	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	22	22	22				
138	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
139	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	43	43				
140	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
141	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	70	113	113				
142	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total						2129	2129	470	317	777	786	1133	0
143	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
144	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
145	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	180	200	200				
146	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	70	110	110				
148	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
149	Wajpara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	3	0	0	8	0				
150	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	0	34	30	115				
Rangpur Zone Total						800	720	203	284	348	425	85	85
Sub-total: Plants in operation						22070	21484	6014.0	7880	13427	14787	3465	1153
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								5745	7528	12826	14126		
(B) Plants under long term maintenance/ contract expired													
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forecast Outage	
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
153	Bogra 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amnara 50 MW PP(Sirhal)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						278	0	0	0				
Gross Total						22348	21484	6014	7880	13427	14787	3465	1153
(C) Actual data of 03.05.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	7880	MW,	at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	7528	MW,	at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10281	MW,	at = 1:00 hrs	Dhaka	2265	2265	0	Mymensingh	700	700	0
04.	Minimum Generation (Generation end)	:	6014	MW,	at = 9:00 hrs	Chattoogram	779	779	0	Sylhet	306	306	0
05.	Day-peak Generation (Generation end)	:	6014	MW,	at = 9:00 hrs	Khulna	984	984	0	Barishal	228	228	0
06.	Evening-peak Generation (Generation end)	:	7880	MW,	at = 21:00 hrs	Rajshahi	878	878	0	Rangpur	602	602	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at = 21:00 hrs	Cumilla	786	786	0	Total	7528	7528	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5611	MW,	at = 5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 128413988 Taka	(c) Coal = 86376828 Taka				
a) Gas limitation	:	3185	MW				(b) Oil = 65905015 Taka	Total = 280695831 Taka					
d) Coal supply Limitation	:	85	MW			14.	Maximum Temperature in Dhaka was :	29.1° C					
b) Low water level in Kapali lake	:	195	MW			15.	Export through East-West interconnections :						
c) Plants under shut down/ maintenance	:	1153	MW				At evening peak-hour	-384	MW,	at 21:00 hrs			
10.	Total Energy (Generation + India Import)	:	172.78	MKWh			Maximum	-456	MW,	at 2:00 hrs			
	By Gas = 127.604 MKWh			By Oil = 8.517 MKWh			Energy	2.312	MKWh				
	By Coal = 18.604 MKWh			By Hydro = 0.633 MKWh									
	By Solar= 0.674 MKWh												
11.	Total Gas Supplied	:	853.92	MMCFD									
(D) Forecast of 04.05.22 (Today) Wednesday :													
01.	Maximum Demand	:	8200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14787	MW	(Generation end)	05.	Total Generation	:	137.81	MKWh			
03.	Reserve / Shortage	:	6587	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.6° C				

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation