

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022				Day : Wednesday				Date : 11.05.22					
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 15406 MW				Rule Curve = 80.29 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.52 ft				Today = 74.45 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.05.22 (Yesterday)		11.05.22 (Today)		10.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	102	101	102	102				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	272	332	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	373	388	400	400				
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0		110	Under maint.		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	270	300	335	335				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	130	115	250	250	220	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	48	93	93				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	45	50	52	52				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	51	35	51				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	100				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	32	132	132				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	105	290	290				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300				
27	Branganagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	35	55	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	126	144	144				
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55	55				
35	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
36	Siddhirgonj 100 MW PP/Dutch Bangla	HFO (NENP)	12x8.9	100	100	100	100	100	100				
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	73	93	90	96				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	30	48	94	94				
Dhaka Zone Total				6055	5898	2636	2976	4079	4071	445	1135		
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	90	100	100	100	80	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	25	25				
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	5	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	36	37	37	37				
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	105	68	105	105				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	202	205	205				
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	276	283	300	300				
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	75	90	90				
50	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
51	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	51	51	51				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	35	10	25				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	92	97	97	97				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	39	54	54	54				
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	77	88	106	106				
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	83	100	100				
57	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	40	40	50	50				
58	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	99	99	100	100				
Chattogram Zone Total				2442	2282	1191	1431	1558	1548	280	330		
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	28	31	28	28				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	160	192	210	225				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Shortage		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	270	330	330	90	Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	5	55	55	50	Gas Shortage		
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	80	150	150	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	33	50	50				
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	134	135	135	135				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	51	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	19	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	8	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	33	43	43	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	21				
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.288	200	200	0	0	200	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	70	80	80				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	68	114	113	113				
79	Bharos 54 MW PP	HFO (IPP)	3'18.2	54	54	17	17	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.428	115	115	0	17	100	100				
**	Import (Tripura)	India		160	160	106	112	143	166				
Cumilla Zone Total				3059	3014	1031	1354	2017	2056	950	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	120	107	160	210	95	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20				
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0				
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	55	109	115	115				
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	120	200	200				
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
87	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	12	0	50	0				
88	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22				
Mymensingh Zone Total				717	622	238	380	569	567	95	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.05.22 (Yesterday)		11.05.22 (Today)		10.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
89	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	6	30	30	30				
90	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	41	41		48	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	22	51	51				
92	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
94	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	60	55	55				
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	236	267	270	270	63		Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	0	81	81				
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	192	219	220	220				
98	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	19	20	20				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	24	24				
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0	341		Under maint.	
102	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	240	241	350	400				
103	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	400	400	400				
104	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	37	39	40	40	11		Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	48	50	50	50				
Sylhet Zone Total				2522	2477	1474	1589	1816	1866	74	489		
107	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	185	210	250	250	200		Gas Shortage	
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	37	37				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
111	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	200	200				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105				
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	50	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	102	0	100	0				
116	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	16	94	115	115				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	32	32				
**	Bheramara (HVDC)	India		1000	1000	909	898	903	903				
Khulna Zone Total				2388	2384	1212	1252	1947	1907	200	0		
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	34	33	33				
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	52	88	88				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	770	840	770	1000				
122	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
123	Bhola 220MW CCPP (Nutan Bidyt BC)	Gas/HSD (IPP)	2x75+1x70	220	220	104	121	220	220				
Barishal Zone Total				1958	1958	906	1079	1161	1601	0	0		
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	36	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	54	90	90				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	40	40				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	37	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	133	129	160	160	91		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	416	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total				2129	2129	731	1015	1360	1362	692	0		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	201	200	200				
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	70	103	113	113				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6'20	115	115	0	92	115	115				
Rangpur Zone Total				800	720	276	396	436	428	85	85		
Sub-total: Plants in operation				22070	21484	9695.0	11472	14943	15406	2821	2039		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9461	11196	14582	15035				
(B) Plants under long term maintenance/contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired				278	0	0	0	0	0				
Gross Total				22348	21484	9695	11472	14943	15406	2821	2039		
(C) Actual data of 10.05.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11472	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11196	MW, at = 21:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	
03.	Highest Generation (Generation end)	:	11472	MW, at = 21:00 hrs			MW	MW	MW		MW	MW	
04.	Minimum Generation (Generation end)	:	8622	MW, at = 7:00 hrs		Dhaka	3793	3793	0	Mymensingh	848	848	
05.	Day-peak Generation (Generation end)	:	9695	MW, at = 12:00 hrs		Chattoogram	1288	1288	0	Sylhet	430	430	
06.	Evening-peak Generation (Generation end)	:	11472	MW, at = 21:00 hrs		Khulna	1353	1353	0	Barishal	375	375	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 21:00 hrs		Rajshahi	1159	1159	0	Rangpur	824	824	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8706	MW, at = 5:00 hrs		Cumilla	1126	1126	0				
09.	Generation shortfall at evening peak due to :	:								Total	11196	11196	
	a) Gas limitation	:	2536	MW		13.	Fuel cost :	(a) Gas = 136610939 Taka	(c) Coal = 113204926 Taka				
	d) Coal supply Limitation	:	85	MW			(b) Oil = 426048451 Taka	Total = 675864317 Taka					
	b) Low water level in Kapali lake	:	200	MW									
	c) Plants under shut down/ maintenance	:	2039	MW		14.	Maximum Temperature in Dhaka was :	31.8° C					
10.	Total Energy (Generation + India Import)	:	243.64	MKWh		15.	Export through East-West interconnections :						
	By Gas = 132.584 MKWH			By Oil = 60.713 MKWh			At evening peak-hour	:	9695	MW, at 21:00 hrs			
	By Coal = 24.648 MKWH			By Hydro = 0.705 MKWh			Maximum	:	-220	MW, at 20:00 hrs			
	By Solar= 0.719 MKWH						Energy	:	0.205	MKWh			
11.	Total Gas Supplied	:	1020.23	MMCFD									
(D) Forecast of 11.05.22 (Today) Wednesday :													
01.	Maximum Demand	:	12500	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15406	MW (Generation end)	05.	Total Generation	:	265.47	MKWh				
03.	Reserve / Shortage	:	2906	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	33.5° C					

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation