

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022				Day : Thursday				Date : 12.05.22				
Probable Maximum Demand : 12900 MW				Probable Maximum Generation : 15995 MW				Rule Curve = 80.10 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.46 ft				Today = 74.37 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.05.22 (Yesterday)		12.05.22 (Today)		11.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW			
					Day	Evening	Day	Evening	Gen. shortfall for : Gas/water/Coal limitation MW	Probable start-up date		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	65	260	260	300	Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	90	102	102			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	338	330	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgoni TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	336	407	400	412			
11	Siddhirgoni 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	Under maint.	
12	Siddhirgoni 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	300	335	335	335			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	120	150	150	215	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	15	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	40	90	90			
16	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	41	43	52	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	50	51			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	105			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	100	132	132			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	145	290	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	88	149	149			
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Branganagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	17	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	93	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirgoni 100 MW PP/Dutch Bangla	HFO (NENP)	12x8.9	100	100	8	40	100	100			
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	59	93	90	100			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	62	100	100	100			
Dhaka Zone Total				6055	5898	2805	3093	4275	4313	440	1070	
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25			
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	2	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	24	40	37	40			
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	216	203	205	205			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300			
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	76	90	90			
50	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	51	51			
51	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	51	51			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			2	19	10	30			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	69	89	90	90			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	106	106	106	110			
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	39	100	100	100			
57	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	30	30	30	30			
58	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	99	109	100	115			
Chattogram Zone Total				2442	1228	1238	1425	1531	1548	280	330	
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	31	35	35			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	200	168	210	225			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	280	330	330	80	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	55	55	55	Gas Shortage	
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	113	150	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	135	135	135	135			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	52	85	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	10	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	10	21	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	25	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	21			
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+61x.915+15x1.98	200	200	0	0	200	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	80	52	80	80			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.79+2'3.1	113	113	65	107	113	113			
79	Bharat 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.428	115	115	0	8	100	100			
**	Import (Tripura)	India		160	160	110	108	143	166			
Cumilla Zone Total				3059	3014	1209	1294	2023	2063	945	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	107	108	120	150	94	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	97	115	115			
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	80	140	200	200			
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0			
87	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	32	0	50	0			
88	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total				717	622	381	389	529	507	94	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.05.22 (Yesterday)		12.05.22 (Today)		11.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	22	43	43	43			
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	42	42	42	42			
91	Fenchugonj 51 MW CAPP (Barikataullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51			
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	110	163	163			
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	40	60	60			
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	220	265	270	270	65	Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	78	80	80			
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	219	219	220	220			
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	15	19	20	20			
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	14	13	24	24			
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	10	260	300	341			
102	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	240	329	350	400			
103	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	180	180	400	400			
104	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	31	30	35	19	Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	48	50	50	50			
Sylhet Zone Total					2522	2477	1404	1753	2124	2220	84	148
107	Bheramara GTTP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
108	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	250	260	250	300	150	Gas Shortage	
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35			
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			
111	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	200	200			
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100			
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	14	35	105	105			
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	105	105			
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	51	0	100	0			
116	Khulna 115 MW PP (KPLCL-2)	HFO (NENP)	7x17	115	115	16	70	99	99			
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	32	32			
**	Bheramara (HVDC)	India		1000	1000	887	895	903	903			
Khulna Zone Total					2388	2384	1218	1275	1929	1939	150	0
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	50	110			
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	30	33	35			
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	58	38	60	60			
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	700	800	1000			
122	Potatkhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	150			
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	160	192	220	220			
Barishal Zone Total					1958	1958	936	993	1163	1575	0	0
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
125	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	36	40			
127	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
128	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30			
129	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	90	93			
130	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40			
131	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	50	50			
132	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	37	38			
133	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	158	164	160	200	56	Gas Shortage	
136	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	378	400	400			
137	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22			
138	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
139	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	52	52			
140	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	70	113	113	113			
141	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	90	113	113			
142	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
Rajshahi Zone Total					2129	2129	697	964	1360	1402	657	0
143	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
144	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
145	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200			
146	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	109	108	113	113			
148	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
149	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
150	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6'20	115	115	0	72	115	115			
Rangpur Zone Total					800	720	316	380	436	428	85	85
Sub-total: Plants in operation					22070	21484	10204.0	11566	15370	15995	2735	1633
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9952	11280	14990	15599				
(B) Plants under long term maintenance/contract expired												
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		Forced Outage	
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0		Contract expired	
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3-5x2.0	20	0	0	0	0	0		Contract Expired on 12/11/2020	
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0		Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					278	0	0	0	0			
Gross Total					22348	21484	10204	11566	15370	15995	2735	1633
(C) Actual data of 11.05.22 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	11566	MW, at = 19:30 hrs									
02.	Max. Demand at eve. peak (Sub-station end)	11280	MW, at = 19:30 hrs									
03.	Highest Generation (Generation end)	11566	MW, at = 19:30 hrs									
04.	Minimum Generation (Generation end)	8706	MW, at = 7:00 hrs									
05.	Day-peak Generation (Generation end)	10204	MW, at = 12:00 hrs									
06.	Evening-peak Generation (Generation end)	11566	MW, at = 19:30 hrs									
07.	Evening Peak Load-shed (Sub-station end)	0	MW, at = 19:30 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	8850	MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation	2450	MW									
c)	Coal supply Limitation	85	MW									
b)	Low water level in Kapali lake	200	MW									
c)	Plants under shut down/ maintenance	1633	MW									
10.	Total Energy (Generation + India Import)	246.00	MKWh									
	By Gas =	134.760	MKWh	By Oil =	60.915	MKWh						
	By Coal =	24.696	MKWh	By Hydro =	0.716	MKWh						
	By Solar=	0.912	MKWh									
11.	Total Gas Supplied	1072.37	MMCFD									
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
	Demand	Supply	Load Shed									
	MW	MW	MW									
	Dhaka	3918	3918	0	Mymensingh	942	942	0				
	Chattoagram	1326	1326	0	Sylhet	398	398	0				
	Khulna	1353	1353	0	Barishal	300	300	0				
	Rajshahi	1176	1176	0	Rangpur	847	847	0				
	Cumilla	1020	1020	0								
					Total	11280	11280	0				
13.	Fuel cost :	(a) Gas = 142718786 Taka	(c) Coal = 113409650 Taka									
		(b) Oil = 428649015 Taka	Total = 684777451 Taka									
14.	Maximum Temperature in Dhaka was :	31.9° C										
15.	Export through East-West interconnections :											
	At evening peak-hour	10204	MW, at 19:30 hrs									
	Maximum	220	MW, at 20:00 hrs									
	Energy	0.205	MKWh									
(D) Forecast of 12.05.22 (Today) Thursday :												
01.	Maximum Demand	12900	MW (Generation end)	04.	Maximum Load-shed	0	MW At evening peak (Sub-station end)					
02.	Maximum Generation	15995	MW (Generation end)	05.	Total Generation	274.37	MKWh					