

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022				Day : Sunday				Date : 22.05.22			
Probable Maximum Demand : 13500 MW				Probable Maximum Generation : 14978 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.78 ft				Today = 74.07 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.05.22 (Yesterday)		22.05.22 (Today)		Rule Curve = 78.00 ft		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		21.05.22 (Yesterday)		
					Day	Evening	Day	Evening	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	250	270	270		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	72	105	105		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	316	250	320	330	110	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110	Under maint.
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	260	335	335		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	140	135	150	150	200	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	10	40	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	32	90	90		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	53	53	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	25	25		
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	50	50	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	70	105	105		
22	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	0	82	132	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	75	290	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	149	149	149		
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300		
27	Branganiganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	55	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	90	90	90		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	23	162	144	144		
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0		
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	34	55	55		
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
36	Siddhirgoni 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	24	90	90		
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	74	90	90		
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	13	80	96	96		
Dhaka Zone Total				6055	5898	1854	2589	3845	3835	947	770
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0		
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25		
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	0	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	8	40	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	17	105	105	105		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	208	202	220	220		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	45	277	280	280		
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	50	38	50		
50	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	41	51	51		
51	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	51	51		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	10	10	25		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	8	82	80	83		
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	34	54	54	54		
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	70	73	110	110		
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	50	40	50		
57	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	10	10	10	10		
58	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	17	108	110	110		
Chattogram Zone Total				2442	2282	488	1162	1311	1326	380	330
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	24	0	30	30		
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	190	181	140	150		
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Shortage
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	270	300	330	90	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	30	10	10	25	Gas Shortage
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	0	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	137	0	0		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	41	41		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	100	99	100	100		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	120	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	16	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	42	43	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	5	20	20	20		
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.288	200	200	0	0	200	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	110	110		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	104	28	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.428	115	115	0	17	100	100		
**	Import (Tripura)	India		160	160	72	114	143	166		
Cumilla Zone Total				3059	3014	811	1367	1599	1747	925	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	127	155	150	150	47	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	20	20		
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	27	109	115	115		
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	150	170	180		
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
87	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0		
88	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	16	24	22	22		
Mymensingh Zone Total				717	622	202	455	529	487	47	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.05.22 (Yesterday)		22.05.22 (Today)		21.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)					
89	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43			48	GT-4 Under maint.			
90	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42							
91	Fenchugonj 51 MW PP (Barakattulah)	Gas (RPP)	19x2.90	51	51	50	50	51	51							
92	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110							
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11							
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	20	60	60							
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	110	110	330			Gas Shortage			
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	80	80							
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	219	220	220							
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0							
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10							
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	12	12	12							
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	300	341							
102	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	360	400	400							
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	396	322	400	400							
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work			
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	24	42	48	50							
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	5	5	44	44							
Sylhet Zone Total						2522	2477	1709	1586	1941	1984	330	148			
107	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
108	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	370	280	240	230	130			Gas Shortage			
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35							
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80							
111	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	150	220							
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100							
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	105	105							
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	50	105	105							
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	100	0							
116	Khulna 115 MW PP (KPLCL-2)	HFO (NENP)	7x17	115	115	25	49	115	115							
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	40	40							
**	Bheramara (HVDC)	India		1000	1000	382	910	935	935							
Khulna Zone Total						2388	2384	866	1402	1925	1965	130	0			
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	50	110							
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	9	28	30	31							
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	88	86	86							
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	920	1050	1050							
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150							
123	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	103	195	220	220							
Barishal Zone Total						1958	1958	559	1280	1453	1647	0	0			
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	35	40							
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200							
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30							
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	84	68	68							
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40							
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50							
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	36	38							
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210			Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	220	220			Gas Shortage			
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	120	92	175	180	128			Gas Shortage			
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	420	300	410	410							
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22							
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11							
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52							
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	25	113	113	113							
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	113	113	113							
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0							
Rajshahi Zone Total						2129	2129	588	821	1361	1587	729	0			
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Under Overhauling			
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99			Coal Shortage			
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	10	109	110	110							
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0							
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	0	52	115	115							
Rangpur Zone Total						800	720	189	336	408	400	184	85			
Sub-total: Plants in operation						22070	21484	7266.0	10998	14372	14978	3672	1333			
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								7197	10894	14235	14836					
(B) Plants under long term maintenance/contract expired																
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage			
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired			
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020			
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/contract expired						278	0	0	0	0	0					
Gross Total						22348	21484	7266	10998	14372	14978	3672	1333			
(C) Actual data of 21.05.22 (Yesterday) Saturday :																
01.	Max. Demand at eve. peak (Generation end)					10998	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)					10894	MW, at = 19:30 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)					11367	MW, at = 1:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)					4396	MW, at = 8:00 hrs		Dhaka	4453	4453	0	Mymensingh	753	753	0
05.	Day-peak Generation (Generation end)					7266	MW, at = 12:00 hrs		Chattoogram	1231	1231	0	Sylhet	389	389	0
06.	Evening-peak Generation (Generation end)					10998	MW, at = 19:30 hrs		Khulna	1057	1057	0	Barishal	327	327	0
07.	Evening Peak Load-shed (Sub-station end)					0	MW, at = 19:30 hrs		Rajshahi	996	996	0	Rangpur	676	676	0
08.	Minimum Generation Forecast up to 8.00 hrs					8751	MW, at = 5:00 hrs		Cumilla	1012	1012	0				
09.	Generation shortfall at evening peak due to :															
	a) Gas limitation					3288	MW									
	d) Coal supply Limitation					184	MW									
	b) Low water level in Kaptai lake					200	MW									
	c) Plants under shut down/ maintenance					1333	MW									
10.	Total Energy (Generation + India Import)					212.10	MKWh									
	By Gas =	125.670	MKWh	By Oil =	45.315	MKWh										
	By Coal =	22.182	MKWh	By Hydro =	0.702	MKWh										
	By Solar=	0.869	MKWh													
11.	Total Gas Supplied					994.51	MMCFD									
(D) Forecast of 22.05.22 (Today) Sunday :																
01.	Maximum Demand					13500	MW (Generation end)	04.	Maximum Load-shed			0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation					14978	MW (Generation end)	05.	Total Generation			251.90	MKWh			
03.	Reserve/ Shortage					1478	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :			34.8° C				