

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022					Day : Tuesday				Date : 24.05.22					
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 14668 MW					Rule Curve = 77.60 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 74.58 ft.					Today = 74.66 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.05.22 (Yesterday)		24.05.22 (Today)		23.05.22 (Yesterday)		24.05.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	270	270	270					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	105	105	105					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	204	320	340	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	23	356	0	0					
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	110		Under maint.		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	329	0	0	0	335		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	142	135	150	150	200		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	45	52	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	33	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	50	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	132	115	132	132					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	255	276	290	290					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	62	266	300	300					
27	Branganagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	99	100	100					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	98	100	100					
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	19	55	55	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	90	90					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	134	144	144					
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0					
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55					
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
36	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	82	90	90	90					
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	83	81	80	80					
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	87	96	96	96					
Dhaka Zone Total					6055	5898	3313	3739	3523	3483	760	770		
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	70	35	40	160		Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	24	25	25	25					
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	10	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	43	50	50					
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	98	105	105	105					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	203	203	220	220					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	247	264	273	273					
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50					
50	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
51	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	51	0	51					
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	23	10	25					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	75	85	86	86					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	35	35					
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	97	92	92	110					
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	50					
57	Julidah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	0	10	10	10	10					
58	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	108	108	110	110					
Chattogram Zone Total					2442	2282	1040	1262	1199	1313	340	330		
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	30	33	30	30					
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	148	191	194	194					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	270	340	340	90		Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50		Gas Shortage		
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	128	140	140					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	41	40	40					
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	100	100	100	100					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	103	200	200	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.288	200	200	0	200	100	200					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	110	114					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	29	114	28	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	17	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.428	115	115	75	82	83	83					
**	Import (Tripura)	India		160	160	113	130	143	166					
Cumilla Zone Total					3059	3014	1062	1786	1683	1913	950	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	130	130	140	140	72		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20					
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0					
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	98	115	115					
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	108	190	170	200					
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
87	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0					
88	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22					
Mymensingh Zone Total					717	622	423	462	519	497	72	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.05.22 (Yesterday)		24.05.22 (Today)		23.05.22 (Yesterday)		24.05.22 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Gas/water/Coal limitation MW	Machines shut down (MW)		
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26		GT-1 Under maint.		
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49		GT-4 Under maint.		
91	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	0	0	0	0						
92	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53			Gas Shortage		
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11			Gas Shortage		
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	50	55	55						
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	110	90	110	110	240			Gas Shortage		
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	50	80	80						
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220						
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	20	20	20						
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	295	300	341						
102	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	402	400	400						
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	399	400	400	400						
104	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100			Under project work		
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50			Gas Shortage		
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50			Gas Shortage		
Sylhet Zone Total						2522	2477	1712	1732	1790	1831	404	175		
107	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
108	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	235	245	320	320	165			Gas Shortage		
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	35	35						
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	58	0	60						
111	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220						
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	100	100						
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105						
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	32	105	105	105						
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	101	0	100	0						
116	Khulna 115 MW PP (KPLCL-2)	HFO (NENP)	7x17	115	115	83	115	115	115						
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	40	40	40						
**	Bheramara (HVDC)	India		1000	1000	911	904	913	913						
Khulna Zone Total						2388	2384	1467	1705	1833	2013	165	0		
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	48	50	110						
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	32	20	33						
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	86	86	86						
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	790	1020	1050	1050						
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150						
123	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	216	220	220	220						
Barishal Zone Total						1958	1958	1156	1423	1443	1649	0	0		
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	43	34	43						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	176	0	176						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	29	30	30						
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	83	85	85						
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	2	32	40	40						
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	43	43	43						
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	38	38						
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210			Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	220	220			Gas Shortage		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	179	176	180	180						
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	420	410	410						
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22						
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11						
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	34	52	52						
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113						
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113						
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0						
Rajshahi Zone Total						2129	2129	943	1328	1177	1576	601	0		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99			Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	101	101	103	103						
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	67	97	115	115						
Rangpur Zone Total						800	720	350	373	401	393	184	85		
Sub-total: Plants in operation						22070	21484	11466.0	13810	13568	14668	3476	1360		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						11089	13356	13122	14186						
(B) Plants under long term maintenance/contract expired															
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage		
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired		
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020		
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/contract expired						278	0	0	0	0	0				
Gross Total						22348	21484	11466	13810	13568	14668	3476	1360		
(C) Actual data of 23.05.22 (Yesterday) Monday :															
01.	Max. Demand at eve. peak (Generation end)	:	13810	MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	13356	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	13810	MW, at = 21:00 hrs		MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end)	:	9232	MW, at = 8:00 hrs	Dhaka	4907	4907	0	Mymensingh	1039	1039	0			
05.	Day-peak Generation (Generation end)	:	11466	MW, at = 12:00 hrs	Chattoogram	1286	1286	0	Sylhet	500	500	0			
06.	Evening-peak Generation (Generation end)	:	13810	MW, at = 21:00 hrs	Khulna	1677	1677	0	Barishal	406	406	0			
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 21:00 hrs	Rajshahi	1344	1344	0	Rangpur	856	856	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10276	MW, at = 5:00 hrs	Cumilla	1341	1341	0							
09.	Generation shortfall at evening peak due to :	:							Total	13356	13356	0			
	a) Gas limitation	:	3132	MW	13.	Fuel cost :	(a) Gas = 149494739 Taka	(c) Coal = 232310603 Taka							
	d) Coal supply Limitation	:	184	MW		(b) Oil = 1285471662 Taka	Total = 1667277004 Taka								
	b) Low water level in Kapali lake	:	160	MW											
	c) Plants under shut down/ maintenance	:	1360	MW	14.	Maximum Temperature in Dhaka was :	35.2° C								
10.	Total Energy (Generation + India Import)	:	285.64	MKWh	15.	Export through East-West interconnections :									
	By Gas = 136.846 MKWh			By Oil = 94.098 MKWh		At evening peak-hour	:	11466	MW, at 21:00 hrs						
	By Coal = 27.552 MKWh			By Hydro = 0.996 MKWh		Maximum	:	302	MW, at 22:00 hrs						
	By Solar= 1.351 MKWh					Energy	:	0	MKWh						
11.	Total Gas Supplied	:	999.49	MMCFD											
(D) Forecast of 24.05.22 (Today) Tuesday :															
01.	Maximum Demand	:	14200	MW (Generation end)	04.	Maximum Load-shed	:	0	MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	14668	MW (Generation end)	05.	Total Generation	:	293.70	MKWh						
03.	Reserve / Shortage	:	468	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	36.4° C							