

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022				Day : Thursday				Date : 26.05.22			
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 14906 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.71 ft				Today = 74.72 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.05.22 (Yesterday)		26.05.22 (Today)		Rule Curve = 77.20 ft		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : 25.05.22 (Yesterday)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	270	280	280		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	99	96	105	105		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	328	348	340	340			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	115	Under maint.	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	110	Under maint.	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	332	337	330	330		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	150	150	150	185	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	94	93	93		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	49	47	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	50	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105		
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	132	132	132	132		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	266	278	290	290		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	114	149	149		
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	81	40	300	300		
27	Branganagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	95	100	100	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	97	98	100	100		
29	Nababganj 55 MW PP (Southern power	HFO (IPP)	3x19.3	55	55	55	55	55	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	104	90	104		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	144	162		
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0		
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55		
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
36	Siddhirgonj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	78	91	90	90		
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	56	81	80	80		
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	96	96	96	96		
Dhaka Zone Total				6055	5898	3482	3552	3863	3865	410	885
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	75	40	75	155	Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	7	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	85	105	105	105		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	225	Awaiting for HGPI	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	260	278	273	283		
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50		
50	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51		
51	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	59	0	60		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	24	10	25		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	60	77	86	86		
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	35	35		
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	87	92	110		
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	65	25	50		
57	Julidah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	0	10	10	10	10		
58	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	90	108	110	110		
Chattogram Zone Total				2442	2282	917	1222	1084	1247	235	555
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	129	Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	20	30	30		
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	158	210	190	210	11	Gas Shortage
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	360	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	290	340	340	70	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	50	Gas Shortage	
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	100	140	140		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	32	40	40		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	98	100	100	100		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	6	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	32	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	20		
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.288	200	200	50	20	150	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	110	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	116	28	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	17	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.428	115	115	45	83	83	83		
**	Import (Tripura)	India		160	160	114	126	143	165		
Cumilla Zone Total				3059	3014	1222	1576	1729	1928	941	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	109	140	140	140	62	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	20	20		
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	108	108	115	115		
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	179	181	170	200		
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
87	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0		
88	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	3	24	22	22		
Mymensingh Zone Total				717	622	466	470	519	497	62	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.05.22 (Yesterday)		26.05.22 (Today)		25.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44	44		26	GT-1 Under maint.
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.
91	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	0	0	0	0			
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	60	60	60			
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	157	157	160	160	173		Gas Shortage
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	50	0	50			
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	206	220	220			
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	22	24			
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	300	341			
102	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	402	400	400			
103	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	398	398	400	400			
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5*2	50	50	0	0	0	0	50		Gas Shortage
Sylhet Zone Total					2522	2477	1721	1774	1767	1860	357	175
107	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
108	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	280	275	320	320	135		Gas Shortage
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	35	35			
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	32	0	60			
111	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220			
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	100	100			
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	93	94	105	105			
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	67	89	105	105			
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	32	0	100	0			
116	Khulna 115 MW PP (KPLCL-2)	HFO (NENP)	7x17	115	115	47	84	115	115			
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	40	40	40	40			
**	Bheramara (HVDC)	India		1000	1000	920	922	942	942			
Khulna Zone Total					2388	2384	1479	1573	1862	2042	135	0
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	50	110			
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	26	20	33			
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	57	56	86	86			
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	840	900	1050	1050			
122	Potashahi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150			
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	217	218	220	220			
Barishal Zone Total					1958	1958	1166	1265	1443	1649	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43			
126	Baghabari 200 MW PP (Paramount)	IPP	135x1.6	200	200	10	47	0	175			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	2	29	30	30			
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	82	85	85			
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	40	40			
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	34	43	43			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	38	38			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	166	200	180	200			
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	414	410	410			
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	24	43	52	52			
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	75	113	113	113			
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	113	113			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
Rajshahi Zone Total					2129	2129	798	1220	1177	1375	601	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	225	225	99		Coal Shortage
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	81	101	103	103			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	1.11	96	115	115			
Rangpur Zone Total					800	720	373	372	451	443	184	85
Sub-total: Plants in operation					22070	21484	11624.0	13024	13895	14906	2925	1700
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							11244	12598	13440	14418		
(B) Plants under long term maintenance/contract expired												
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/contract expired					278	0	0	0	0			
Gross Total					22348	21484	11624	13024	13895	14906	2925	1700
(C) Actual data of 25.05.22 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	: 13024	MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 12598	MW, at = 19:30 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	: 13024	MW, at = 19:30 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	: 9931	MW, at = 8:00 hrs		Dhaka	4798	4798	0	Mymensingh	1052	1052	0
05.	Day-peak Generation (Generation end)	: 11624	MW, at = 12:00 hrs		Chattoagram	1445	1445	0	Sylhet	507	507	0
06.	Evening-peak Generation (Generation end)	: 13024	MW, at = 19:30 hrs		Khulna	1488	1488	0	Barishal	339	339	0
07.	Evening Peak Load-shed (Sub-station end)	: 0	MW, at = 19:30 hrs		Rajshahi	1110	1110	0	Rangpur	761	761	0
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9258	MW, at = 5:00 hrs		Cumilla	1099	1099	0				
09.	Generation shortfall at evening peak due to :								Total	12598	12598	0
	a) Gas limitation	: 2586	MW		13.	Fuel cost :	(a) Gas = 148671951 Taka	(c) Coal = 223402491 Taka				
	d) Coal supply Limitation	: 184	MW				(b) Oil = 1279793405 Taka	Total = 1651867847 Taka				
	b) Low water level in Kapali lake	: 155	MW									
	c) Plants under shut down/ maintenance	: 1700	MW		14.	Maximum Temperature in Dhaka was :	32.8° C					
10.	Total Energy (Generation + India Import)	: 282.08	MKWh	15.	Export through East-West interconnections :							
	By Gas = 133.423 MKWH	By Oil = 95.076 MKWH			At evening peak-hour	: 11624	MW, at 19:30 hrs					
	By Coal = 26.562 MKWH	By Hydro = 1.120 MKWH			Maximum	: 100	MW, at 1:00 hrs					
	By Solar = 1.176 MKWH				Energy	: 0.001	MKWh					
11.	Total Gas Supplied	: 1006.15	MMCFD									
(D) Forecast of 26.05.22 (Today) Thursday :												
01.	Maximum Demand	: 14000	MW (Generation end)	04.	Maximum Load-shed	: 0	MW At evening peak (Sub-station end)					
02.	Maximum Generation	: 14906	MW (Generation end)	05.	Total Generation	: 303.22	MKWh					
03.	Reserve / Shortage	: 906	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	36.4° C						

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation