

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month May, 2022				Day : Sunday				Date : 29.05.22			
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 14964 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.59 ft				Today = 74.58 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.05.22 (Yesterday)		29.05.22 (Today)		28.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		
					Day	Evening	Day	Evening	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	280	280		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	102	106	105	108		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	300	330	340	350		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	95	0	100	0	105	105
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	325	333	330	330		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	150	150	150	185	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	76	93	93	93		
16	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	53	52	53	53		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	50	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	80	90	105	105		
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	142	132	142		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	225	275	300	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	149	149	149		
26	Karangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	29	300	300		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	75	100	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	75	100	100		
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	53	55	55	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	92	92		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	126	162	162		
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0		
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55	55		
35	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
36	Siddhirgonj 100 MW PP/Dutch Bangla	HFO (NENP)	12x8.9	100	100	48	91	90	91		
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	20	88	88	85		
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	96	96	96		
Dhaka Zone Total				6055	5898	2965	3478	4004	3895	927	765
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	38	68	40	40	162	Low water level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0		
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	2	25	25	25		
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	9	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	6x6.89	50	50	0	29	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	87	105	105	105		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	267	285	280	300		
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50		
50	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	0	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	42	0	60		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	16	10	15		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	75	67	75	85		
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	35	36		
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	90	110	110	110		
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	64	30	70		
57	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	10	10	10	10		
58	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	105	108	110	110		
Chattogram Zone Total				2442	2282	911	1222	1052	1273	242	555
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	32	36	32	36		
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	201	213	215	215		
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	25	250	360	335	Gas Shortage
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	55	53	55	55		
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	200	184	100	110		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	30	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	50	10	130	137		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	101	100	100		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	190	200	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	5	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+61x.915+15x1.288	200	200	0	20	150	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	114	9	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.428	115	115	45	90	90	101		
**	Import (Tripura)	India		160	160	84	116	143	165		
				3059	3014	1029	1426	1703	2136	958	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	138	130	150	150	72	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0		
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	103	103	115	115		
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	110	185	170	200		
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
87	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	50	0	0		
88	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	24	23	22	22		
Mymensingh Zone Total				717	622	447	461	529	507	72	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.05.22 (Yesterday)		29.05.22 (Today)		28.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42		49	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	5	5	5	5				
92	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		53	Gas Shortage	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0		11	Gas Shortage	
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	56	60	60				
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	156	110	110	110		220	Gas Shortage	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	50	50	50		36	Gas Shortage	
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	24	16	16				
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	270	300	341				
102	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	401	400	400				
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	381	395	400	400				
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0		50	Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0		50	Gas Shortage	
Sylhet Zone Total				2522	2477	1739	1735	1766	1807	440	176		
107	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	275	252	285	270		158	Gas Shortage	
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	35	40				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	41	0	60				
111	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	53	105	105				
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	67	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	86	0	100	0				
116	Khulna 115 MW PP (KPLCL-2)	HFO (NENP)	7x17	115	115	91	85	115	115				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	24	40	40				
**	Bheramara (HVDC)	India		1000	1000	914	922	930	930				
Khulna Zone Total				2388	2384	1494	1482	1815	1985	158	0		
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	29	32	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	6	31	20	20				
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	88	88	88				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	840	700	1050	1050				
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150				
123	Bhola 220MW CCPP (Nutan Bidyt BC)	Gas/HSD (IPP)	2x75+1x70	220	220	50	210	220	220				
Barishal Zone Total				1958	1958	1025	1078	1445	1638	0	0		
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	18	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	165				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	27	30	30				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	65	65	80				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	30	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	194	186	180	180				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	419	410	410				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	15	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	52	52				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	76	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	80	113	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2129	2129	766	1071	1132	1320	601	0		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175		99	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	82	105	113	113				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	66	115	115	115				
Rangpur Zone Total				800	720	326	395	411	403	184	85		
Sub-total: Plants in operation				22070	21484	10702.0	12348	13857	14964	3582	1581		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10411	12012	13480	14557				
(B) Plants under long term maintenance/contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired				278	0	0	0	0	0				
Gross Total				22348	21484	10702	12348	13857	14964	3582	1581		
(C) Actual data of 28.05.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	12348	MW, at = 19:30 hrs									
02.	Max. Demand at eve. peak (Sub-station end)	:	12012	MW, at = 19:30 hrs									
03.	Highest Generation (Generation end)	:	12348	MW, at = 19:30 hrs									
04.	Minimum Generation (Generation end)	:	9098	MW, at = 6:00 hrs									
05.	Day-peak Generation (Generation end)	:	10702	MW, at = 12:00 hrs									
06.	Evening-peak Generation (Generation end)	:	12348	MW, at = 19:30 hrs									
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 19:30 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9409	MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	3236	MW									
	d) Coal supply Limitation	:	184	MW									
	b) Low water level in Kapali lake	:	162	MW									
	c) Plants under shut down/ maintenance	:	1581	MW									
10.	Total Energy (Generation + India Import)	:	262.64	MKWh									
	By Gas =	:	133.699	MKWh									
	By Coal =	:	25.308	MKWh									
	By Solar=	:	1.152	MKWh									
11.	Total Gas Supplied	:	1023.60	MMCFD									
12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
	Zone		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
			MW	MW	MW		MW	MW	MW				
	Dhaka		4822	4822	0	Mymensingh	922	922	0				
	Chattoogram		1424	1424	0	Sylhet	540	540	0				
	Khulna		1187	1187	0	Barishal	257	257	0				
	Rajshahi		825	825	0	Rangpur	813	813	0				
	Cumilla		1222	1222	0								
						Total	12012	12012	0				
13.	Fuel cost :		(a) Gas = 151271874 Taka	(c) Coal = 212108589 Taka									
			(b) Oil = 1001300231 Taka	Total = 1364680694 Taka									
14.	Maximum Temperature in Dhaka was :		34.0° C										
15.	Export through East-West interconnections :												
	At evening peak-hour		10702	MW, at 19:30 hrs									
	Maximum		56	MW, at 1:00 hrs									
	Energy		0.02	MKWh									