

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2022					Day : Tuesday				Date : 31.05.22					
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 15367 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 74.70 ft.				Today = 74.53 ft.				Rule Curve = 76.20 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.05.22 (Yesterday)		31.05.22 (Today)		30.05.22 (Yesterday)		30.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+ 1x 126	365	365	280	280	280	280					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	105	105	108					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	330	340	350					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225				Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	403	360	405					
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	327	315	330	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	140	150	150	150	185			Gas Shortage	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	40	55	55					
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	94	94	93	93					
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x167+7x17.73	80	80	50	53	53	53					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	23	33	33					
20	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	50	50					
21	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105					
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	62	150	150	150					
23	Karnaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	280	300	300					
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	28	174	300	300					
27	Branganiganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	70	100	100					
28	Aurnati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	99	100	100					
29	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	55	55	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	45	55	55	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	92	104					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162					
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0					
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55					
35	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
36	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	73	100	90	100					
37	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	71	90	88	85					
38	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	64	96	96	96					
Dhaka Zone Total					6055	5898	3165	4087	4282	4329	515	765		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	68	68	70	70	162			Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0						
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	32	50	50					
45	Sikalbaha 105 MW PP (Baraka Sikabaha	HFO (IPP)	6x18.415	105	105	105	105	105	105					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225			Awaiting for HGPI	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	266	300	300	300					
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	90	90	90					
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	0	102					
51	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	21	56	0	60					
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			5	11	10	25					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	63	81	75	85					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	35	36					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	100	100	100					
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	10	10	10	10					
58	Chattogram 116 MW PP (Avloma Ener)	HFO (IPP)	6x21.06	116	116	90	108	110	110					
Chattogram Zone Total					2442	2282	993	1356	1237	1400	242	555		
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129			Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	37	32	36					
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	152	158	215	215					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	345	355	300	360					
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360			Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	45	30	55	55	25			Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	63	8	16	16	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	133	130	137					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	50	40	50	50					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	150	150	152	152					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	20	20	20					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.058	200	200	0	0	150	200					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	0	0	0					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	114	9	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	25	16	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	57	99	90	101					
**	Import (Tijura)	India		160	160	108	122	143	165					
Cumilla Zone Total					3059	3014	1485	1596	1722	1980	835	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	115	121	150	150	81			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0					
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	95	108	115	115					
85	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	175	200	170	200					
86	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
87	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0					
88	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	23	23	22	22					
Myensingh Zone Total					717	622	482	472	529	507	81	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.05.22 (Yesterday)		31.05.22 (Today)		30.05.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
89	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	43	43		26	GT-1 Under maint.	
90	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42		49	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakutullah)	Gas (RPP)	19x2.90	51	51	25	25	5	5				
92	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
94	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	60	60				
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81				
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	220				
98	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	18	20	20				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	24	16	16				
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	300	341				
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	402	400	400				
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	395	400	400				
104	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	11	6	11	39		Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	20	50	5	50				
Sylhet Zone Total						2522	2477	1687	1792	1820	92	505	
107	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	275	245	285	285	165		Gas Shortage	
109	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	35	40				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	65				
111	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	100	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	105	105	105				
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	105	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0				
116	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	85	81	115	115				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	40	40				
**	Bheramara (HVDC)	India		1000	1000	921	922	933	933				
Khulna Zone Total						2388	2384	1428	1585	1818	2008	165	0
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	50	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	32	20	20				
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	87	88	88				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	770	960	1050	1050				
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150				
123	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	183	222	220	220				
Barishal Zone Total						1958	1958	1095	1350	1445	1638	0	0
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	165				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	11	30	30				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	65	80				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	8	32	32	32				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	186	195	200				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	356	414	410	410				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	76	113	113	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	94	90	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	708	1085	1180	1282	601	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	79	100	113	113				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Maipara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	108	115	115	115				
Rangpur Zone Total						800	720	367	390	411	403	184	85
Sub-total: Plants in operation						22970	21484	11410.0	13713	14353	15367	2715	1910
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						10908	13110	13721	14691				
(B) Plants under long term maintenance/ contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						278	0	0	0	0			
Gross Total						22348	21484	11410	13713	14353	15367	2715	1910
(C) Actual data of 30.05.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	13713	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13110	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13713	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	9847	MW, at =	7:00 hrs	Dhaka	4779	4779	0	Mymensingh	1067	1067	0
05.	Day-peak Generation (Generation end)	:	11410	MW, at =	12:00 hrs	Chattogram	1233	1233	0	Sylhet	519	519	0
06.	Evening-peak Generation (Generation end)	:	13713	MW, at =	21:00 hrs	Khulna	1624	1624	0	Barishal	372	372	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Rajshahi	1392	1392	0	Rangpur	908	908	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10101	MW, at =	5:00 hrs	Cumilla	1215	1215	0				
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	2369	MW		13. Fuel cost :		(a) Gas =	156760137	Taka	(c) Coal =	210887431	Taka
	d) Coal supply Limitation	:	184	MW				(b) Oil =	1243773632	Taka	Total =	1611421200	Taka
	b) Low water level in Kaptai lake	:	162	MW									
	c) Plants under shut down/ maintenance	:	1910	MW									
10.	Total Energy (Generation + India Import)	:	283.66	MKWh									
	By Gas =	137.523	MKWh	By Oil =	93.333								
	By Coal =	25.180	MKWh	By Hydro =	1.652								
	By Solar=	1.114	MKWh										
11.	Total Gas Supplied	:	1063.70	MMCFD									
(D) Forecast of 31.05.22 (Today) Tuesday :													
01.	Maximum Demand	:	14000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15367	MW	(Generation end)	05.	Total Generation	:	289.59	MKWh			
03.	Reserve / Shortage	:	1367	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.8°	C			