

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 2-Jun-22		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	180	4221000	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	280	6733391	Condenser problem
	Ghorasal 78.5 MW PP (MAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	98	2269681	
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	398	4012030	
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	330	7900000	Machine problem
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	225	5102350	GT-2 S/D, Gas shortage
9	Meghnaghat 100 MW(IEI)	ORPP	12*8.9	100	80	1919040	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	145	3447156	Gas shortage & FGMO
11	Madanganj 102 PP(Summit)	ORPP	6*17	102	77	1718064	Engine problem
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	1250588	
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	442260	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2120 MW GTTP	EGCB	2*105	210	0	1104000	GT-2 U/M & Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla	ORPP	12*8.9	100	100	1867018	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	170	6432057	Gas shortage
19	Gaagajar 102 MW PP (Digital Po	IPP	12*8.924	102	94	1664496	
20	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1305720	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2420160	
23	Nababganj 55 MW PP (Northern)	IPP	3*19.3	55	35	894353	Engine problem
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1140447	
25	Bosila 108MW RP(CLC)	IPP	12*8.75+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	52	1164300	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	493400	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	734600	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	50	1060800	#REF!
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	296	6144761	
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	70	850752	Low Demand
33	Bramhangon 100 MW PP (Aggr	IPP	114*0.959	100	100	814087	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	99	741987	
35	Kodda 149 MW PP Unit-1 (Summ	IPP	8*18.45+8.97	149	133	3155904	Engine problem
36	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2316000	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	88	2087040	Engine problem
38	Manikgonj 162MW (MPGL)	IPP	9*18	162	144	3288960	Engine problem
39	Spectra Solar Plant Ltd.	IPP	35	35	0	0	
40	Kanchan Purbachal Power Gener	IPP	18.4*3	55	55	1281240	
Dhaka area Total				5898	3776	79977912	
41	Chattogram TPP-1	PDB	1*210	180	100	2400000	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Razzan 25 MW PP	RPCL	3*8.9	25	17	260728	Engine problem
44	Teknaf 20MW PP (SolarTech)Teknaf	SolarTech Energ	20	20	0	18495	
45	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	38	961920	Engine problem
46	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	68	1626560	Low water level
47	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Si	IPP	6*17.5	105	105	2523309	
50	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	51	543406	Engine problem
51	Dokhazari-Kalashah 100 MW Peakir	PDB	6*17	102	51	396593	
52	Juddah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	10	257520	Fuel shortage
53	Juddah 100 MW PP Unit-3 (Acom)	IPP	8*13.5	100	90	2029440	Engine problem
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	537936	
	Malancha, Ctg. EP2 (United)	IPP	5*8.73+3*9.34	0	32	557280	
55	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	74	1525460	Engine problem
56	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	13441	
57	Anwara 300 MW PP (United)	IPP	17*17+24	300	289	5233964	
58	Jodiac Power	IPP	3*18.55+1*3.6	54	36	904845	Engine problem
59	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2509916	
60	Juddah unit-2 (Acom)	IPP	8*13.6	100	100	2342400	
	Anilma Energy Ltd.	IPP	6*21.2	116	108	2583109	
Chattogram area Total				2382	1301	27230284	
61	Ashuganj TPP Unit-3	APSCL	1*150	129	0	0	Contract Expired
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Contract Expired
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	179	4808000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	285	6106000	Gas shortage
65	Ashuganj 50 MW PP	APSCL	14*3.968	45	33	738646	Engine problem
66	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	55	1259040	
67	Ashuganj 195MW PP (APSCL-UR	IPP	20*9.73+1*16	195	8	367999	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1222540	
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	144	2997527	Engine problem
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	48	716136	
71	Chandpur 150 MW CCPP	IPP	1*108+1*57	163	150	3686720	
72	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	200	4505760	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	0	Engine problem
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	0	135900	Engine problem
**	Imoport (Tripura)	Imported power	0	160	128	2707200	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	726800	
76	Jangalia 52 MW PP (Kandanaev)	IPP	8*9.92	52	25	274814	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	485340	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	60	389568	Low Demand
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	10	

