

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2022					Day : Sunday				Date : 05.06.22					
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 15361 MW					Rule Curve = 77.04 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 73.50 ft.					Today = 73.08 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.06.22 (Yesterday)		05.06.22 (Today)		04.06.22 (Yesterday)		05.06.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW					
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180		Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	280						
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	102	102		102				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0		105		Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	20	0	0	0	0				Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	326	331	330		330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225		225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	364	398	400		412				
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0		105	105			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	170	0	0		0				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	142	140	150		150	195	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	40	55		55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	94	93		93				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22		22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	45	45	53		53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25		25				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33		33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	37	50	50		50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	53	95	105		105				
22	Kodda 150MW PP	HFO (BPD- RPCL)	9x17.06	149	149	0	150	150		150				
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	38	54	54		54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	90	298	300		300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	111	149	149		149				
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	104	300		300				
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	100		100				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	100		100				
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55		55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55		55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104		104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	117	162	162		162				
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30		0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	34	55	55		55				
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0		0				
36	Siddhirgonj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	24	91	100		100				
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	66	85	88		88				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	81	92	96		96				
Dhaka Zone Total					6055	5898	2772	3564	4001	3983	525	765		
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	62	60	70		70	170	Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100		100	80	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0		0	180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5		0				
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25		25				
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	19	0	20		0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	44	44		44				
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	87	105	105		105				
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0		0	150	Under maint.		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0		0	225	Awaiting for HGPI		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	60	277	300		300				
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90		90				
50	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0		51				
51	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	17		50				
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22		22				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	22	25		25				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	56	80		85				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54		54				
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110		110				
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100		100				
57	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	10	10	10		10				
58	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	108	108	110		110				
Chattogram Zone Total					2442	2282	869	1234	1287	1351	250	555		
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0		0		Contract Expired		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0		0	134	Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	38	32		36				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	190	186	215		215				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	275	310	340		340				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0		0	360	Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	54	56	55		55				
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	16		16	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	44	44	51		51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	90	150	130		140				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	50		50				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	150	150	150		150				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200		200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	22		22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	10	11		11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33		33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8		25				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	20		20				
76	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.288	200	200	0	0	150		200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	17	17		114				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	105	9		105				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	35		35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	99	82	90		101				
**	Import (Tripura)	India		160	160	130	126	143		165				
Cumilla Zone Total					3059	3014	1270	1610	1777	2084	681	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	111	110	150		160	92	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	20		20				
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0		0				
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	24	97	115		115				
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	86	183	170		185				
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6		0				
87	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	3	0	50		0				
88	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	18	24	22		22				
Mymensingh Zone Total					717	622	260	431	529	502	92	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.06.22 (Yesterday)		05.06.22 (Today)		04.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.	
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	41	41		48	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	22	31	55	53				
92	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	35	35	110	110		128	ST under maint.	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	60	60				
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	84	84	84				
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	192	213	220	220				
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	19	20	20				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	310	341				
102	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	398	401	400	400				
103	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	40	32	40	40	18		Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	20	30	30	44	20		Gas Shortage	
Sylhet Zone Total						2522	2477	1683	1815	38	676		
107	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	280	270	380	380	140		Gas Shortage	
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	35	40				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	70				
111	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	30	0	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	93	105	105				
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	89	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0				
116	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	30	78	100	115				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	24	40	40	40				
**	Bheramara (HVDC)	India		1000	1000	896	905	922	922				
Khulna Zone Total						2388	2384	1363	1787	140	0		
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	48	110				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	31	20	27				
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	85	88	88				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	980	1050	1050				
122	Potatkhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150				
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	190	217	220	220				
Barisal Zone Total						1958	1958	988	1362	1443	1645	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	43				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	200				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	23	30	35				
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	90	65	90				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	50	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	30	40				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	176	202	190	210				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	423	0	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	76	113	95	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	100	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total						2129	2129	773	1154	773	1367	601	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	41	71	71	44		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	76	107	80	113				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	0	0	8	0				
148	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)	6*20	115	115	34	72	115	115				
Rangpur Zone Total						800	720	285	395	449	474	143	85
Sub-total: Plants in operation						22070	21484	10222.0	13036	13861	15361	2470	2081
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9911	12639	13861	14894				
(B) Plants under long term maintenance/contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired						278	0	0	0				
Gross Total						22348	21484	10222	13036	13861	15361	2470	2081
(C) Actual data of 04.06.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13036	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12639	MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	13036	MW, at = 21:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	9265	MW, at = 8:00 hrs	Dhaka	4554	4554	0	Mymensingh	941	941	0	
05.	Day-peak Generation (Generation end)	:	10222	MW, at = 12:00 hrs	Chattoogram	1309	1309	0	Sylhet	431	431	0	
06.	Evening-peak Generation (Generation end)	:	13036	MW, at = 21:00 hrs	Khulna	1737	1737	0	Barishal	405	405	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 21:00 hrs	Rajshahi	1368	1368	0	Rangpur	784	784	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10057	MW, at = 5:00 hrs	Cumilla	1110	1110	0					
09.	Generation shortfall at evening peak due to :	:							Total	12639	12639	0	
	a) Gas limitation	:	2157	MW	13.	Fuel cost :	(a) Gas = 158019953 Taka	(c) Coal = 204034422 Taka					
	d) Coal supply Limitation	:	143	MW			(b) Oil = 1017817985 Taka	Total = 1379872360 Taka					
	b) Low water level in Kapali lake	:	170	MW									
	c) Plants under shut down/ maintenance	:	2081	MW	14.	Maximum Temperature in Dhaka was :	32.8° C						
10.	Total Energy (Generation + India Import)	:	267.64	MKWh	15.	Export through East-West interconnections :							
	By Gas = 138.711 MKWh			By Oil = 77.900 MKWh		At evening peak-hour	:	10222	MW, at 21:00 hrs				
	By Coal = 24.443 MKWh			By Hydro = 1.471 MKWh		Maximum	:	-146	MW, at 1:00 hrs				
	By Solar= 0.798 MKWh					Energy	:	0.28	MKWh				
11.	Total Gas Supplied	:	1018.66	MMCFD									
(D) Forecast of 05.06.22 (Today) Sunday :													
01.	Maximum Demand	:	14000	MW (Generation end)	04.	Maximum Load-shed	:	0	MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	15361	MW (Generation end)	05.	Total Generation	:	287.44	MKWh				
03.	Reserve / Shortage	:	1361	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	36.8° C					

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation