

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2022		Day: Tuesday				Date: 07.06.22							
Probable Maximum Demand :		13900 MW				Probable Maximum Generation : 14057 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 72.70 ft		Today = 72.06 ft		Rule Curve = 77.56 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.06.22 (Yesterday)		07.06.22 (Today)		06.06.22 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation (MW)	06.06.22 (Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening					
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	260	260	260				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	96	98	102	102				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	300	298	300	270				
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	361	291	340	330				
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105		
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	145	150	150	190		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Gangagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	85	85	93	93				
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	51	51	53	53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.75	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.75	33	33	27	27	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	48	50	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105				
22	Kooda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	120	150	150	150				
23	Karnaghat 54 MW PP (Bariso Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
24	Kooda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	245	285	285				
25	Kooda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
26	Kiranggonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	202	301	300	300				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	98	100	100				
28	Auranah 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	91	96	100	100				
29	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	35	55	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	91	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162				
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	34	55	55	55				
35	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
36	Siddhirgonj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	87	89	92	92				
37	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	54	88	88	88				
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	92	93	93	93				
Dhaka Zone Total				6055	5898	3503	3651	3845	3775	855	765		
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	40	40	195		Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
41	Kapali 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
43	Toknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	43	43	44	44				
45	Sikalbaha 105 MW PP (Baraka Sikabha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0				
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		150	Under maint.
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	266	250	300	300				
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	90	90				
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51				
51	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			4	27	5	25				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	72	72	80	80				
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	70	80	80	80				
58	Chattogram 116 MW PP (Anlima Enen)	HFO (IPP)	6x21.06	116	116	92	108	110	110				
Chattogram Zone Total				2442	2282	1196	1272	1290	1336	275	555		
59	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0			Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	30	36	32	36				
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1175	221	221	194	203	185	185				
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	298	355	260	340				
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	50	53	55	55				
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	8	26	8	8	169		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	44	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	132	130	148				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	3	38	50	50				
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	90	89	90	90				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	200	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	18	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x4+4x61+315+15x1058	200	200	100	200	150	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	0	0				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	103	9	105				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	19	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	65	78	90	101				
**	Impoort (Tajpura)	India		160	160	146	164	143	165				
Cumilla Zone Total				3059	3014	1374	1841	1575	1863	663	0		
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	79	125	70	100	77		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.524	95	8	0	0	0	0				
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	107</						

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.06.22 (Yesterday)		07.06.22 (Today)		06.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT-1 Under maint.		
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	41	41		50	GT-4 Under maint.		
91	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	5	17	15	15					
92	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		53	ST under maint.		
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
94	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	60					
95	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	84	84					
97	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	178	179	180	180					
98	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	19	20	20					
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	24	24					
101	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	310	341					
102	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	400	400	400					
103	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	389	400	400	400					
104	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	7	6	7	7	44		Gas Shortage		
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	20	20	20	30		Gas Shortage		
Sylhet Zone Total						2522	2477	1691	1711	1735	1766	74	560	
107	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
108	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	395	325	150	150	85		Gas Shortage		
109	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	35	40					
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	74	0	70					
111	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	96	0	100					
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	45	93	105	105					
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	32	105	105	105					
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	56	0	100	0					
116	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	47	95	115	115					
117	Noapara 40 MW PP (Khanghan Ali)	HFO (NENP)	5*8.5	40	40	0	40	40	40					
**	Bheramara (HVDC)	India		1000	1000	922	924	940	940					
Khulna Zone Total						2388	2384	1497	1790	1590	1665	85	0	
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	48	110					
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	33	20	33					
120	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x88	194	194	81	84	88	88					
121	Peyra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	750	1010	1050	1050					
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17					
123	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	215	203	220	220					
Barishal Zone Total						1958	1958	1100	1395	1443	1518	0	0	
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	43					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	190	100	190					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	30	35					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	65	90					
129	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32					
130	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	50	50					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40					
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	187	130	130	125	80		Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	200	120	0					
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	255	424	340	340					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22					
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52					
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	60	113	113	113					
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	51	94	94	94					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
Rajshahi Zone Total						2129	2129	784	1423	1229	1237	471	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	87	89	0	0					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	109	75	113					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	8	0	80					
147	Maipara, Tatala 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	72	72	72	72					
Rangpur Zone Total						800	720	338	453	330	440	99	85	
Sub-total: Plants in operation						22070	21484	11848.0	14004	13516	14057	2599	1965	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						11363	13431	12963	13482					
(B) Plants under long term maintenance/ contract expired														
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						278	0	0	0	0	0	0	0	
Gross Total						22348	21484	11848	14004	13516	14057	2599	1965	
(C) Actual data of 06.06.22 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	:	14004	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13431	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	14004	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	10636	MW, at =	8:00 hrs	Dhaka	5077	5077	0	Mymensingh	837	837	0	
05.	Day-peak Generation (Generation end)	:	11848	MW, at =	12:00 hrs	Chattogram	1415	1415	0	Sylhet	529	529	0	
06.	Evening-peak Generation (Generation end)	:	14004	MW, at =	21:00 hrs	Khulna	1745	1745	0	Barishal	420	420	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Rajshahi	1291	1291	0	Rangpur	761	761	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10664	MW, at =	5:00 hrs	Cumilla	1357	1357	0					
09.	Generation shortfall at evening peak due to :	:								Total	13431	13431	0	
	a) Gas limitation	:	2305	MW		13.	Fuel cost :		(a) Gas =	152131890	Taka	(c) Coal =	241085108	Taka
	d) Coal supply Limitation	:	99	MW					(b) Oil =	1482226342	Taka	Total =	1875443341	Taka
	b) Low water level in Kaptai lake	:	195	MW										
	c) Plants under shut down/ maintenance	:	1965	MW		14.	Maximum Temperature in Dhaka was :		35.1° C					
10.	Total Energy (Generation - India Import)	:	297.18	MKWh		15.	Export through East-West interconnections :							
	By Gas =	133.729	MKWh	By Oil =	106.634	MKWh	At evening peak-hour		: 11848		MW, at	21:00 hrs		
	By Coal =	29.276	MKWh	By Hydro =	0.810	MKWh	Maximum		: 66		MW, at	2:00 hrs		
	By Solar =	0.939	MKWh				Energy		: 0.022		MKWh			
11.	Total Gas Supplied	:	1041.55	MMCFD										
(D) Forecast of 07.06.22 (Today) Tuesday :														
01.	Maximum Demand	:	13900	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	14057	MW	(Generation end)	05.	Total Generation : 294.97 MKWh							
03.	Reserve / Shortage	:	1											