

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2022					Day : Wednesday				Date : 08.06.22			
Probable Maximum Demand : 13934 MW					Probable Maximum Generation : 14381 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 72.06 ft				Today = 0.00 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.06.22 (Yesterday)		08.06.22 (Today)		Rule Curve = 77.56 ft		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : 07.06.22 (Yesterday)			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	280	280	280			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	92	102	102			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	297	272	340	340			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	315	291	400	400	121	Gas Shortage	
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	142	150	150	150	185	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	82	85	93	93			
16	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	49	45	53	53			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	10	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	50	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	105	105			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	128	150	150	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	240	245	285	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	149	133	149			
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	303	300	300	300			
27	Branganiganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	96	98	100	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	93	93	100	100			
29	Nababganj 55 MW PP (Southern power	HFO (IPP)	3x19.3	55	55	35	35	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	88	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	22	55	55	55			
35	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
36	Siddhirgoni 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	85	88	92	92			
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	72	87	90	90			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	97	95	97			
Dhaka Zone Total					6055	5898	3487	3639	3953	3941	971	765
39	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	40	40	195	Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0			
42	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
43	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	18	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	43	44	44			
45	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	87	87	105	105			
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI	
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	263	270	300	300			
49	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
50	Dohazani -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51			
51	Hathazani 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	20	5	25			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	70	72	80	80			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
56	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
57	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	80	80	80	80			
58	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	90	108	110	110			
Chattogram Zone Total					2442	2282	1174	1267	1290	1336	275	555
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	31	37	37	37			
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	187	205	180	180			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	300	300	330			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	56	55	55			
65	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	44	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	83	140	140	140			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	50	50			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	90	0	0			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	16	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	21	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	8	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.288	200	200	192	200	150	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	104	9	105			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.428	115	115	90	90	100	100			
**	Import (Tripura)	India		160	160	122	118	143	165			
Cumilla Zone Total					3059	3014	1387	1748	1552	1750	681	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	80	127	70	100	75	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	91	106	115	115			
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	170	188	190	200			
86	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
87	Sutikahai 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0			
88	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	18	24	22	22			
Mymensingh Zone Total					717	622	397	465	469	457	75	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.06.22 (Yesterday)		08.06.22 (Today)		07.06.22 (Yesterday)		08.06.22 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
89	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	43	43			26		GT-1 Under maint.	
90	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	40	41	41			50		GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	17	11	51	51						
92	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110			53		ST under maint.	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
94	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	60	60						
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330		Under maint.	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	84	84						
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	166	166	0	0						
98	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	19	20	20						
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24						
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	310	310	341						
102	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400						
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	391	400	400	400						
104	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100		Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	40	40			44		Gas Shortage	
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	20	10	44	50			40		Gas Shortage	
Sylhet Zone Total						2522	2477	1716	1705	1648	1685	84	559		
107	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
108	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	130	178	170	170			232		Gas Shortage	
109	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	35	40						
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	0	70						
111	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0						
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	9	97	0	100						
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	93	94	105	105						
114	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	88	105	105	105						
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	38	0	100	0						
116	Khulna 115 MW PP (KPLCL-2)	HFO (NENP)	7x17	115	115	61	94	115	115						
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	40	40	40						
**	Bheramara (HVDC)	India		1000	1000	923	920	940	940						
Khulna Zone Total						2388	2384	1342	1633	1610	1685	232	0		
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	48	110						
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	33	20	33						
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	81	81	88	88						
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	870	1090	1050	1050						
122	Potashahi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17						
123	Bhola 220MW CCPP (Nutan Bidyt BC)	Gas/HSD (IPP)	2x75+1x70	220	220	201	213	220	220						
Barishal Zone Total						1958	1958	1223	1466	1443	1518	0	0		
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	16	34	43						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	23	190	100	190						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	14	30	35						
128	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	91	65	90						
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	32	32	32						
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	34	34	43						
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40						
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	119	176	160	170						
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	220			220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	116	0	0	0			220		Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	401	414	414						
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	22	22	22						
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52						
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'x18.55	113	113	113	113	113	113						
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	94	94						
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0						
Rajshahi Zone Total						2129	2129	869	1284	1197	1569	611	0		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0				85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175			99		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	74	101	75	113						
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	80						
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0						
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6'x20	115	115	52	72	72	72						
Rangpur Zone Total						800	720	305	348	330	440	184	85		
Sub-total: Plants in operation						22070	21484	11900.0	13555	13492	14381	3113	1964		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								11508	13109	13047	13908				
(B) Plants under long term maintenance/contract expired															
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0					Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0					Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired						278	0	0	0	0	0				
Gross Total						22348	21484	11900	13555	13492	14381	3113	1964		
(C) Actual data of 07.06.22 (Yesterday) Tuesday :															
01.	Max. Demand at eve. peak (Generation end)	:	13555	MW,	at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13109	MW,	at = 21:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	13587	MW,	at = 22:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	:	10664	MW,	at = 7:00 hrs		Dhaka	4837	4837	0	Mymensingh	1014	1014	0	
05.	Day-peak Generation (Generation end)	:	11900	MW,	at = 12:00 hrs		Chattoogram	1380	1380	0	Sylhet	509	509	0	
06.	Evening-peak Generation (Generation end)	:	13555	MW,	at = 21:00 hrs		Khulna	1677	1677	0	Barishal	413	413	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at = 21:00 hrs		Rajshahi	1341	1341	0	Rangpur	806	806	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10756	MW,	at = 5:00 hrs		Cumilla	1132	1132	0					
09.	Generation shortfall at evening peak due to :	:									Total	13109	13109	0	
	a) Gas limitation	:	2734	MW		13.	Fuel cost :	(a) Gas = 149382408 Taka	(c) Coal = 243069962 Taka						
	d) Coal supply Limitation	:	184	MW			(b) Oil = 1502696390 Taka	Total = 1895148759 Taka							
	b) Low water level in Kapali lake	:	195	MW											
	c) Plants under shut down/ maintenance	:	1964	MW											
10.	Total Energy (Generation + India Import)	:	294.70	MKWh		14.	Maximum Temperature in Dhaka was : 34.7° C								
	By Gas = 131.080 MKWH			By Oil = 107.810 MKWh		15.	Export through East-West interconnections :								
	By Coal = 28.821 MKWH			By Hydro = 0.860 MKWh			At evening peak-hour			11900	MW,	at	21:00 hrs		
	By Solar= 0.858 MKWH						Maximum			50	MW,	at	24:00		
							Energy			0.006	MKWh				
11.	Total Gas Supplied	:	999.89	MMCFD											
(D) Forecast of 08.06.22 (Today) Wednesday :															
01.	Maximum Demand	:	13934	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	:	14381	MW	(Generation end)	05.	Total Generation : 302.23 MKWh								
03.	Reserve / Shortage	:	447	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 36.4° C								