

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2022										Day : Saturday		Date : 11.06.22			
Probable Maximum Demand : 13600 MW										Probable Maximum Generation : 14763 MW					
Water Level of Kaptai Lake at 06:00 AM										Rule Curve = 78.60 ft.					
Sl. No.	Name of Power Station	No. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 71.56 ft.		11.06.22 (Today)		10.06.22 (Yesterday)		10.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)				
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date				
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0			260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	0	0	0	0			180		Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	180	180	180							
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	280	280	280	280							
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	90	98	98	98							
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	0	0	0	0			105		Under maint.		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	0	0	0	0					Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	322	332	340	340							
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	225	225	225	225	225				Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0			115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	398	398	412	412							
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	0	0	0	0			105	105			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	175	220	180	180			115		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	145	125	150	150			210		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	30	55	55							
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	85	94	93							
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22							
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	38	51	52							
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	25	25	33							
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	16	25	25							
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	49	50							
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	105							
22	Kodda 150MW PP	HFO (BPDG-RPCL)	9x17.06	149	149	32	115	150							
23	Karnaghat 54 MW PP (Barso Energy)	HFO (IPP)	3x18.69	54	54	54	54	54							
24	Kodda 300 MW PP Unit-2 (Sumit)	HFO (IPP)	18x17.076	300	300	124	245	285							
25	Kodda 140 MW PP Unit-1 (Sumit)	HFO (IPP)	8x18.415+1x8.97	149	149	92	135	130							
26	Kiraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300							
27	Branghagan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100							
28	Aurhat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100							
29	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	55	55							
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55							
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	92	92	104							
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	48	162	162							
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30							
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55							
35	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0							
36	Siddhirgonj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	30	90	91							
37	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	81	86	90							
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0							
Dhaka Zone Total				6055	5898	2730	3428	4061	4036	655	765				
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	32	32	35			198		Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100			80		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0							
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0			180		Under maint.		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	11	25	25							
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20							
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	43	44							
45	Sikabaha 105 MW PP (Baraka Sikabaha	HFO (IPP)	6x18.415	105	105	105	105	105							
46	Sikabaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0							
47	Sikabaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0			150		Under maint.		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	100	282	285			225		Awaiting for HGPI		
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90							
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0			51				
51	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0							
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22							
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			19	42	10			25				
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	66	71							
54	Sikabaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54							
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	110	110							
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100							
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	0	78	80	80							
58	Chattogram 116 MW PP (Anlima Enen	HFO (IPP)	6x21.06	116	116	90	90	110							
Chattogram Zone Total				2442	2282	946	1292	1266	1307	278	555				
59	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0					Contract Expired		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0			134		Gas Shortage		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	31	30	33							
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	183	182	210							
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	265	305	300							
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0			360		Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	52	55							
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	26	73			169		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51							
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	60	140	140							
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	40	50							
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0			163				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	139	200	150							
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	22							
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11							
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	20	25	33							
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	8							
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20							
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.058	200	200	0	0	150							
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	51	98	51							
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	94	50							
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35							
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	81	99	100							
**	Import (Tripura)	India		160	160	92	112	143			165				
Cumilla Zone Total				3059	3014	1099	1536	1685	1928	663	163				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	112	150	155			52		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20							
83	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0							
84	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	35	97	105							
85	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	166	200	160							
86	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6							
87	Sutishail 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50							
88	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	24	22							
Mymensingh Zone Total				717	622	406	491	514	502	52	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.06.22 (Yesterday)		11.06.22 (Today)		10.06.22 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)			Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
89	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	43		26	GT-1 Under maint.	
90	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
91	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
92	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		53	ST under maint.	
93	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
94	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	60	62	62				
95	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
96	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	84	84				
97	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
98	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	18	18	18				
99	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
100	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24				
101	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	25	310	341				
102	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	368	401	400	400				
103	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	261	260	400	400				
104	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
105	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	41	42	41	42				
106	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	48	49	44	44				
Sylhet Zone Total						2522	2477	1151	1232	1649	1681	0	558
107	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
108	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	245	275	250	275	135		Gas Shortage	
109	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	35	45				
110	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	71	0	80				
111	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	5	135	150	150				
112	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	100				
113	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	48	105	90	105				
114	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	105	105	105				
115	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0				
116	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	89	95	95	95				
117	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	40	40				
**	Bheramara (HVDC)	India		1000	1000	923	923	940	940				
Khulna Zone Total						2388	2384	1431	1787	1805	1935	135	0
118	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	48	48				
119	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	30	20	33				
120	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	76	88	81	81				
121	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	940	1050	1050				
122	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
123	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	206	217	220	220				
Barishal Zone Total						1958	1958	904	1324	1436	1449	0	0
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	100	190				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	10				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	65	90				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	170	195	200	215				
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	120	141	210	210	79		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	330	414	414	414				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
139	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	76	113				
140	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	94	94	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	732	1235	1336	1517	470	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	74	92	75	100				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
147	Maipara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
148	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	34	108	72	108				
Rangpur Zone Total						800	720	285	375	330	408	184	85
Sub-total: Plants in operation						22070	21484	9684.0	12700	14082	14763	2437	2126
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9371	12290	13627	14286				
(B) Plants under long term maintenance/ contract expired													
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired						278	0	0	0	0	0		
Gross Total						22348	21484	9684	12700	14082	14763	2437	2126
(C) Actual data of 10.06.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	12700	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12290	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12766	MW, at =	22:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	8452	MW, at =	8:00 hrs	Dhaka	4170	4170	0	Mymensingh	1010	1010	0
05.	Day-peak Generation (Generation end)	:	9684	MW, at =	12:00 hrs	Chattogram	1364	1364	0	Sylhet	464	464	0
06.	Evening-peak Generation (Generation end)	:	12700	MW, at =	21:00 hrs	Khulna	1591	1591	0	Barishal	355	355	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Rajshahi	1365	1365	0	Rangpur	759	759	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9800	MW, at =	5:00 hrs	Cumilla	1212	1212	0				
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :							
	a) Gas limitation	:	2055	MW		(a) Gas = 149157929				(c) Coal = 198610370			
	d) Coal supply Limitation	:	184	MW		(b) Oil = 960234859				Taka Total = 1308003159			
	b) Low water level in Kaptai lake	:	198	MW		14. Maximum Temperature in Dhaka was :							
	c) Plants under shut down/ maintenance	:	2126	MW		33.0° C							
10.	Total Energy (Generation + India Import)	:	250.43	MKWh		15. Export through East-West interconnections :							
	By Gas =	127.858	MKWh	By Oil =	72.559	At evening peak-hour :							
	By Coal =	23.808	MKWh	By Hydro =	0.765	Maximum :							
	By Solar=	0.967	MKWh			Energy :							
11.	Total Gas Supplied	:	1122.27	MMCFD		At evening peak-hour :							
(D) Forecast of 11.06.22 (Today) Saturday :													
01.	Maximum Demand	:	13600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14763	MW	(Generation end)	05.	Total Generation	:	266.79	MW			
03.	Reserve/ Shortage	:	1163	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	37.9°	C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation