## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date : 16-Jun-22 Till now the maximum generation is : 16-Apr-22 The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 8:00 10104 M Available Max Generation : 14696 M 15-Jun-22 In-22 Generation & Demand Hour 12:00 10104 MW 13264.0 MW 13264.0 MW 21:00 21:00 14696 MW E.P. Demand (at gen end) Hour Max Demand (Evening) 14000 MW Maximum Generation 13306.0 MW Hour 23:00 Reserve(Generation end) 696 MW Total Gen. (MKWH) 287.8 System Load Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum vel of Kaptai Lake at 6:00 A M on Energy Energy 314 MW 24:00 MKWHR Actual : 74.02 Ft.(MSL) Rule curve 79.95 Ft.( MSL ) 1014.90 MMCFD Oil Consumed (PDB): Gas Consumed : Total = HSD Liter FO Liter Cost of the Consumed Fuel (PDB-Tk143.025.321 Gas Coal Tk239,553,196 : Tk1,587,530,838 Total : Tk1,970,109,355 Load Shedding & Other Information Today Estimated Shedding (S/S end) Estimated Demand (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) 0% Chittagong Area 0 0:00 1310 0% Khulna Area ٥ 0.00 1718 ٥ 0% Rajshahi Area Cumilla Area 0:00 1539 1364 0% 0% 0% 0% 0% Mymensingh Are Sylhet Area 0 0:00 1003 0 0:00 556 364 Barisal Area Rangpur Area Total 0:00 768 0% 13488 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Barapukuria ST: Unit-2 9) Shaiibazar 330 MW 2) Ghorasal-3.4 3) Ashuganj-5 4) Baghabari-71.100 MW 5) Raozan unit- 2 6) Siddhirganj 210 MW 7) Sikalbaha 225 MW 8) Sirajganj Unit-3 Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) Bibiyana(South) ST was synchronized at 09:53. b) Khulna© 132/33 kV T-3 transformer was under shut down from 08:06 to 10:35 for C/M. c) Bhola Nutun Biddut GT-1 was synchronized at 08:24. (d) Bhola 225 MW CCPP GT-2 was shut down at 10:11 due to gas shortage. e) Aminbazar-Meghnaghat 230 kV Ckt-1 was under shut down from 09:14 to 16:58 for C/M. f) Saver 132/33 kV T-2 transformer was under shut down from 09:04 to 10:26 for C/M. | 1) Saver 132/53 KV 1-2 Izelasion was under shut down into 1924 to 10,26 to 10.26 to 10.86. | 2) Ghorasal GIS-Ghoresal-3 P/P 132 kV Ckt was switched on at 11:08. | 3) Gopalganj P/P 132/33 kV T-2 transformer was under shut down from 10:52 to 12:24 for C/M. | 3) Siddhirganj 335 MW GT was synchronized at 12:24. | 3) Sunamganj-Chattak 132 kV Ckt-1 tripped at 12:15 showing VT fuse fail relay at Sunamganj end and was switched on at 12:21. | 4) Aminbazar 230 kV Bus-1 was under shut down from 13:01 to 15:35 for C/M. I) Ashuganj(N) GT was synchronized at 13:55. m) Sylhet 225 MW CCPP GT synchronized at 15:09. n) Siddhirganj 335 MW ST was synchronized at 16:01. o) Biblyana-3 GT was synchronized at 17:17. p) Chandpur CCPP GT was synchronized at 17:54. q) Hathazari-AKSM 230 kV Ckt was under shut down from 15:00 to 17:08 due to B-phase PT at Hathazari end got out order r) Tongi-Ultrara 132 kV Ckt was under shut down from 17:45 to 21:09 due to CVT problem at Tongi end. s) Sonargaon-Daudkandi 132 kV Ckt-1 tripped at 15:44 from both end showing Dist. Z1, R-phase relay and was switched on at 15:53. t) Chandour 132/33 kV T-2 transformer was switched on at 15:48. u) Feni-Chauddagram 132 kV Ckt-1 tripped at 18:32 from Feni end showing Dist. Z1, A-phase relay and was switched on at 18:45. v) Mithapukur-Rangpur Confidence P/P 132 kV Ckt-1was switched on at 18:14. w) Kishoreganj 132/33 kV T-1 & T2 transformers along with 33 kV Bus section were under shut down from 00:07(16-06-2022) to 01:36(16-06-2022) due to red hot at 33 kV Bus sectionalized. About 90 MW power interruption occurred under Kishoreganj S/S area from 00:07 to 01:36. x) Gopalganj-Rampal 400 kV Ckt was shut down at 05:45(16-06-2022) for D/W. y) Payra Bus coupler was switched on at 05:24(16-06-2022) for D/W. z) Kabirpur 132/33 kV T-3 transformer was under shut down from 06:23(16/06/2022) to 07:59(16/06/2022) due to red hot at 33 kV incoming. aa) Rajshahi(O) 132/33 kV T-3 transformer was shut down at 07:04(16/06/2022) due to red hot at 33 kV About 40 MW power interruption occurred under Rajshahi S/S area from 07:04(16/06/2022) to till. ab) Payra unit-2 was shut down at 07:26(16-06-2022) due to Gopalgarij-Rampal 400 kV Ckt was shut down. ac) Ullon-Dhanmondi 132 kV underground cable-3 tripped at 03:50(16-06-2022) showing Dist. C-phase, general trip at Ullon end. Sub Divisional Engineer **Executive Engineer** Superintendent Engineer

**Network Operation Division** 

Load Despatch Circle

**Network Operation Division**