

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date : 15-Jun-22             |                                  | Page -2         |                     |                  |                      |                  |                           |
|------------------------------|----------------------------------|-----------------|---------------------|------------------|----------------------|------------------|---------------------------|
| No.                          | Name of the Power Stations       | Producer        | Installed Capacity  | Present Capacity | Peak Hour Generation | Energy Generated | Remarks                   |
|                              |                                  |                 | Unit No. X Capacity | MW               | MW                   | KWH              |                           |
| 1                            | Ghorasal Repowered CCPP-Unit-3   | PDB             | 1*260               | 260              | 0                    | 0                | Under maint.              |
| 2                            | Ghorasal Repowered CCPP Unit-2   | PDB             | 1*210               | 180              | 0                    | 0                | Under maint.              |
| 3                            | Ghorasal TPP Unit-5              | PDB             | 1*210               | 190              | 180                  | 4378500          |                           |
| 3                            | Ghorasal 365 MW CCPP Unit-7      | PDB             | 1*243+1*122         | 365              | 280                  | 6473536          | Condenser problem         |
| 4                            | Ghorasal 78.5 MW PP(MAX)         | QRPP            | 2*40                | 0                | 0                    | 0                | Contract Expired          |
| 4                            | Ghorashtal 108MW PP (Regent)     | IPP             | 34*3.35             | 108              | 97                   | 2219500          | Engine problem            |
| 5                            | Haripur GTTP                     | SBU, PDB        | 2*32                | 20               | 0                    | 0                | Under maint.              |
| 6                            | Haripur 412 MW CCPP              | EGCB            | 1*273+1*139         | 412              | 409                  | 9744380          |                           |
| 7                            | Haripur 360MW CCPP(HPL)          | IPP             | 1*235+1*125         | 360              | 337                  | 7554000          |                           |
| 8                            | Meghnaghat 450 MW CCPP(MPL)      | IPP             | 2*150+1*150         | 450              | 225                  | 5146500          | GT-1 S/D, Gas shortage    |
| 9                            | Meghnaghat 100 MW(EL)            | QRPP            | 12*8.9              | 100              | 85                   | 1828800          | Engine problem            |
| 10                           | Meghnaghat CCPP(Summit)          | IPP             | 2*110+1*110         | 335              | 0                    | 0                | Under maint.              |
| 11                           | Madanganj 102 PP(Summit)         | QRPP            | 6*17                | 102              | 0                    | 0                | Under maint.              |
| 12                           | Madanganj-55 MW PP(Summit)       | (IPP)           | 3*17.08+1*11.3      | 55               | 55                   | 1146529          |                           |
| 13                           | Keraniganj 100 MW PP (Powerpac)  | QRPP            | 8*13.45             | 0                | 0                    | 0                | Contract Expired          |
| 14                           | Narsinghā 22 MW PP (Doreen)      | SIPP, REB       | 8*2.90              | 22               | 22                   | 443556           |                           |
| 15                           | 210 MW Siddhirgonj TPP           | PDB             | 1*210               | 115              | 0                    | 0                | Under maint.              |
| 16                           | Siddhirgonj 2*120 MW GTTP        | EGCB            | 2*105               | 210              | 0                    | 1680000          | GT-2 U/M                  |
| 17                           | Siddhirgonj 100 PP(Dutch Bangla) | QRPP            | 12*8.9              | 100              | 100                  | 2206685          |                           |
| 18                           | Siddhirgonj 335 MW CCPP          | EGCB            | 1*217+1*118         | 335              | 335                  | 1934092          |                           |
| 19                           | Gagnagar 102 MW PP (Digital Po   | IPP             | 12*8.924            | 102              | 94                   | 2124864          | Engine problem            |
| 20                           | Katpali 52 MW PP (Sinha)         | IPP             | 7*7.9               | 0                | 0                    | 0                | Fuel shortage             |
| 21                           | Kamalaghat 54 MW PP(Banco En     | IPP             | 3*18                | 54               | 35                   | 874080           | Engine problem            |
| 22                           | Kodda 150MW PP                   | BPDB-RPCL       | 9*17.06             | 149              | 150                  | 3282240          |                           |
| 23                           | Manikganj 55 MW PP (Northern)    | IPP             | 3*19.3              | 55               | 55                   | 1329258          |                           |
| 24                           | Nababganj 55 MW PP (Southern)    | IPP             | 3*19.3              | 55               | 55                   | 810995           |                           |
| 25                           | Bosila 108MW PP(RCL)             | IPP             | 12*8.775+1*3.5      | 0                | 0                    | 0                |                           |
| 26                           | Summit Power (Madhabdi-Ashuli    | SIPP, REB       | 3*3.67+4*8.73       | 80               | 42                   | 1031640          | Engine problem            |
| 27                           | Maona 33 MW PP(Summit)           | SIPP, REB       | 4*8.73              | 33               | 33                   | 793600           |                           |
| 28                           | Rupganj 33 MW PP(Summit)         | SIPP, REB       | 4*8.73              | 33               | 25                   | 506100           | Engine problem            |
| 29                           | Saidpur 52 MW PP                 | RPCL            | 6*17.5              | 52               | 47                   | 1085760          | #REF!                     |
| 30                           | Tongi 80 MW GTTP                 | PDB             | 1*105               | 105              | 0                    | 0                | Under maint.              |
| 31                           | Kodda 300 MW PP Unit-2 (Summ     | IPP             | 18*17.076           | 300              | 290                  | 6894942          |                           |
| 32                           | Keraniganj 300 MW PP (APR)       | IPP             | 25*11.4             | 300              | 25                   | 3699459          | Low demand.               |
| 33                           | Bramhangaan 100 MW PP (Aggr      | IPP             | 114*0.959           | 100              | 90                   | 1568027          | Engine problem            |
| 34                           | Aurahati 100MW PP (Aggreko)      | IPP             | 0.85*23+0.95*91     | 100              | 50                   | 1272699          | Low demand.               |
| 35                           | Kodda 149 MW PP Unit-1 (Summ     | IPP             | 8*18.45+8.97        | 149              | 132                  | 3082032          | Engine problem            |
| 36                           | Gazipur 100 MW PP                | RPCL            | 6*17.5              | 105              | 90                   | 2148000          |                           |
| 37                           | Meghnaghat 104 MW PP (OPCL)      | IPP             | 18.5*6              | 104              | 92                   | 2228160          |                           |
| 38                           | Manikgonj 162MW PP(MPGL)         | IPP             | 9*18                | 162              | 162                  | 3843360          |                           |
| 39                           | Spectra Solar Plant Ltd.         | IPP             | 35                  | 35               | 0                    | 0                |                           |
| 40                           | Kanchan Purbachal Power Gener    | IPP             | 18.4*3              | 55               | 55                   | 1328760          |                           |
| <b>Dhaka area Total</b>      |                                  |                 |                     | <b>5847</b>      | <b>3647</b>          | <b>82650054</b>  |                           |
| 41                           | Chattogram TPP-1                 | PDB             | 1*210               | 180              | 100                  | 2400000          | Machine problem           |
| 42                           | Chattogram TPP-2                 | PDB             | 1*210               | 180              | 0                    | 0                | Gas shortage              |
| 43                           | Razzan 25 MW PP                  | RPCL            | 3*8.9               | 25               | 25                   | 514774           |                           |
| 44                           | Teknaf 20MW PP (SolarTech)Teknaf | SolarTech Energ | 20                  | 20               | 0                    | 58185            |                           |
| 44                           | Patenga 50MW PP (Baraka)         | IPP             | 8*6.88              | 50               | 44                   | 1008000          | Engine problem            |
| 45                           | Kapla Hydro: Unit-1,2,3,4, 5     | PDB             | 2*40+3*50           | 230              | 32                   | 804420           | Low water level           |
| 46                           | Sikalbaha 225MW                  | PDB             | 1*150+1*175         | 225              | 0                    | 0                | HGPI for 30 days.         |
| 47                           | Sikalbaha Peaking GT             | PDB             | 1*150               | 150              | 0                    | 0                | Under maint.              |
| 48                           | Sikalbaha 105 MW PP (Baraka St   | IPP             | 6*17.5              | 105              | 105                  | 2526643          |                           |
| 49                           | Hathazari 100 MW peaking PP      | PDB             | 11*8.9              | 98               | 34                   | 370032           | Engine problem            |
| 50                           | Dohazari -Kaleash 100 MW Peakin  | PDB             | 6*17                | 102              | 51                   | 312738           | Fuel shortage             |
| 51                           | Juddah 100 MW Unit-1 (Acorn)     | QRPP            | 8*13.45             | 100              | 90                   | 2033760          | Engine problem            |
| 52                           | Juddah 100 MW PP Unit-3 (Acorn)  | IPP             | 8*13.5              | 100              | 90                   | 2114880          | Engine problem            |
| 53                           | Barabkunda 22 MW PP (Regent)     | SIPP, PDB       | 8*2.90              | 22               | 22                   | 504864           |                           |
|                              | Malancha Ctg. EP2 (Unite)        | IPP             | 5*8.73+3*9.34       | 0                | 30                   | 501120           |                           |
| 54                           | Chattogram 108 MW PP (ECPV)      | IPP             | 18*7                | 108              | 78                   | 1774080          | Engine problem            |
| 55                           | Kapla 7 MW Solar PP              | PDB             | 7.4 MW              | 7                | 0                    | 27000            |                           |
| 56                           | Anwara 300 MW PP (Unite)         | IPP             | 17*17+24            | 300              | 265                  | 6056945          | Engine problem            |
| 57                           | Jodiac Power                     | IPP             | 3*18.55+1*3.6       | 54               | 54                   | 1368789          |                           |
| 58                           | Karnaphuli Power Ltd.            | IPP             | 18.415*6+6.5        | 110              | 110                  | 2530825          |                           |
| 59                           | Juddah unit-2 (Acorn)            | IPP             | 8*13.6              | 100              | 100                  | 2394240          |                           |
| 60                           | Anilma Energy Ltd.               | IPP             | 6*21.2              | 116              | 90                   | 2132727          | Engine problem            |
| <b>Chattogram area Total</b> |                                  |                 |                     | <b>2382</b>      | <b>1320</b>          | <b>29434022</b>  |                           |
| 61                           | Ashuganj TPP Unit-3              | APSCL           | 1*150               | 0                | 0                    | 0                | Contract Expired          |
|                              | Ashuganj TPP Unit-4              | APSCL           | 1*150               | 0                | 0                    | 0                | Contract Expired          |
|                              | Ashuganj TPP Unit-5              | APSCL           | 1*150               | 134              | 0                    | 0                | Gas shortage              |
| 62                           | Ashuganj 225 MW CCPP             | APSCL           | 1*142+1*75          | 221              | 213                  | 4369000          | #REF!                     |
| 63                           | Ashuganj 450 MW CCPP(North)      | APSCL           | 1*360               | 360              | 10                   | 607500           | Gas shortage              |
| 64                           | Ashuganj 450 MW CCPP(South)      | APSCL           | 1*360               | 360              | 280                  | 7645000          | Gas shortage              |
| 65                           | Ashuganj 50 MW PP                | APSCL           | 14*3.968            | 45               | 34                   | 841392           | Engine problem            |
| 66                           | Ashuganj 55 MW PP (Precision)    | RPP             | 15*4                | 55               | 5                    | 899520           | Gas shortage              |
| 67                           | Ashuganj 195MW PP (APSCL-UR      | IPP             | 20*9.73+1*16        | 195              | 8                    | 1137454          | Gas shortage              |
| 68                           | Ashuganj 51 MW PP (Midland)      | IPP             | 6*9.34              | 51               | 43                   | 942628           | Engine problem            |
| 69                           | Ashuganj 150MW PP (Midland)      | IPP             | 23*7.015            | 150              | 133                  | 3059418          | Engine problem            |
| 70                           | Titas 50 MW Peaking PP           | PDB             | 6*8.92              | 52               | 40                   | 478032           | Low demand.               |
| 71                           | Chandpur 150 MW CCPP             | PDB             | 1*108+1*57          | 163              | 91                   | 519700           | ST-under maint.           |
| 72                           | Chandpur 200MW (Dash energy)     | IPP             | 12*18.4             | 200              | 200                  | 3007680          |                           |
| 73                           | Feni 22MW PP (Doreen)            | SIPP, PDB       | 8*2.90              | 22               | 16                   | 430812           |                           |
| 74                           | Feni 11 MW PP (Doreen)           | SIPP, REB       | 4*2.90              | 11               | 8                    | 191520           |                           |
| **                           | Impoport (Tripura)               | Imported power  | 0                   | 160              | 82                   | 2117760          | Bad weather.              |
| 75                           | Jangalia 33MW PP (Summit)        | SIPP, PDB       | 4*8.73              | 33               | 33                   | 795000           |                           |
| 76                           | Jangalia 52 MW PP (Kandana)      | IPP             | 8*9.92              | 52               | 0                    | 0                | Fuel shortage             |
| 77                           | Cumilla 25 MW PP (Summit)        | SIPP, PDB       | 3*3.67+2*6.97       | 25               | 21                   | 345200           |                           |
| 78                           | Daudkandi 200 MW PP (B.Trac)     | IPP             | 154*1.4             | 200              | 50                   | 647232           | Low demand.               |
| 79                           | Feni Lanka Power                 | IPP             | 7*18.415+1*9.78     | 114              | 0                    | 0                | Fuel shortage             |
| 80                           | Chowmuhani 113 MW                | IPP             | 12*9.78+2*3.1       | 113              | 13                   | 230160           | Fuel shortage             |
| 81                           | Bhairab 54.5 MW                  | IPP             | 3*18.2              | 54               | 35                   | 865440           | 33 kV feeder problem.     |
| 82                           | Chandpur 115(Doreen)             | IPP             | 4*18.5+2*22.5       | 115              | 102                  | 2370240          | Engine problem            |
| <b>Cumilla Area Total</b>    |                                  |                 |                     | <b>2885</b>      | <b>1417</b>          | <b>31508668</b>  |                           |
| 83                           | RPCL 210MW CCPP                  | IPP             | 4*35+1*70           | 202              | 142                  | 2580480          | Gas shortage              |
| 84                           | Tangail 22 MW PP (Doreen)        | SIPP, PDB       | 8*2.90              | 22               | 14                   | 362268           |                           |
| 85                           | Jamalpur 95 MW PP(Powerpac)      | IPP             | 12*8.924            | 0                | 0                    | 0                | Under maint.              |
| 86                           | Sarishabari 3 MW Solar Plant     | IPP             | 1*3                 | 3                | 0                    | 8000             |                           |
| 87                           | Mymensingh 200 MW PP (Unite)     | IPP             | 9.78*21             | 200              | 191                  | 4490400          | Engine problem            |
| 88                           | Jamalpur 115 MW PP (Unite)       | IPP             | 9.78*12             | 115              | 97                   | 2116800          | Engine problem            |
| 89                           | Sutakhal 50 MW Solar PP          | IPP             | 50                  | 50               | 0                    | 107230           |                           |
| 90                           | Tangail Pali Power Gen 22 MW     | IPP             | 4*6.7               | 22               | 22                   | 530880           |                           |
| <b>Mymensingh Area Total</b> |                                  |                 |                     | <b>614</b>       | <b>466</b>           | <b>10197258</b>  |                           |
| 91                           | Fenchugonj CCPP Phase-1          | PDB             | 2*32+1*33           | 70               | 43                   | 1028000          | Machine problem           |
| 92                           | Fenchugonj CCPP Phase-2          | PDB             | 2*35+1*35           | 90               | 41                   | 958344           | Machine problem           |
| 93                           | Kushara 163 MW CCPP (KP)         | IPP             | 1*109+1*54          | 163              | 110                  | 2722990          | ST Under maint.           |
| 94                           | Shahjibazar 330 MW CCPP          | PDB             | 3*110               | 330              | 0                    | 0                | Under maint.              |
| 95                           | Fenchugonj 51 MW PP (Barakata    | RPP             | 19*2.90             | 51               | 53                   | 1126200          |                           |
|                              | Fenchuganj 44MW (Energyprima     | RPP             | 12*3.5+5*2          | 50               | 50                   | 1090440          |                           |
| 96                           | Hobiganj 11MW PP Confidence-E    | SIPP, REB       | 4*2.90              | 11               | 11                   | 264000           |                           |
| 97                           | Shahjibazar GTTP Unit- 8 & 9     | PDB             | 2*35                | 66               | 64                   | 1459872          |                           |
| 98                           | Shahjibazar 86MW PP (Shahjibaz   | RPP             | 32*2.90             | 86               | 78                   | 1809600          |                           |
| 99                           | Shahjibazar 100 MW GTTP          | PDB             | 1*100               | 100              | 0                    | 0                | Under maint.              |
| 100                          | Sylhet 225 MW CCPP               | PDB             | 1*142+1*89          | 231              | 125                  | 1051800          | Sync at 15.09.            |
| 101                          | Sylhet. 20 MW GTTP               | PDB             | 1*20                | 20               | 19                   | 435000           |                           |
|                              | Sylhet 50MW PP (EPL)             | RPP             | 27*2                | 50               | 31                   | 851960           | Engine problem            |
| 102                          | Shahjahanulla 25 MW PP           | SIPP, REB       | 3*9.34              | 25               | 24                   | 526440           |                           |
| 103                          | Bibiana-II 341 MW CCPP (Summ     | IPP             | 1*222+1*119         | 341              | 275                  | 7181500          | FGMO                      |
| 104                          | Bibiyana-III 400 MW CCPP         | PDB             | 400 MW              | 400              | 285                  | 1290000          | GT synchronized at 17:17. |
| 105                          | Sylhet 10MW PP (Dash)            | RPP             | 8*1.95              | 10               | 10                   | 253980           |                           |
| 106                          | Bibiyana South 400 MW            | PDB             | 400 MW              | 383              | 400                  | 4401800          |                           |
| <b>Sylhet Area Total</b>     |                                  |                 |                     | <b>2477</b>      | <b>1619</b>          | <b>26451925</b>  |                           |
| 107                          | Bheramara GTTP Unit-3            | PDB             | 1*20                | 16               | 0                    | 0                | Reserve.                  |
| **                           | Bheramara (HVDC )                | Imported power  | 2*500               | 1000             | 907                  | 21920000         |                           |
| 108                          | Khulna 115 PP MW (KPCL-2)        | QRPP            | 7*17                | 115              | 78                   | 2055360          | Engine problem            |
| 109                          | Faridpur 50 MW Peaking PP        | PDB             | 8*6.89              | 54               | 39                   | 371040           | Engine problem            |
| 110                          | Khulna 225 MW CCPP               | NWPGCL          | 1*150+1*75          | 230              | 217                  | 3816000          |                           |
| 111                          | Gopalganj 100 MW Peaking PP      | PDB             | 16*6.88             | 109              | 60                   | 499968           | Engine problem            |
| 112                          | Bheramara 410 MW CCPP            | NWPGCL          | 1*278+1*132         | 410              | 205                  | 5713632          | Gas shortage              |
|                              | Noapara 40 MW PP (Khanjahan A    | ORPP            | 5*8.5               | 40               | 32                   | 251250           |                           |
| 113                          | Noapara 100 MW PP (Bangla Tre    | IPP             | 70*1.4              | 100              | 20                   | 211200           | Low demand.               |
| 114                          | Rupsha 105 MW PP (Orion rupsh    | IPP             | 6*18.445            | 105              | 93                   | 1932480          | Engine problem            |
| 115                          | Madhumati 100 MW PP              | NWPGCL          | 6*18                | 105              | 89                   | 1987184          | Engine problem            |
| 116                          | Mongla Orion 100 MW Solar PP     | IPP             | 100                 | 100              | 0                    | 496900           |                           |
| <b>Khulna Area Total</b>     |                                  |                 |                     | <b>2384</b>      | <b>1740</b>          | <b>38234914</b>  |                           |
| 117                          | Barisal 110 MW PP (Summit )      | IPP             | 7*17.076            | 110              | 48                   | 1022304          | Line O/L                  |
| 118                          | Bhola 33 MW PP (Venture)         | RPP             | 1*34.50             | 40               | 32                   | 615476           | Engine problem            |
| 119                          | Bhola 225 MW CCPP                | PDB             | 2*63+1*68           | 194              | 83                   | 2659654          | Gas shortage              |
| 120                          | Bhola 95 MW PP (Aggreko)         | QRPP            | 96*1.10             | 0                | 0                    | 0                | Contract Expired          |
| 121                          | Payra 1320 MW                    | BPCL            | 2*622               | 1244             | 1000                 | 24072000         | Line O/L                  |
| 122                          | Bhola Nutan Biddut BD LTD        | IPP             | 220                 | 220              | 222                  | 4097973          | Machine problem           |
| 123                          | United Payra Power Ltd.          | IPP             | 8*18.5+1*9.5        | 150              | 17                   | 445200           | Line O/L                  |
| <b>Barisal Area Total</b>    |                                  |                 |                     | <b>1958</b>      | <                    |                  |                           |