

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2022					Day : Thursday				Date : 16.06.22			
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 14696 MW				Rule Curve = 79.95 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 71.79 ft				Today = 74.02 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.06.22 (Yesterday)		16.06.22 (Today)		15.06.22 (Yesterday)		16.06.22 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	280	280	280			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	90	97	97	97			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	311	337	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	409	405	412			
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	94	0	0	0	105	105	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	335	300	335			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335	Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	85	94	94	94			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	40	42	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	25	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	43	47	48	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	90	90			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150			
23	Karnaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	276	290	285	290			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	115	132	130	135			
26	Kerangonj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	301	25	300	300			
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	90	100	100			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	50	98	98			
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	92	93	93			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
33	Manikgonj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Siddhirganj 100 MW PP/Dutch Bangla	HFO (NENP)	12x8.9	100	100	88	100	90	100			
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	70	85	79	90			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	3513	3647	3951	3994	330	1100
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	32	32	38	38	198	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
41	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	20	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	2	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	44	44	44			
44	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	105	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	248	265	265	265			
48	Julidah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	34	17	35			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	30	5	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	77	78	78	81			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	90	110	110	110			
55	Julidah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
56	Julidah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	78	90	78	90			
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	90	90	90	90			
Chattogram Zone Total					2442	2382	1150	1320	1246	1330	278	555
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	0	0	0	0	0		Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	34	34	38	38			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	208	213	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	305	280	270	280	280			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	10	100	250		Under Startup	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	5	10	5	50	Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	92	8	8	8	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	110	133	140	140			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	40	40	50	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	91	90	90			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	200	150	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	16	21	21			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	21	20	20			
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	95x1.4+63x.915+15x1.208	200	200	25	50	0	200			
76	Feni 11.4 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	13	9	9			
78	Bharat 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	102	100	100			
**	Import (Tripura)	India		160	160	100	82	143	165			
Cumilla Zone Total					3059	2885	1289	1417	1478	1905	371	0
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	87	142	110	120	60	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	14	20	20			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	85	97	95	105			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	188	191	180	191			
84	Saishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0			
86	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	22	22	22	22	60	0	
Mymensingh Zone Total					622	614	414	466	479	458	60	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.06.22 (Yesterday)		16.06.22 (Today)		15.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	53	51	51				
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		53	ST under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	64	62	65				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	81	81				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	125	100	200			Under Startup	
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	19	19	19				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	15	24	24	24				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	275	310	341				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	285	285	285			ST under startup	
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	102	400	100	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	37	31	41	41				
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	50	50	50	50				
Sylhet Zone Total						2522	2477	934	1619	1338	1772	0	559
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	240	205	230	230		205	Gas Shortage	
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	38	38				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	60				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	120	217	120	220				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	0	100				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	20	93	93	93				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	55	89	70	89				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	81	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	60	78	92	115				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	32	40	40				
**	Bheramara (HVDC)	India		1000	1000	906	907	920	920				
Khulna Zone Total						2388	2384	1490	1740	1703	1905	205	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	48	48	48				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	32	23	33				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	83	85	85				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1000	1050	1050				
120	Potulakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
121	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	223	222	180	220				
Barishal Zone Total						1958	1958	1235	1402	1403	1453	0	0
122	a) Baghatbari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghatbari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
123	Baghatbari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	34	0	34				
124	Baghatbari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	11	20	100	190				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	8	0	0				
126	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	90	0	90				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	8	32	32	32				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	34	34	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	194	216	130	210				
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	187	175	180	210				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	350	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	95	95	95				
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	94	94				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total						2129	2129	1095	1283	1084	1476	381	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175		99	Coal Shortage	
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	74	87	95	95				
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
145	Majpara, Tatala 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	1	0	8	0				
146	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	36	108	72	108				
Rangpur Zone Total						800	720	286	370	350	403	184	85
Sub-total: Plants in operation						21924	21396	11406.0	13264	13032	14696	1809	2299
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								10981	12770	12546	14149		
(B) Plants under long term maintenance/contract expired													
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired
148	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/contract expired						424	0	0	0	0	0		
Gross Total						22348	21396	11406	13264	13032	14696	1809	2299
(C) Actual data of 15.06.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13264	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12770	MW, at =	21:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	13306	MW, at =	23:00 hrs			MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	10479	MW, at =	8:00 hrs		Dhaka	4769	4769	0	Myensingh	984	984
05.	Day-peak Generation (Generation end)	:	11406	MW, at =	12:00 hrs		Chattogram	1245	1245	0	Sylhet	385	385
06.	Evening-peak Generation (Generation end)	:	13264	MW, at =	21:00 hrs		Khulna	1657	1657	0	Barishal	413	413
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs		Rajshahi	1453	1453	0	Rangpur	753	753
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10104	MW, at =	5:00 hrs		Cumilla	1110	1110	0			
09.	Generation shortfall at evening peak due to :	:					Total						
	a) Gas limitation	:	1427	MW									
	d) Coal supply Limitation	:	184	MW									
	b) Low water level in Kapali lake	:	198	MW									
	c) Plants under shut down/ maintenance	:	2299	MW									
10.	Total Energy (Generation + India Import)	:	287.81	MKWh									
	By Gas =	121.125	MKWH	By Oil =	112.753	MKWh							
	By Coal =	28.356	MKWH	By Hydro =	0.804	MKWh							
	By Solar=	0.732	MKWH										
11.	Total Gas Supplied	:	1014.90	MMCFD									
(D) Forecast of 16.06.22 (Today) Thursday :													
01.	Maximum Demand	:	14000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14696	MW	(Generation end)	05.	Total Generation	:	302.82	MKWh			
03.	Reserve / Shortage	:	696	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.7°	C			

* Captive Power; ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation