

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		17-Jun-22		Page -2			
No.	Name of the Power Stations	Producer	Installed Capacity	Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-1	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	180	4378500	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	220	5256727	Condenser problem
4	Ghorashal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	97	2111818	Engine problem
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	43	6301700	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	0	3910000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	360	5908050	Gas shortage
9	Meghnaghat 100 MW(EL)	ORPP	12*8.9	100	78	1383360	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	300	4055360	Gas shortage
11	Madanganj 102 PP(Summit)	ORPP	6*17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	965544	
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	146376	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	GT-2 U/M
17	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	16	614400	Low demand
18	Siddhirgonj 335 MW CCPP	ORPP	1*217+1*118	335	46	4601048	Synchronized at 19:47.
19	Gaganagar 102 MW PP (Digital Po	IPP	12*8.924	102	0	632880	Reserve.
20	Katpali 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	995760	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	0	390720	Reserve.
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	782760	
24	Nababganj 55 MW PP (Southern	IPP	3*19.3	55	35	929222	Engine problem
25	Bosila 108MW PP(RCLC)	IPP	12*8.75+1*3.5	0	0	0	
26	Summit Power (Madhabadi-Ashuli	SIPP, REB	3*3.67+4*8.73	80	41	899880	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	28	697200	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	261900	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	0	414720	#REF!
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	130	2453890	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	0	Reserve.
33	Bramhangonj 100 MW PP (Aggr	IPP	114*0.959	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	8*18.45+8.97	149	106	2132928	Engine problem
36	Gazipur 100 MW PP	RPCL	6*17.5	105	0	1103880	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*5*6	104	68	1547520	Engine problem
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	35	1329120	Low demand
39	Spectra Solar Plant Ltd.	IPP	35	35	0	0	
40	Kanchan Purbachal Power Gener	IPP	18.4*3	55	17	541800	Low demand
Dhaka area Total				5847	1984	54747063	
41	Chattogram TPP-1	PDB	1*210	180	100	2400000	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Razzan 25 MW PP	RPCL	3*8.9	25	0	52070	Reserve.
44	Teknaf 20MW PP (SolarTech)Teknaf	SolarTech Energ	20	20	0	59265	
44	Patenga 50MW PP (Baraka)	IPP	8*6.88	50	45	842400	Engine problem
45	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	66	1582380	Low water level
46	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	IPP	1*150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Si	IPP	6*17.5	105	105	2225554	
49	Hathazari 100 MW Peaking PP	PDB	11*8.9	98	0	36096	Reserve.
50	Dohazari -Kalesh 100 MW Peakir	PDB	6*17	102	0	126407	Fuel shortage
51	Juddah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	60	1038000	Low demand
52	Juddah 100 MW PP Unit-3 (Acom)	IPP	8*13.5	100	90	1515840	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	524352	
	Malancha, Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	42	724320	
54	Chattogram 108 MW PP (ECPV)	IPP	18*7	108	0	142080	Reserve.
55	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	7559	
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	0	1342364	Reserve.
57	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1067338	
58	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	92	1947880	Engine problem
59	Juddah unit-2 (Acom)	IPP	8*13.6	100	100	1962240	Reserve.
60	Anilma Energy Ltd.	IPP	6*21.2	116	90	2031109	Engine problem
Chattogram area Total				2382	866	19627254	
61	Ashuganj TPP Unit-3	APSCL	1*150	0	0	0	Contract Expired
	Ashuganj TPP Unit-4	APSCL	1*150	0	0	0	Contract Expired
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	176	3541000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	280	7117000	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	280	6612000	Gas shortage
65	Ashuganj 50 MW PP	APSCL	14*3.968	45	0	46512	Gas shortage
66	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	5	136800	Gas shortage
67	Ashuganj 195MW PP (APSCL-UR	IPP	20*9.73+1*16	195	8	200727	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	50	948773	
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	149	2062479	
70	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	80592	Reserve.
71	Chandpur 150 MW Peaking PP	IPP	1*108+1*157	163	135	3214310	Machine problem
72	Chandpur 200MW (Dash energy)	IPP	12*18.4	200	155	2487840	Low demand
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	441900	Engine problem
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	183960	Engine problem
**	Impoport (Tripura)	Imported power	0	160	100	2299200	
	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	738700	
76							