

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 21-Jun-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
				MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1120	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4347000	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	68	1469909	Engine problem
7	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273+1138	412	411	10110880	
9	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	0	0	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1150	450	450	9558750	
11	Meghnaghat 100 MW(EL)	NENP	12*8.9	100	88	1942800	Engine problem
12	Meghnaghat CCGP(Summit)	IPP	2*110+1110	335	250	6545047	FGMO
13	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
14	Madanganj-55 MW PP(Summit)	IPP	3*17.08+111.3	55	40	1076479	Engine problem
15	Karaniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	285192	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 212MW GTTP	EGCB	2*105	210	96	1858000	GT-2 U/M and gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*8.9	100	100	1224941	
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	335	7513267	
21	Saagaraj 102 MW PP (Digital Po	IPP	12*8.924	102	85	1302768	Engine problem
22	Katpali 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1285920	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	625440	
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1009997	
26	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	55	883692	
27	Bosila 108MW RPCL	IPP	12*9.75+113.5	0	0	0	
28	Summit Power (Madhabdi Ashuli)	SIPP, REB	3*3.67+4*8.73	80	45	1058280	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	717670	Engine problem
30	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	0	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	41	688320	#REF!
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.06	300	278	3979416	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	169	716956	Low demand
35	Bramhangonj 100 MW PP (Aggr	IPP	114*0.959	100	50	25284	Low demand
36	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	50	28754	Low demand
37	Kodda 149 MW PP Unit-1 (Summ	IPP	8*18.45+8.97	149	132	2525616	Engine problem
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	1880400	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	2008320	
40	Manikganj 162MW (MPGL)	IPP	9*18	162	162	2306160	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	0	
42	Kanchan Purbachal Power Gener	IPP	18.4*3	55	55	1327320	
Dhaka area Total				5847	3655	67744748	
43	Chattogram TPP-1	PDB	1*210	180	100	2400000	Machine problem
44	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
45	Razzan 25 MW PP	RPCL	3*8.9	25	16	109731	Engine problem
46	Teknaf 20MW PP (Solartech)	IPP	2*9	20	0	0	48410
47	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	45	1011360	Engine problem
48	Kapla Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	117	2673455	Low water level
49	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka S	IPP	6*17.5	105	105	2342490	
52	Hahazari 100 MW peaking PP	PDB	11*8.9	98	34	94781	Gas shortage
53	Dohazari -Kalaish 100 MW Peakir	PDB	6*17	102	51	186582	Gas shortage
54	Judah 100 MW Unit-1 (Acom)	NENP	8*13.45	100	80	1427040	Engine problem
55	Judah 100 MW PP Unit-3 (Acom)	IPP	8*13.5	100	90	2016960	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	22	520752	
57	Malancha Cig. EP2 (United)	IPP	5*8.73+3*9.34	0	22	509760	
58	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	65	182400	Engine problem
59	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	24690	
60	Anwara 300 MW PP (United)	IPP	17*17.24	300	242	2338473	Engine problem
61	Jodiac Power	IPP	3*18.55+1*3.6	54	35	857109	Engine problem
62	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	92	2537516	Engine problem
63	Judah unit-2 (Acom)	IPP	8*13.6	100	100	2262720	Engine problem
64	Anima Energy Ltd.	IPP	6*21.2	116	108	2458909	Engine problem
Chattogram area Total				2382	1324	24007228	
65	Ashuganj TPP Unit-3	APSCCL	1*150	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCCL	1*150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage
68	Ashuganj 225 MW CCGP	APSCCL	1*142+1*75	221	214	4913000	#REF!
69	Ashuganj 450 MW CCGP(North)	APSCCL	1*360	360	330	8097000	
70	Ashuganj 450 MW CCGP(South)	APSCCL	1*360	360	300	7327000	FGMO
71	Ashuganj 420 MW CCGP(East)	APSCCL	284+138*1	0	0	246981	On test.
72	Ashuganj 50 MW PP	APSCCL	14*3.968	45	34	812088	Engine problem
73	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	52	1262880	
74	Ashuganj 195MW PP (APSCCL-Ur	IPP	20*9.73+11*16	195	88	2191272	Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1056656	Engine problem
76	Ashuganj 150MW PP (Midland)	IPP	23*17.05	150	143	2418763	Engine problem
77	Titas 50 MW Peaking PP	PDB	6*8.92	50	50	116760	
78	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	136	3250360	Machine problem
79	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	200	2857760	
80	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	497088	
81	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	235260	
82	Import (Tripura)	Imported power	0	160	124	2492160	
83	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	666300	
84	Jangalia 52 MW PP (Lakdewee)	IPP	6*8.92	52	0	0	Fuel shortage
85	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	20	503330	
86	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	10	4224	Low demand
87	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Fuel shortage
88	Chowmahani 113 MW	IPP	12*9.78+2*3.1	113	96	1194480	Engine problem
89	Bharat 54.5 MW	IPP	3*18.2	54	17	516240	33 kV feeder problem.
90	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	116	2393396	
Cumilla Area Total				2885	2038	42910962	
91	RPCL 210MW CCGP	IPP	4*35+1*70	202	167	3967680	Gas shortage
92	Tangali 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	419508	
93	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
94	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	6800	
95	Mymensingh 200 MW PP (Unite	IPP	9*7.21	200	193	3693900	Engine problem
96	Jamalpur 115 MW PP (Unite)	IPP	3*7.12	115	92	1027200	Engine problem
97	Suitkhal 50 MW Solar PP	IPP	50	50	0	228170	
98	Tangali Pali Power Gen 22 MW	IPP	4*6.7	22	22	532900	
Mymensingh Area Total				614	494	9875758	
99	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	43	1032000	Machine problem
100	Fenchugonj CCGP Phase-2	PDB	2*36+1*35	80	0	0	Machine problem
101	Koshiara 163 MW CCGP (RP)	IPP	1*108+1*54	163	110	2704172	ST Under maint.
102	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
103	Fenchugonj 51 MW PP (Barakati	RPP	19*2.90	51	53	1169400	
104	Fenchugonj 44MW (Energyprima	NENP	12*3.6+5*2	50	49	1169784	
105	Hobiganj 11MW PP (Confidence-E	SIPP, REB	4*2.90	11	11	212113	
106	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	57	1342464	
107	Shahjibazar 98MW PP (Shahjiba	RPP	32*2.90	86	86	1898880	
108	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
109	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	120	2887680	Gas shortage
110	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
111	Sylhet 50MW PP (EPL)	NENP	27*2	50	25	534580	Gas shortage
112	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	109816	Engine problem
113	Bibianna-II 341 MW CCGP (Summ	IPP	1*222+1*119	341	260	6929000	FGMO
114	Bibianna-III 400 MW CCGP	PDB	400 MW	400	400	949000	
115	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	176400	
116	Bibianna South 400 MW	PDB	400 MW	383	389	8605800	
Sylhet Area Total				2477	1628	38264089	
117	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
118	Bheramara (HVDC)	Imported power	2*500	1000	921	22314181	
119	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	62	933120	Engine problem
120	Faidpur 50 MW Peaking PP	PDB	8*6.98	54	44	68160	Engine problem
121	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	0	0	Reserve.
122	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
123	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	330	7390556	Gas shortage
124	Noapara 40 MW PP (Khanjahan A	NENP	5*8.5	40	32	333000	Engine problem
125	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	70	42240	Low demand
126	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	90	1046280	Engine problem
127	Madhumali 100 MW PP	NWPGCL	6*18	105	15	36000	Low demand
128	Mongla Orion 100 MW Solar PP	IPP	100	100	0	372240	
Khulna Area Total				2384	1564	32538877	
129	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	89088	Line O/L
130	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	28	507158	Engine problem
131	Bhola 225 MW CCGP	PDB	2*63+1*68	194	87	2161250	Gas shortage
132	Bhola 95 MW PP (Aggreko)	ORPP	8*11.40	0	0	0	Contract Expired
133	Payra 1320 MW	BCPCL	2*822	1244	420	11338700	Line O/L
134	Bhola Nutan Bidut BD LTD	IPP	220				