

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2022				Day : Wednesday				Date : 22.06.22			
Probable Maximum Demand : 13200 MW				Probable Maximum Generation : 14693 MW				Rule Curve = 81.57 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 83.23 ft.				Today = 85.47 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.06.22 (Yesterday)		22.06.22 (Today)		21.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW		
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	60	68	69	76		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	400	400		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	412	411	412	412		
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	96	96	97	97	9	105
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	300	250	320	320		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	55		
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	85	85	85		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	45	45	45	45		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33		
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	0	25	25		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	43	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	90	105		
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	150	150		
23	Kamalganj 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	278	285	290		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	132	135	135		
26	Karanganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	169	200	300		
27	Banriganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	100	100		
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	25	98		
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	53	55	55	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	53	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	104	104	104		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	107	162	162	162		
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	30	0	0		
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	100	100	100		
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	89	88	80	88		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total			6004	5847	2847	3655	3786	3986	9	1130	
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	108	117	81	81	113	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0	0		
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	45	45	45		
44	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	87	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	100	242	265	300		
48	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	90	90	90	90		
49	Doahazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	34	0	0		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	22	11	20		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	65	80	92		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	35	35		
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	92	110	110		
55	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
56	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	80	80	50	50		
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	108	108	108		
Chattogram Zone Total			2442	2382	949	1324	1252	1334	193	555	
58	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	0	0	0	0	0		Contract Expired
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	34	35	35		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	212	214	215	215		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	300	320	320		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	330	330	330		
	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)				40	0	0	0		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	52	52	52		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	88	88	110	110	107	Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	80	143	140	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	136	135	135		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	73	200	150	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	8	8		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	21	21		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.35+15x1.058	200	200	0	10	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	96	38	94		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	100	116	100	115		
**	Import (Tripura)	India		160	160	104	124	143	165		
Cumilla Zone Total			3059	2885	1724	2038	2079	2332	241	0	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	151	167	150	150	35	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	92	95	107		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	120	193	180	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakthali 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0		
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22		
Mymensingh Zone Total			622	614	365	494	519	499	35	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.06.22 (Yesterday)		22.06.22 (Today)		21.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51					
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		53	ST under maint.		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	57	65	65					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	84	84					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	120	120	120					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	8	8					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	260	320	341					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	400	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	389	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	21	25	25	25					
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	45	49	50	50					
Sylhet Zone Total						2522	2477	1654	1628	1697	1718	0	600	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	330	290	290	80		Gas Shortage		
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	39					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60					
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	70	0	100					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	90	93	93					
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	70	89					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	73	0	100	0					
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	62	97	97					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	32	40	40					
**	Bheramara (HVDC)	India		1000	1000	924	921	940	940					
Khulna Zone Total						2388	2384	1354	1564	1630	1968	80	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	48	48					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	28	20	25					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	87	87	87					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	330	420	622	622					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	35	35					
121	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	225	220	220	220					
Barishal Zone Total						1958	1958	657	788	1032	1037	0	0	
122	a) Baghatbari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghatbari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
123	Baghatbari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	15	0	34					
124	Baghatbari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	2	100	190					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	0					
126	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	89	0	90					
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32					
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	0	34					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	37					
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	140	167	170	160					
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	170	163	190	180					
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	372	414	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0					
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	75	111	75	113					
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	94	94	94					
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0					
Rajshahi Zone Total						2129	2129	898	1154	1114	1411	381	0	
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175	175	99		Coal Shortage		
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15					
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	95	70	100					
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
145	Majpara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
146	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	90	108	108	108					
Rangpur Zone Total						800	720	337	378	361	408	184	85	
Sub-total: Plants in operation						21924	21396	10785.0	13023	13470	14693	1123	2370	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								10310	12449	12876	14045			
(B) Plants under long term maintenance/contract expired														
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired		
148	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired		
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired		
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/contract expired						424	0	0	0	0	0			
Gross Total						22348	21396	10785	13023	13470	14693	1123	2370	
(C) Actual data of 21.06.22 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)		13023 MW, at = 19:30 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)		12449 MW, at = 19:30 hrs				Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)		13023 MW, at = 19:30 hrs				Chhata	4668	4668	0	Mymensingh	969	969	0
04.	Minimum Generation (Generation end)		9143 MW, at = 7:00 hrs				Dhaka	1276	1276	0	Sylhet	389	389	0
05.	Day-peak Generation (Generation end)		10785 MW, at = 12:00 hrs				Khulna	1501	1501	0	Barishal	359	359	0
06.	Evening-peak Generation (Generation end)		13023 MW, at = 19:30 hrs				Rajshahi	1296	1296	0	Rangpur	859	859	0
07.	Evening Peak Load-shed (Sub-station end)		0 MW, at = 19:30 hrs				Cumilla	1132	1132	0				
08.	Minimum Generation Forecast up to 8:00 hrs.		9506 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :													
	a) Gas limitation		826 MW											
	d) Coal supply Limitation		184 MW											
	b) Low water level in Kapali lake		113 MW											
	c) Plants under shut down/ maintenance		2370 MW											
10.	Total Energy (Generation + India Import)		266.27 MKWh											
	By Gas =	154.740 MKWH	By Oil =	67.690 MKWH										
	By Coal =	15.617 MKWH	By Hydro =	2.673 MKWH										
	By Solar=	0.739 MKWH												
11.	Total Gas Supplied		1169.95 MMCFD											
(D) Forecast of 22.06.22 (Today) Wednesday :														
01.	Maximum Demand		13200 MW (Generation end)			04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation		14693 MW (Generation end)			05.	Total Generation : 269.89 MKWh							
03.	Reserve / Shortage		1493 MW (Generation end)			06.	Probable Max. Temperature in Dhaka : 32.6° C							