

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 25-Jun-22		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TYP Unit-5	PDB	1'210	190	180	4353000	
3	Ghorasal 365 MW CCGP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
4	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	87	1974863	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	411	9955330	
7	Haripur 360MW CCGP(HPL)	IPP	1'235+1'125	360	142	450000	Gas shortage
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1'150	450	400	9771000	Gas shortage
9	Meghnaghat 100 MW(IEI)	NENP	12'8.9	100	89	1943040	Engine problem
10	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	335	305	6714996	FGMO
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1162884	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	350100	
15	210 MW Siddhirgonj TTP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	GT-2 U/M and gas s
17	Siddhirganj 100 PP(Dutch Bangla)	NENP	12'8.9	100	98	1417046	
18	Siddhirganj 335 MW CCGP	EGCB	1'217+118	335	270	7387185	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	94	1609056	Engine problem
20	Katpoki 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1292400	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	150	1436160	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	1189189	
24	Nababaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	1141237	
25	Bosila 108MW PP(IECL)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabadi-Ashulia)	SIPP, REB	3'3.67+4'8.73	80	53	1222080	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	799400	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	0	0	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	50	918720	#REF!
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	278	4707053	Engine problem
32	Keraniganj 300 MW PP (APRI)	IPP	2'561.4	300	0	219009	Reserve.
33	Bramhanganj 100 MW PP (Aggreko)	IPP	114'0.959	100	27	77051	Low demand
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	30	100107	Low demand
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	134	2181168	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2328000	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	2137920	
38	Manikgonj 162MW PP(MPLG)	IPP	9'18	162	162	3054240	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	194597	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	0	591480	33 kV feeder proble
Dhaka area Total				5847	3443	70678311	
41	Chattogram TTP-1	PDB	1'210	180	100	2300000	Machine problem
42	Chattogram TTP-2	PDB	1'210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3'8.9	25	25	321242	
43	Teknaf 20MW PP (Solartech)	IPP	20	20	0	122715	
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	43	938400	Engine problem
45	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	125	2971195	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2544218	
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	34	199888	Engine problem
50	Dohazari -Kalash 100 MW Peaking	PDB	8'17	102	51	285439	Fuel shortage
51	Juldah 100 MW Unit-1 (Acom)	NENP	8'13.45	100	30	742440	Engine problem
52	Juldah 100 MW PP Unit-3 (Acom)	IPP	8'13.5	100	90	1931520	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	22	499824	
54	* Malancha, Ctg. EPZ (Unltd)		5'8.73+3'9.34	0	28	585120	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	82	464640	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	30000	
56	Anwara 300 MW PP (Unltd)	IPP	17'17+24	300	300	4147527	
57	Jodiac Power	IPP	3'18.55+1'3.6	54	54	1256536	
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	110	2366899	
59	Juldah unit-2 (Acom)	IPP	8'13.6	100	77	1479360	
60	Arilma Energy Ltd.	IPP	6'21.2	116	90	2152800	Engine problem
Chattogram area Total				2382	1386	25319763	
61	Ashuganj TTP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
62	Ashuganj TTP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
63	Ashuganj TTP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCGP	APSCL	1'142+1'175	221	208	4742000	#REF!
63	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	345	7919600	FGMO
64	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	330	7334000	FGMO
65	Ashuganj 420 MW CCGP(East)	APSCL	284'1+138'1	0	0	1272500	On test.
66	Ashuganj 50 MW PP	APSCL	14'3.968	45	14	403920	Engine problem
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	52	1203840	
67	Ashuganj 195MW PP (APSCL-Unltd)	IPP	20'9.73+1'16	195	189	4365818	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1130674	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	140	2977454	Engine problem
70	Titas 50 MW Peaking PP	PDB	8'8.92	52	49	549128	
71	Chandpur 150 MW CCGP	PDB	1'106+1'157	163	136	3265500	
72	Chandpur 200MW (Dash energy)	IPP	12'18.4	200	200	3492960	Machine problem
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	446004	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	248400	
**	Impoorti (Tripura)	Imported power	0	160	150	3211200	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	737800	
76	Jangalia 52 MW PP (Lakdorew)	IPP	8'8.92	52	0	0	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	458800	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	35904	Reserve.
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	0	Fuel shortage
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	94	1218840	Engine problem
81	Bhairab 45.5 MW	IPP	3'18.2	54	35	849600	33 kV feeder proble
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	98	2731200	Engine problem
Cumilla Area Total				2865	2178	4545462	
83	RPCL 210MW CCGP	IPP	4'35+1'70	202	129	3831380	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	426780	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	12950	
87	Mymensingh 200 MW PP (Unltd)	IPP	9'78'21	200	200	4248000	
88	Jamalpur 115 MW PP (Unltd)	IPP	9'78'12	115	108	1845800	
89	Sutakhal 50 MW Solar PP	IPP	50	0	0	328030	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	24	553680	
Mymensingh Area Total				614	481	11246400	
91	Fenchugonj CCGP Phase-1	PDB	2'32+1'33	70	43	1031000	Machine problem
92	Fenchugonj CCGP Phase-2	PDB	2'35+1'35	90	42	984944	Machine problem
93	Kushara 163 MW CCGP (KP)	IPP	1'109+1'54	163	110	2662773	ST Under maint.
94	Shahjibazar 330 MW CCGP	PDB	3'11.0	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	33	811200	Gas shortage
96	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	30	780984	Gas shortage
96	Hobiganj 11MW PP Colidence-E	SIPP, REB	4'2.90	11	11	251040	
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	31	730752	Engine problem
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	81	1902720	
99	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCGP	PDB	1'142+1'89	231	120	2861430	ST Under maint.
101	Sylhet. 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage
102	Sylhet 50MW PP (EPL)	NENP	27'2	50	25	576960	Engine problem
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	385248	Engine problem
103	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	280	7112500	FGMO
104	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	402	9379000	
105	Sylhet 10MW PP (Dash)	RPP	6'1.95	10	10	211860	
106	Bibiyana South 400 MW	PDB	400 MW	383	400	9383000	
Sylhet Area Total				2477	1634	39065411	
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500	1000	883	21698909	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	63	1805760	Engine problem
109	Fardpur 50 MW Peaking PP	PDB	8'6.89	54	39	199680	Engine problem
110	Khulna 225 MW CCGP	NWPGCL	1'150+1'175	230	0	0	Reserve.
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	11520	Reserve.
112	Bheramara 410 MW CCGP	NWPGCL	1'278+1'132	410	385	8744256	
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	40	217875	
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	25920	Reserve.
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	93	973920	Engine problem
115	Madhumati 100 MW PP	NWPGCL	6'18	105	0	0	Line O/L
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	549390	
Khulna Area Total				2384	1503	34227200	
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	16	110112	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	29	534162	Engine problem
119	Bhola 225 MW CCGP	PDB	2'63+1'68	194	85	1976145	Gas shortage
120	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BPCL	2'622	1244	600	113	