

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month July 2022				Day : Friday				Date : 01.07.22			
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 14025 MW				Rule Curve = 84.00 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.07 ft.				Today = 89.05 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.06.22 (Yesterday)		01.07.22 (Today)		30.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	0	0		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	64	71	71	73	37	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	236	330	330		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	392	312	412	412		
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	125	130	125	150	205	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	94	94	90	94		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	45	51	51	51		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	15	25	25		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	50	49	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105		
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	82	132	130	132		
23	Kamalganj 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	213	275	260	275		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	89	133	130	133		
26	Karaganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	202	203	200	300		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	85	85	85		
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	81	81	25	81		
29	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	17	55	55	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	93	94	90	104		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	162	162		
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	5	0	30	0		
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55		
35	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	92	100	100	100		
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	71	75	80	80		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total			6004	5847	3123	3399	3265	3457	682	765	
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	124	125	125	125		Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0			
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Soltartech)	Solar (IPP)	1x20	20	20	15	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	31	44	40	44		
44	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	195	288	265	300		
48	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	76	76	76		
49	Doahazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	52	0	60		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	28	10	25		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	73	92	80	92		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	108	110	110		
55	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	77	50	80		
56	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	20	20	20	20		
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	90	90	90	90		
Chattogram Zone Total			2442	2382	1074	1356	1197	1379	80	555	
58	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	0	0	0	0	0		Contract Expired
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	33	30	33	12	Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	160	209	215	215		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	300	300	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	300	300		
	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)				290	0	0	0		On Test
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	50	55	55	5	Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	8	8	8	187	Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	140	147	140	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	49	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	122	123	120	125		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	200	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	21	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.058	200	200	200	150	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	96	94	96		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	97	116	115	115		
**	Import (Tripura)	India		160	160	122	146	143	165		
Cumilla Zone Total			3059	2885	1669	2069	1991	2214	338	0	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	69	105	120	120	97	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	57	98	95	98		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	113	177	175	177		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutahati 50 MW Solar PP	Solar (IPP)	1x50	50	50	4	0	50	0		
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	14	22	22	22		
Mymensingh Zone Total			622	614	258	424	486	439	97	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.06.22 (Yesterday)		01.07.22 (Today)		30.06.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	44	44	44		26	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	33	22	22				
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110		53	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	63	64				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	120	120				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	310				
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	403	400				
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	24	6	25				
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	30	35	30				
Sylhet Zone Total					2522	2477	1682	1664	1692	1732	0	557
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	165	160	200		250	Gas Shortage	
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0		34		
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0		60		
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	223	222	120		220		
110	Nospara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	19	50	0		100		
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	93	93	93				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	11	105	70		105		
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	36	0	100		0		
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	48	20		48		
115	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	40	40		40		
**	Bheramara (HVDC)	India		1000	1000	876	860	930				
Khulna Zone Total					2388	2384	1447	1612	1573	1830	250	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	110	48	16		48		
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	29	20		29		
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	84	85		85		
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	550	622		622		
120	Potashkhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	35		35		
121	Bhola 220MW CCPP (Nutan Bidyt BC)	Gas/HSD (IPP)	2x75+1x70	220	220	164	224	220		220		
Barishal Zone Total					1958	1958	798	935	998	1039	0	0
122	a) Baghatbari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0		71	Gas Shortage	
	b) Baghatbari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0		100	Gas Shortage	
123	Baghatbari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0		34		
124	Baghatbari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	48	80	100		200		
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	27	0		35		
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0		90		
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	6	32	16		32		
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	25	8		25		
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0		37		
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	214	217	150		220		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	157	149	200		220		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	377	373	414		414		
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22		22		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11		11		
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0		0		
137	Bagura 113 MW PP (Confidence)	HFO (IPP)	6'18.55	113	113	113	113	113		113		
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	87	94	94		94		
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6		0		
Rajshahi Zone Total					2129	2129	1057	1304	1134	1547	381	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175		175	Coal Shortage	
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		15		
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	70	98	96		98		
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		10		
145	Majpara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8		0		
146	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6'20	115	115	90	90	90		90		
Rangpur Zone Total					800	720	340	363	369	388	184	85
Sub-total: Plants in operation					21924	21396	11448.0	13126	12705	14025	2012	1962
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					11011	12625	12219	13489				
(B) Plants under long term maintenance/contract expired												
147	Jamalganj 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0	Contract Expired	
148	Kalpatiti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0		0	Contract Expired	
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0	Forced Outage	
150	Karriganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0		0	Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0		0	Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0		0	Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					424	0	0	0		0		
Gross Total					22348	21396	11448	13126	12705	14025	2012	1962
(C) Actual data of 30.06.22 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	:	13126	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	12625	MW, at =	21:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	13126	MW, at =	21:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	10144	MW, at =	7:00 hrs		Dhaka	4656	4656	0	Mymensingh	995
05.	Day-peak Generation (Generation end)	:	11448	MW, at =	12:00 hrs		Chattogram	1324	1324	0	Sylhet	400
06.	Evening-peak Generation (Generation end)	:	13126	MW, at =	21:00 hrs		Rajshahi	1579	1579	0	Barishal	374
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs		Khulna	1321	1321	0	Rangpur	829
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10047	MW, at =	5:00 hrs		Cumilla	1146	1146	0		
09.	Generation shortfall at evening peak due to :	:										
	a) Gas limitation	:	1828	MW								
	d) Coal supply Limitation	:	184	MW								
	b) Low water level in Kapali lake	:	0	MW								
	c) Plants under shut down/ maintenance	:	1962	MW								
10.	Total Energy (Generation + India Import)	:	372.96	MKWh								
	By Gas =	135.287	MKWh	By Oil =	192.288	MKWh						
	By Coal =	17.377	MKWh	By Hydro =	2.950	MKWh						
	By Solar=	0.638	MKWh									
11.	Total Gas Supplied	:	1021.03	MMCFD								
(D) Forecast of 01.07.22 (Today) Friday :												
01.	Maximum Demand	:	13000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14025	MW	(Generation end)	05.	Total Generation	:	369.38	MKWh		
03.	Reserve / Shortage	:	1025	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.1° C			

* Captive Power; ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation