

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month July 2022				Day : Sunday				Date : 03.07.22					
Probable Maximum Demand : 14250 MW				Probable Maximum Generation : 13440 MW				Rule Curve = 84.32 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.05 ft.				Today = 89.05 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.07.22 (Yesterday)		03.07.22 (Today)		02.07.22 (Yesterday)		03.07.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0	260			Under project work	
	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	180			Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	280	280	280				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	63	73	73	73	35			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	203	200	185	185				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	225	210	210				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	299	313	290	290				
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	94	94	94	94				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	51	51	51	51				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	22	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	49	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	90	105	105				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	115	145	150	150				
23	Kamalganj 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	243	275	285	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	118	138	149	149				
26	Karaganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	302	303	300	300				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	85	83	85	85				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	76	83	80	85				
29	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	35	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	144	72	162				
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	36	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	19	55	55				
35	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	100	99	100	100				
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	77	76	80	87				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2851	3297	3267	3379	810	765		
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	126	122	122	122			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	90	90	90	90		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0					
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	44	38	44				
44	Sikalbaha 105 MW PP (Baraka Sikalb	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	178	300	265	300				
48	Julda 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	76	76	76				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	42	0	45				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	27	10	25				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	84	87	94	94				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	35	54				
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	84	110	110	110				
55	Julda unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	73	50	80				
56	Julda 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	20	20	20	20				
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	90	90	90	90				
Chattogram Zone Total				2442	2382	1043	1319	1177	1353	90	555		
58	a) Ashuganj TPP Unit-4	Gas (APSCCL)	1 x 150	150	0	0	0	0	0			Contract Expired	
	b) Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	8	29	8	8	16		Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	202	205	130	130				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	300	300	300				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	310	330	330				
	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)				276	0	0	0			On Test	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	5	54	5	5				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	185	8	8				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	44	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	137	143	140	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	48	33	50	50				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	85	84	85	85				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	200	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	21	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	15	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.315+15x1.058	200	200	200	200	200	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	0	0	0				
77	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	28	94	28	55				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	116	116	115	115				
**	Import (Tripura)	India		160	160	88	124	143	165				
Cumilla Zone Total				3059	2885	1681	1931	1913	1973	150	0		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	105	104	80	80	98		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	20	20				
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	58	98	60	98				
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	115	176	175	177				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutahali 50 MW Solar Plant	Solar (IPP)	1x50	50	50	43	0	50	0				
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22				
Mymensingh Zone Total				622	614	365	419	409	397	98	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.07.22 (Yesterday)		03.07.22 (Today)		02.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32-1x33	97	70	44	44	44		26	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35-1x35	104	90	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	19	5	5				
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110		53	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	61	30				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	86				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	120	120				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	300	310		341		
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	399	401	400				
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	6				
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	35	25	25				
Sylhet Zone Total					2522	2477	1657	1645	1623	1654	0	557
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	175	170	160		240	Gas Shortage	
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	30		37		
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	50	50		60		
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	201	206	220		220		
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	100	99	100		100		
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	75	92	94		94		
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105		105		
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	79	0	100		0		
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	49	16		49		
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	40		40		
**	Bheramara (HVDC) India			1000	1000	873	853	930		930		
Khulna Zone Total					2388	2384	1632	1697	1845	1795	240	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	32		48		
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	29	20		29		
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	86	85		85		
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	480	620	622		622		
120	Potlakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	35		35		
121	Bhola 220MW CCPP (Nutan Bidyt BC)	Gas/HSD (IPP)	2x75+1x70	220	220	219	223	220		220		
Barisal Zone Total					1958	1958	800	1041	1014	1039	0	0
122	a) Baghatbari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0		71	Gas Shortage	
	b) Baghatbari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0		100	Gas Shortage	
123	Baghatbari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0		34		
124	Baghatbari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	171	110	150		200		
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	29	0		35		
126	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	90	0		90		
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16		32		
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	43		43		
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0		37		
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	210	213	220		220		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	159	150	145		145		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	404	390	360		360		
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	21	22		22		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11		11		
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0		0		
137	Bagura 113 MW PP (Confidence)	HFO (IPP)	6*18.55	113	113	113	113	113		113		
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	94		113		
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6		0		
Rajshahi Zone Total					2129	2129	1218	1377	1180	1455	381	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	175	175	175		175	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	15	0		15		
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	96	70		98		
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		10		
145	Majpara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8		0		
146	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	90	95	90		97		
Rangpur Zone Total					800	720	335	381	343	395	184	85
Sub-total: Plants in operation					21924	21396	11582.0	13107	12771	13440	1953	1962
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							11258	12241	12414	13064		
(B) Plants under long term maintenance/contract expired												
147	Jamapir 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0	Contract Expired	
148	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0		0	Contract Expired	
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0	Forced Outage	
150	Karriganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0		0	Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0		0	Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0		0	Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/contract expired					424	0	0	0	0	0		
Gross Total					22348	21396	11582	13107	12771	13440	1953	1962
(C) Actual data of 02.07.22 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)				13107	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :				
02.	Max. Demand at eve. peak (Sub-station end)				12741	MW, at = 21:00 hrs		Demand	Supply	Load Shed	Zone	Demand
03.	Highest Generation (Generation end)				13107	MW, at = 21:00 hrs		MW	MW	MW		MW
04.	Minimum Generation (Generation end)				10359	MW, at = 8:00 hrs		Dhaka	4713	4573	140	Mymensingh
05.	Day-peak Generation (Generation end)				11582	MW, at = 12:00 hrs		Chattoagram	1283	1243	40	Sylhet
06.	Evening-peak Generation (Generation end)				13107	MW, at = 21:00 hrs		Khulna	1578	1528	50	Barishal
07.	Evening Peak Load-shed (Sub-station end)				500	MW, at = 21:00 hrs		Rajshahi	1304	1244	60	Rangpur
08.	Minimum Generation Forecast up to 8:00 hrs.				11004	MW, at = 5:00 hrs		Cumilla	1183	1133	50	
09.	Generation shortfall at evening peak due to :											
	a) Gas limitation				1769	MW		13.	Fuel cost :	(a) Gas = 141831718 Taka	(c) Coal = 146563112 Taka	
	d) Coal supply Limitation				184	MW			(b) Oil = 1633248679 Taka	Total = 1921643510 Taka		
	b) Low water level in Kaplai lake				0	MW						
	c) Plants under shut down/ maintenance				1962	MW						
10.	Total Energy (Generation + India Import)				283.17	MKWh		14.	Maximum Temperature in Dhaka was : 34.3° C			
	By Gas =	125.684	MKWh	By Oil =	111.499	MKWh		15.	Export through East-West interconnections :			
	By Coal =	18.033	MKWh	By Hydro =	3.033	MKWh			At evening peak-hour		11582	MW, at 21:00 hrs
	By Solar=	1.266	MKWh						Maximum		202	MW, at 22:00 hrs
11.	Total Gas Supplied				983.72	MMCFD			Energy		0.132	MKWh
(D) Forecast of 03.07.22 (Today) Sunday :												
01.	Maximum Demand				14250	MW (Generation end)	04.	Maximum Load-shed : 551.18737 MW At evening peak (Sub-station end)				
02.	Maximum Generation				13440	MW (Generation end)	05.	Total Generation : 307.86 MKWh				
03.	Reserve / Shortage				-810	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 33.7° C				

* Captive Power; ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation