| | | | | POWER GRID COMPANY NATIONAL LOAD D | ESPATCH CENTER | D . | | | | | | QF-LDC-0 |
|---|---|--|---|---------------------------------------|---------------------------|------------|---------------------|--------------------------------------|-------------------|-------------|----------------------------------|----------------|
| | | | | DAILY R | EPORI | | | | Reporting | Date: | 7-Jul-22 | Page -1 |
| Till now the maximu | um generation is : - | | 14782.0 | | | | 21:00 | Hrs on | 16-Apr-22 | , Dato . | , our LL | |
| The Summary of Ye | sterday's | 6-Jul-22 | Generation & Demand | | | | | Today's Actual M | in Gen. & Pro | | . & Demand | |
| Day Peak Generation | . : | 11838.0 | | Hour: | 12:00 | | | Min. Gen. at | 8:00 |) | | 3 MW |
| Evening Peak Generati E.P. Demand (at gen e | | 13614.0 13864.0 | MVV | Hour : Hour : | 21:00 21:00 | | | Available Max Gen Max Demand (Eve | | : | | '5 MW 00 MW |
| Maximum Generation | inu). | 13614.0 | | Hour: | 21:00 | | | Reserve(Generatio | | | | '5 MW |
| Total Gen. (MKWH) | | 296.5 | | System L | oad Factor : 90.73 | | | Load Shed | : | | | 0 MW |
| | | | EXPORT / IMPORT T | HROUGH EAST-WEST INTER | CONNECTOR | | | | | | | |
| Export from East grid to | | | | | 248 MW | at | | 7:00 | | Energy | | MKWHR. |
| Import from West grid t | to East grid :- Maximu | ım | - | | MW | at | | - | | Energy | | - MKWHR. |
| ater Level of Kaptai Lake Actual : | | (MSL), | 7-Jul-22 | | Rule curve : | 84.96 | ie. | Ft.(MSL) | | | | |
| Actual . | 09.00 FL | (IVISL), | | | Rule curve . | 04.90 | 10 | FL(INISL) | | | | |
| Gas Consumed : | Total = | 1020.30 | MMCFD. | | Oil Co | nsumed | (PDB): | | | | | |
| | | | | | | | | | HSD : | | | Liter |
| | | | | | | | | | FO : | | | Liter |
| Cost of the Consumed | Fuel (DDD LD:4) | Gas : | | Tk151,472,806 | | | | | | | | |
| | ruei (PDB+PVI) | Coal : | | Tk151,472,606 Tk158,750,695 | | | Oil : | Tk1,626,409,608 | | Total · Tk | 1,936,633,110 |) |
| | | Jour . | | 11(100,100,000 | | | · | 111,020,100,000 | | rotar . rit | 1,000,000,111 | , |
| | Loa | d Shedding & O | her Information | | | | | | | | | |
| | | | | | | | | | | | | |
| Area | Yesterday | | | -tht1 B 1 (8 /8 / | | | | Today | - (0/0 | | | d |
| | MW | | E | stimated Demand (S/S end) MW | | | | Estimated Sheddin | g (S/S end) MW | | ates of Shedd | |
| Dhaka | 0 | 0:00 | | MW 4937 | | | | | MW | (Or | n Estimated D 0% | emanu) |
| Chittagong Area | 0 | 0:00 | | 1331 | | | | | 0 | | 0% | |
| Khulna Area | 42 | 0:00 | | 1743 | | | | | 0 | | 0% | |
| Rajshahi Area | 56 | 0:00 | | 1562 | | | | | 0 | | 0% | |
| Cumilla Area | 18 | 0:00 | | 1383 | | | | | 0 | | 0% | |
| Mymensingh Area | 86 | 0:00 | | 1017 | | | | | 0 | | 0% | |
| Sylhet Area | 0 | 0:00 | | 564 | | | | | 0 | | 0% | |
| Barisal Area | 0 48 | 0:00 | | 369 779 | | | | | 0 | | 0% 0% | |
| Rangpur Area Total | 250 | 0:00 | | 13685 | | | | | 0 | | 0% | |
| Total | 230 | | | 13000 | | | | | | | | |
| | Information of the | Generating Units | under shut down. | | | | | | | | | |
| | | | | | | | | | | | | |
| P | Planned Shut- Down | | | | | d Shut- | Down ST: Unit-1, | | | | | |
| | | | | | 5) Ra 6) Sid 7) Sik | ozan unit- | 210 MW . 25 MW | | | | | |
| | | | nes, Interruption / Forced | | | | | | | | | |
| | | tripped at 08:46 f | rom 33 kV end due to Path | orghata-2 feeder | | | | | | | terruption occ | |
| c) Haripur S/S-Haripur- d) Mirsharai 230/132 k\ e) BSRM-Mirsharai EZ | nat 230 kV Ckt-1 was -412 MW 132 kV Ckt V T-1 transformer was 230 kV Ckt was unde | was under shut do s under shut down er shut down from | from 09:36 to 13:32 for C/N own from 10:13 to 13:44 for from 10:10 to 1714 for D/N 10:27 to 17:03 for D/W. | · C/M. V. | | | | | | | 08:46 to 08:56 | |
| dist.Z1 at Aminbazar g) Bogura confidence F and was switched on h) HVDC pole-2 tripped i) Niamatpur 132/33 kV | end and was switcher P/S-Mithapukur 132 k n at 12:27. d at 15:22 due to auxil / T-3 transformer was | d on at 12:43. V Ckt-1 was shut liary problem and v under shut down | nd showing directional E/F down at 11:09 due to red h was switched on at 15:58. from 13:43 to 18:50 for ma | ot maintenance | | | | | | | terruption occ a from 11:52 | |
| 33 kV Chutipur feede I) Agargaon 230/132 kV m) Patuakhali 132/33 k | T-2 transformer was er and was switched o V T-2 transformer is u kV T-2 transformer is u | shut down at 06:4 in at 09:05(7/7/22) nder shut down si under shut down s | 4(7/7/22) due to red hot ma | | | | | | | | terruption occ n 06:44 to 09: | |
| | Divisional Engineer | | | | Fvs | cutive F | Engineer | | | Sun | erintendent | Engineer |
| Sub D | | | | | | | ation Divis | | | | ad Despatc | |