

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		6-Jul-22		Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	180	4378500	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	300	7157218	Machine problem
4	Ghorashal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	88	1983227	Engine problem
5	Haripur GTPP	SBU_PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Gas shortage
7	Haripur 368MW CCPP(HPL)	IPP	1*235+1*125	360	202	4274000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	210	4210450	Gas shortage
9	Meghnaghat 100 MW(ILEL)	NENP	12*8.9	100	31	736320	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	1310027	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
14	Narsingthi 22 MW PP (Doreen)	SIPP_REB	8*2.90	22	22	454572	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*8.9	100	40	967680	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	224	5415875	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	94	2128176	Engine problem
20	Katpoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
21	Kamalgahat 54 MW PP(Banco Energy)	IPP	3*18	54	54	1213200	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	132	2854080	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1329668	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	946990	
25	Bosila 108MW PP(CLLC)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power (Madhabdi-Ashulia)	SIPP_REB	3*3.67+4*9.73	80	53	1237200	Engine problem
27	Maona 33 MW PP(Summit)	SIPP_REB	4*8.73	33	33	805900	
28	Rupganj 33 MW PP(Summit)	SIPP_REB	4*8.73	33	28	651900	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	51	974400	#REF!
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	248	6051925	Engine problem
32	Keraniganj 300 MW PP (APRI)	IPP	256*1.4	300	303	3951226	
33	Bramhangaoon 100 MW PP (Aggreko)	IPP	114*0.959	100	0	0	Fuel shortage
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	1502416	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	131	2832190	Engine problem
36	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2468400	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	2510400	
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	162	3875040	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	217897	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	55	1338120	
Dhaka area Total				5847	3115	67776797	
41	Chattogram TPP-1	PDB	1*210	180	100	2400000	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3*8.9	25	25	556860	
43	Teknaf 20MW PP (Solartech)	IPP	20	20	0	76680	
44	Patenaga 50MW PP (Baraka)	IPP	8*6.98	50	42	998480	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	124	2917930	Low water level
46	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	2294145	
49	Hathazari 100 MW peaking PP	PDB	11*8.9	98	51	504480	Engine problem
50	Ohazhari-Kalash 100 MW Peaking	PDB	6*17	102	51	658561	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	55	1224600	Fuel shortage
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	90	2036160	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP_PDB	8*2.90	22	21	450336	
*	Malancha, Clg. EP2 (United)		5*8.73+3*9.34	0	22	385920	
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	86	1872840	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29279	
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	290	4641818	Engine problem
57	Jodica Power	IPP	3*18.55+1*3.6	54	54	1366128	
58	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	110	2489010	
59	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	2302080	
60	Anlima Energy Ltd.	IPP	6*21.2	116	108	2456400	Engine problem
Chattogram area Total				2382	1434	29659707	
61	Ashuganj TPP Unit-3	APSCL	1*150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCL	1*150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	209	4714000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	325	7561800	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	315	7865900	Gas shortage
65	Ashuganj 420 MW CCPP(East)	APSCL	284*1+136*1	0	0	1522900	On test.
66	Ashuganj 50 MW PP	APSCL	14*3.968	45	39	819504	Engine problem
66	Ashuganj 55 MW PP (Precision)	QRPP	15*4	55	52	1066560	
67	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	1137454	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1227807	
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	137	3233381	Engine problem
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	40	662976	Engine problem
71	Chandpur 150 MW CCPP	PDB	1*106+1*157	163	84	1925920	Gas shortage
72	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	200	2962560	
73	Feni 22MW PP (Doreen)	SIPP_PDB	8*2.90	22	21	379908	
74	Feni 11 MW PP (Doreen)	SIPP_REB	4*2.90	11	11	250200	
**	Impoport (Tripura)	Imported power	0	160	164	3607680	
75	Jangalia 33MW PP (Summit)	SIPP_PDB	4*8.73	33	16	299500	Engine problem
76	Bangalia 22 MW PP (Kandrawa)	IPP	6*8.92	52	25	160698	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP_REB	3*3.67+2*6.97	25	20	424160	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	195	2587008	
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	507300	
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	9	230160	Fuel shortage
81	Bhairab 54.5 MW	IPP	3*18.2	54	35	551160	33 kV feeder problem.
82	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	116	2773440	
Cumilla Area Total				2885	2186	46502246	
83	RPCL 210MW CCPP	IPP	4*35+1*70	202	104	2129280	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP_PDB	8*2.90	22	14	342864	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8600	
87	Mymensingh 200 MW PP (United)	IPP	9*8*21	200	200	3156000	
88	Jamalpur 115 MW PP (United)	IPP	9*7*12	115	115	1755600	
89	Sutiahali 50 MW Solar PP	IPP	50	50	0	185200	
90	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	594240	
Mymensingh Area Total				614	457	8171784	
91	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	886000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	988296	Machine problem
93	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	110	2478355	ST Under maint.
94	Shahjibazar 330 MW CCPP	PDB	3*110	0	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	0	91200	Gas shortage
96	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5*2	50	0	99144	Gas shortage
96	Hobiganj 11MW PP Confidence-E	SIPP_REB	4*2.90	11	11	240000	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	63	1392096	
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	86	2016960	
99	Shahjibazar 100 MW GTTP	PDB	0	1*100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	140	3293450	ST Under maint.
101	Sylhet 20 MW GTTP	PDB	1*20	20	0	0	Gas shortage
102	Sylhet 50MW PP (EPL)	NENP	27*2	50	0	140400	Engine problem
102	Shahjahanulla 25 MW PP	SIPP_REB	3*9.34	25	16	388202	
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	280	7088500	FGMO
104	Bibiyana-III 400 MW CCPP	IPP	400 MW	400	409	9534000	
105	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	221940	
106	Bibiyana South 400 MW	PDB	400 MW	383	400	9458100	
Sylhet Area Total				2477	1610	38316643	
107	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	840	20883636	
108	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	49	538560	Fuel shortage
109	Fairidpur 50 MW Peaking PP	PDB	6*8.89	54	35	360000	Engine problem
110	Khulna 225 MW CCPP	NWPQCL	1*150+1*75	230	205	4701120	Engine problem
111	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	60	486272	Engine problem
112	Bheramara 410 MW CCPP	NWPQCL	1*278+1*132	410	250	6020640	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	40	260625	
113	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	98	1101120	
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	74	1948800	Engine problem
115	Madhumati 100 MW PP	NWPQCL	6*18	105	100	2490768	
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	309800	
Khulna 330 MW CCPP (OIL)				1*220+1*110	0	0	On test.
Khulna Area Total				2384	1751	39101141	
117	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	48	742842	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	32	593090	Engine problem
119	Bhola 225 MW CCPP	PDB	2*63+1*58	194	87	1707116	Gas shortage
120	Bh						