

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022				Day : Friday				Date : 08.07.22					
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 14002 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.68 ft		Today = 89.87 ft		Rule Curve = 85.12 ft					
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.07.22 (Yesterday)		08.07.22 (Today)		07.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
													Day
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	89	90	90				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	192	282	330	330	78		Gas Shortage	
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	225	225	225	225		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage	
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105	Gas Shortage	
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	192	317	330	320				
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	94	94	94				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+4x7.3	80	80	51	52	51	53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	30	25	30				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	49	40	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	132	130	132				
23	Kamaaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	229	248	285	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	114	139	130	149				
26	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	167	302	200	300				
27	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	100	0	50				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	96	0	100				
29	Nabaganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	55	55	55	55				
30	Manikganj 55 MW PP (Northern	HFO (IPP)	3x19.3	55	55	55	55	17	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	91	104	104	104				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	17	72				
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	33	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	37	55	55	55				
35	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	8	8	100	100				
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	31	31	32	32				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2784	3359	3052	3373	1155	765		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	125	118	125	125			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	44	45	45				
44	Sikalbaha 105 MW PP (Baraka Sikabha	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	174	261	200	300				
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	49	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	50	40	42				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	36	30	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	78	85	85	86				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	36	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	110	110	110				
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	92	90	75	75				
56	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	55	55	55	55				
57	Chattogram 116 MW PP (Anilma Enen	HFO (IPP)	6x21.06	116	116	90	108	108	108				
Chattogram Zone Total				2442	2382	1145	1401	1326	1422	80	555		
58	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	0	0	0	0	0			Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	35	35	35				
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	204	205	210	210				
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	335	340	330	330				
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	335	345	320	330				
	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)				0	0	0	0	300		Gas Shortage	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	48	50	50				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	92	92	8	8	103		Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	142	145	145				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	47	40	47				
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	84	84	85	85				
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	30	20	20				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	34	8	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	20	20				
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	29x1.4+40x1.015+15x1.036	200	200	196	195	100	200				
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114				
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	10	9	9	9				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	95	95	36	70				
**	Import (Tripura)	India		160	160	160	164	143	165				
Cumilla Zone Total				3059	2885	2000	2315	1895	2200	537	0		
80	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	70	102	170	190	100		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	20	20				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	115	59	115				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	112	175	115	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutikdahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0				
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	7	22	22				
Mymensinga Zone Total				622	614	315	419	438	547	100	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.07.22 (Yesterday)		08.07.22 (Today)		07.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
												Day	Evening	Day
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	33	33	32	32		37	GT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (IPP)	19x2.90	51	51	0	0	0	0					
90	Kushiana 163 MW CCPP (KP)	Gas (RPP)	1x109+1x54	163	163	75	75	110	110		88	ST under maint.		
91	Hobigang 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	50	60	64					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	45	86	65	65					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	20	150					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	0	10	10					
98	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	0	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	310	341					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	404	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	394	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage		
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50		Gas Shortage		
Sylhet Zone Total						2522	2477	1508	1525	1476	1641	100	603	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	285	280	280	260	130		Gas Shortage		
107	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	35	35	35					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	66	0	60					
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	202	203	220	220					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	97	92	90	100					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	75	75	74	93					
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	88	89	105	105					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	62	0	100	0					
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	48	16	49					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	8	8	8					
**	Bheramara (HVDC)	India		1000	1000	862	483	501	501					
Khulna Zone Total						2388	2384	1695	1379	1429	1431	130	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	110					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	30	20	32					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	86	85	85	108		Gas Shortage		
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	600	622	622					
120	Potuaakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	90					
121	Bhola 220MW CCPP (Nutan Bidyut BE)	Gas/HSD (IPP)	2x75+1x70	220	220	225	220	220	220					
Barishal Zone Total						1958	1958	833	1022	996	1159	108	0	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	24	34					
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	174	155	170	180					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	16	30					
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	88	85	86					
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	16	32					
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	37					
130	Siragongj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	175	188	200	200					
131	Siragongj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	213	213	220	220	220		Running on HSD		
132	Siragongj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	176	184	180	180					
133	Siragongj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	52	8	52					
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113					
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	94	94					
139	Siragongj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total						2129	2129	1518	1713	1613	1739	391	0	
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overheating		
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250					
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	15	15	15					
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	68	102	70	102					
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	8	0	10					
145	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	108	111	113	113					
Rangpur Zone Total						800	720	433	486	456	490	85	85	
Sub-total: Plants in operation						21924	21396	12231.0	13619	12681	14002	2686	2008	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						11703	13031	12133	13398					
(B) Plants under long term maintenance/ contract expired														
147	Jamalgur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired		
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired		
149	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired		
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0				
Gross Total						22348	21396	12231	13619	12681	14002	2686	2008	
(C) Actual data of 07.07.22 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	13619	MW.	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13031	MW.	at =	21:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13619	MW.	at =	21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	11043	MW.	at =	8:00 hrs	Dhaka	4264	4264	0	Mymensingh	1062	1062	0
05.	Day-peak Generation (Generation end)	:	12231	MW.	at =	12:00 hrs	Chattogram	1291	1291	0	Sylhet	538	538	0
06.	Evening-peak Generation (Generation end)	:	13619	MW.	at =	21:00 hrs	Khulna	1736	1736	0	Barishal	397	397	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW.	at =	21:00 hrs	Rajshahi	1519	1519	0	Rangpur	921	921	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10034	MW.	at =	5:00 hrs	Cumilla	1303	1303	0				
09.	Generation shortfall at evening peak due to :	:									Total	13031	13031	0
a)	Gas limitation	:	2601	MW			13.	Fuel cost :	(a) Gas = 154676051	Taka	(c) Coal = 160855613	Taka		
d)	Coal supply Limitation	:	85	MW				(b) Oil = 1648495003	Taka	Total = 1964026667	Taka			
b)	Low water level in Kaptai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2008	MW			14.	Maximum Temperature in Dhaka was : 34.7° C						
10.	Total Energy (Generation + India Import)	:	296.91	MKWh			15.	Export through East-West interconnections :						
	By Gas = 136.937			MKWh	By Oil = 113.612			At evening peak-hour	:	12231	MW.	at 21:00 hrs		
	By Coal = 20.357			MKWh	By Hydro = 2.784			Maximum	:	248	MW.	at 7:00 hrs		
	By Solar= 1.503			MKWh				Energy	:	0	MKWh			
11.	Total Gas Supplied	:	1051.45	MMCFD										
(D) Forecast of 08.07.22 (Today) Friday :														
01.	Maximum Demand	:	12500	MW	(Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	14002	MW	(Generation end)		05.	Total Generation : 272.52 MKWh						
03.	Reserve / Shortage	:	1502	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka : 35.1° C						