

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022				Day : Saturday				Date : 09.07.22				
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 14230 MW				Rule Curve = 85.28 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.87 ft.				Today = 90.15 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.07.22 (Yesterday)		09.07.22 (Today)		08.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0	260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	180		Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	300	310			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	92	90	92			
5	Tongi 80 MW GTTP	Gas (PDB)	1x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	337	330	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	105	105	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	336	330	335			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagannagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	94	94	94	94			
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	22	22			
17	Summit Power, (Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x4.73	80	80	42	44	51	53			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	30			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	49	40	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	105	105			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	115	130	132			
23	Kamalgat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	210	212	285	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	24	133	130	133			
26	Keranganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	105	200	300			
27	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	0	100			
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	17	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	17	72			
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	36	55	55	55			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	91	92	100	100			
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	60	87	85	87			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	2408	3037	3105	3469	1077	765	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	122	124	125	125		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0			
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	44	44			
44	Sikalbaha 105 MW PP (Baraka Sikabha)	HFO (IPP)	6x18.415	105	105	17	87	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	262	200	265			
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	76	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	51	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	51	50	51			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			30	42	30	40			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	19	79	80	80			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	36	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	65	95	75	95			
56	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	55	55	55	55			
57	Chattogram 116 MW PP (Anilma Enema)	HFO (IPP)	6x21.06	116	116	72	108	108	108			
Chattogram Zone Total				2442	2382	815	1381	1330	1419	80	555	
58	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	0	0	0	0	0		Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	32	36	35	36			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	183	208	210	210			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	275	325	320	325			
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	275	325	320	325			
	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)			217	0	0	0	0	300	Gas Shortage	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	50	52	50	52			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'16	195	195	8	8	8	8	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	107	137	135	137			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	40	50			
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	84	84	84	84			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	20	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	39	8	40			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+40x1.015+15x1.036	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	98	17	98			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	48	40	48			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	72	36	72			
**	Import (Tripura)	India		160	160	126	154	143	165			
Cumilla Zone Total				3059	2885	1765	2003	1918	2222	621	0	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	206	186	170	190	16	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	20	22			
82	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	115	60	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	114	188	115	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutikdahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	20	0	50	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total				622	614	447	535	439	549	16	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.07.22 (Yesterday)		09.07.22 (Today)		08.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	33	33	32	33		37	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	0	0	0				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		53	ST under maint.	
91	Hobigangj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	56	60	64				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	65	86	80	86				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	140	130	140				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10		50	Gas Shortage	
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	310	341				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	400	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	24	0	0	0	50		Gas Shortage	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	45	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1501	1586	1593	1645	100	568
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	315	380	300	410	30		Gas Shortage	
107	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	35	35	35				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	35	0	60				
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	203	220	220				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	90	100				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	50	55				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	89	105	105				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	76	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	41	16	49				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	8	8	8				
**	Bheramara (HVDC)	India		1000	1000	489	492	501	501				
Khulna Zone Total						2388	2384	1074	1336	1425	1543	30	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	32	20	32				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	87	85	87	107		Gas Shortage	
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	622	622	622				
120	Potuaakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	90				
121	Bhola 220MW CCPP (Nutan Bidyut BE)	Gas/HSD (IPP)	2x75+1x70	220	220	221	221	220	220				
Barishal Zone Total						1958	1958	728	994	996	1161	107	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	24	34				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	170	180				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	32	16	32				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	85	88				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	36				
130	Siragongj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	180	214	200	214				
131	Siragongj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	140	220	220	220		Running on HSD	
132	Siragongj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	168	211	180	211				
133	Siragongj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	392	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	70	113	113	113				
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	94	94	94				
139	Siragongj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2129	2129	1003	1505	1613	1787	391	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overheating	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	200	200	200				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	15	15				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	69	97	70	97				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
145	Majpara, Tatala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	72	111	113	113				
Rangpur Zone Total						800	720	398	408	406	435	85	85
Sub-total: Plants in operation						21924	21396	10139.0	12785	12825	14230	2507	1973
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9646	12164	12201	13538				
(B) Plants under long term maintenance/ contract expired													
147	Jamalgur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
149	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22348	21396	10139	12785	12825	14230	2507	1973
(C) Actual data of 08.07.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	12785	MW.	at =	21:00 hrs							
02.	Max. Demand at eve. peak (Sub-station end)	:	12164	MW.	at =	21:00 hrs							
03.	Highest Generation (Generation end)	:	13071	MW.	at =	1:00 hrs							
04.	Minimum Generation (Generation end)	:	9692	MW.	at =	9:00 hrs							
05.	Day-peak Generation (Generation end)	:	10139	MW.	at =	12:00 hrs	Dhaka	3618	3618	0	Mymensingh	1152	1152
06.	Evening-peak Generation (Generation end)	:	12785	MW.	at =	21:00 hrs	Chattogram	1201	1201	0	Sylhet	534	534
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW.	at =	21:00 hrs	Khulna	1651	1651	0	Barishal	388	388
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9066	MW.	at =	5:00 hrs	Rajshahi	1451	1451	0	Rangpur	911	911
09.	Generation shortfall at evening peak due to :	:					Cumilla	1258	1258	0			
a)	Gas limitation	:	2422	MW									
d)	Coal supply Limitation	:	85	MW									
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	1973	MW									
10.	Total Energy (Generation + India Import)	:	272.96	MKWh									
	By Gas =	145.465	MKWh	By Oil =	89.347	MKWh							
	By Coal =	18.892	MKWh	By Hydro =	2.892	MKWh							
	By Solar =	1.269	MKWh										
11.	Total Gas Supplied	:	1096.25	MMCFD									
(D) Forecast of 09.07.22 (Today) Saturday :													
01.	Maximum Demand	:	12500	MW	(Generation end)								
02.	Maximum Generation	:	14230	MW	(Generation end)								
03.	Reserve / Shortage	:	1730	MW	(Generation end)								
04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)								
05.	Total Generation	:	261.03	MKWh									
06.	Probable Max. Temperature in Dhaka :	:	35.7° C										
(E) Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	3618	3618	0	Mymensingh	1152	115						