

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022				Day : Thursday				Date : 14.07.22							
Probable Maximum Demand : 12800 MW				Probable Maximum Generation : 15416 MW											
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 90.86 ft Today = 91.07 ft				Rule Curve = 86.08 ft							
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.07.22 (Yesterday)		14.07.22 (Today)		13.07.22 (Yesterday)		14.07.22 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
	Day	Evening				Day	Evening								
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	100	100						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	300	300						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	92	90	92						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	332	330	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	404	412	412						
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	185	185	190	190						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	325	328	335	335						
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	94	94	94						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	15	22	22						
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+7x8.73	80	80	35	41	39	40						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	27	33	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	50	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105						
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	140	140	145						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	258	285	285						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	52	149	130	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	200	300						
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100						
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100						
29	Nababganj 55 MW PP (Southern pow)	HFO (IPP)	3x19.3	55	55	0	35	55	55						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	0	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104						
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	108	18	35						
33	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	35	0	30	0						
34	Kanchan Purbachal Power Generator	HFO (IPP)	3x19.404	55	55	55	55	55	55						
35	Siddhirganj 100 MW PP(Dutch Bangle	HFO (NENP)	12x8.9	100	100	48	91	90	95						
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	71	69	70	70						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0						
Dhaka Zone Total				6004	5847	3083	3759	3869	4243	335	660				
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	79	126	120	120			Unit 1 under rehabilitation			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	95	100	100	100	80		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	25	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	36	45	45	45						
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	0	68	105	105						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Awaiting for HGPI			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	16	200	265						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	75	90	90	90						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	60	0	60						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			40	42	40	40						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	78	70	92						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	45	54	54	54						
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100						
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	40	50	65	65						
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	90	108	108						
Chattogram Zone Total				2442	2382	750	1126	1278	1451	80	555				
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	0	0	0	0	0			Contract Expired			
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	32	33	33	33						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	0	0	0	0		221	Under maint.			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	330	0	330	320						
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	65	330	330	330						
	Ashuganj 420 MW CCPP(East)	Gas (APSCL)				0	0	0	0	300		Gas Shortage			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	48	51	51						
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+11'6	195	195	158	182	180	180	13		Gas Shortage			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	68	118	132	135						
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	40	50						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	135	136	136						
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	108	200	200	200						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11						
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20						
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.516+15x1.188	200	200	0	0	100	200						
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	46	17	114						
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	104	9	113						
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	21	35	35						
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	59	36	72						
**	Impoport (Tripura)	India		160	160	70	80	60	78						
Cumilla Zone Total				3059	2885	1255	1582	1834	2227	447	221				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	196	198	200	200						
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22						
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	106	60	105						
83	Myemensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	110	164	115	170						
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
85	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0						
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	22	24	22	22						
Myemensingh Zone Total				622	614	454	512	471	519	0	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.07.22 (Yesterday)		14.07.22 (Today)		13.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	43	43		26	GT-1 Under maint.				
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.				
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	34	37	51	51							
90	Kushiar 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	80	80		83	ST under maint.				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11							
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	61	60	62							
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81							
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	120	20	120							
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas shortage				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10							
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	24	24							
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0							
100	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	274	280	280	280							
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	255	260	50	400							
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	27	0	25	25	50		Gas Shortage				
104	Fenchugan 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	35	40	44	44	10		Gas Shortage				
Sylhet Zone Total						2522	2477	1103	1074	821	1273	80	587			
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	380	395	380	400	15		Gas Shortage				
107	Faridpur 50 MW Peaking PP	HFO (PDB)	6x6.98	54	54	0	0	0	42							
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60							
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	220	220							
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100							
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	65	90	90							
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	105	105							
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	107	0	100	0							
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	16	49							
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8							
**	Bheramara (HVDC)	India		1000	1000	487	486	776	867							
Khulna Zone Total						2388	2384	974	1053	1737	1941	15	0			
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	64	110							
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	32	21	31							
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	20	85	129		Gas Shortage				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	830	670	1100	1100							
120	Potuzkhalii 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	17	35							
121	Bhola 220MW CCPP (Nutan Bidyut BI)	Gas/HSD (IPP)	2x75+1x70	220	220	220	221	220	220							
Barishal Zone Total						1958	1958	1153	1055	1442	1581	129	0			
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
b) Baghabari 100 MW GTTP	Gas (PDB)		1 x 100	100	100	0	0	0	0	100		Gas Shortage				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	24	34							
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	150	170							
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	16	30							
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	85	88							
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	16	32							
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34							
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	30							
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	207	160	190	200							
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	208	193	190	200							
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	198	206	190	200							
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	410	414	414							
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22							
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11							
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52							
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113							
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	110	113	94	113							
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0							
Rajshahi Zone Total						2129	2129	1259	1505	1563	1743	171	0			
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage				
b) Barapukuria TPP Unit-2	Coal (PDB)		1 x 125	125	85	0	0	0	0		85	Under Overhauling				
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	199	200	200							
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	15	15							
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	67	95	70	100							
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10							
145	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0							
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	108	50	113							
Rangpur Zone Total						800	720	273	402	343	438	85	85			
Sub-total: Plants in operation						21924	21396	10304.0	12068	13358	15416	1342	2108			
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								10096	11825	13088	15105					
(B) Plants under long term maintenance/ contract expired																
147	Jamalganj 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired				
148	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired				
149	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage				
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired				
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020				
152	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022				
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0					
Gross Total						22348	21396	10304	12068	13358	15416	1342	2108			
(C) Actual data of 13.07.22 (Yesterday) Wednesday :																
01.	Max. Demand at eve. peak (Generation end)					12068	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)					11825	MW, at = 21:00 hrs		Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)					12469	MW, at = 23:00 hrs		MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)					9446	MW, at = 8:00 hrs		Dhaka	3408	3408	0	Mymensingh	1088	1088	0
05.	Day-peak Generation (Generation end)					10304	MW, at = 12:00 hrs		Chattogram	1210	1210	0	Sylhet	366	366	0
06.	Evening-peak Generation (Generation end)					12068	MW, at = 21:00 hrs		Khulna	1655	1655	0	Barishal	408	408	0
07.	Evening Peak Load-shed (Sub-station end)					0	MW, at = 21:00 hrs		Rajshahi	1473	1473	0	Rangpur	910	910	0
08.	Minimum Generation Forecast up to 8:00 hrs.					10035	MW, at = 5:00 hrs		Cumilla	1308	1308	0				
09.	Generation shortfall at evening peak due to :												Total	11825	11825	0
	a) Gas limitation					1257	MW		13.	Fuel cost :	(a) Gas = 182984998	Taka	(c) Coal = 224347611	Taka		
	d) Coal supply Limitation					85	MW				(b) Oil = 841379645	Taka	Total = 1248712254	Taka		
	b) Low water level in Kaptai lake					0	MW									
	c) Plants under shut down/ maintenance					2108	MW		14.	Maximum Temperature in Dhaka was :	36.0° C					
10.	Total Energy (Generation + India Import)					263.07	MKWh		15.	Export through East-West interconnections :						
	By Gas = 154.298						MKWh			At evening peak-hour	10304	MW, at 21:00 hrs				
	By Coal = 26.909						MKWh			Maximum	-840	MW, at 20:00 hrs				
	By Solar= 1.566						MKWh			Energy	2.6645	MKWh				
11.	Total Gas Supplied					1213.30	MMCFD									
(D) Forecast of 14.07.22 (Today) Thursday :																
01.	Maximum Demand					12800	MW (Generation end)	04.	Maximum Load-shed		0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation					15416	MW (Generation end)	05.	Total Generation		270.05	MKWh				
03.	Reserve / Shortage					2616	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :		36.3° C					