

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		14-Jul-22		Page -2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	180	100	2362500	Machine problem
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	290	7287900	Machine problem
4	Ghorashal 78.5 MW PP(PMAX)	QRPP	2*40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34*3.35	108	89	2061636	Engine problem
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	406	9885700	
7	Haripur 368MW CCPP(HPL)	IPP	1*235+1*125	360	332	7352000	Machine problem
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9284550	
9	Meghnaghat 100 MW(IEL)	NENP	12*8.9	100	76	1684800	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	30	843514	Low demand
13	Keranganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIIPP, REB	8*2.90	22	0	269796	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	190	4069000	FGMO
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*8.9	100	93	1286400	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	335	7781531	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	93	1369444	Engine problem
20	Katpasi 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	17	476640	Low demand
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	125	2971200	Transformer O/L
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	309191	
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	350101	Low demand
25	Bosila 108MW PP(CLLC)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power (Madhabdi-Ashulia)	SIIPP, REB	3*3.67+4*8.73	80	40	918420	Engine problem
27	Mazona 33 MW PP(Summit)	SIIPP, REB	4*8.73	33	25	645200	Engine problem
28	Rupganj 33 MW PP(Summit)	SIIPP, REB	4*8.73	33	24	632600	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	49	995040	#REF!
30	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	280	5946543	Engine problem
32	Keranighoj 300 MW PP (APPL)	IPP	258*1.4	300	0	0	Reserve.
33	Brambarangan 100 MW PP (Aggreko)	IPP	114*0.959	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	145	3016	
36	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2299200	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	104	1351680	
38	Manikganj 162MW PP(IMPLGL)	IPP	9*18	162	17	748900	Fuel shortage
39	Spectra Solar Plant Ltd	IPP	35	35	0	270828	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	55	1325160	
Dhaka area Total				5847	3540	74806690	
41	Chattogram TPP-1	PDB	1*210	180	100	2400000	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3*8.9	25	8	380381	Low demand
43	Taknaf 20MW PP (Solarteck)	IPP	20	0	0	121500	
44	Patenga 50MW PP (Baran)	IPP	8*6.88	50	38	1054560	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	125	2886907	Low water level
46	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	87	1108181	Engine problem
49	Hathazari 100 MW peaking PP	PDB	11*8.9	98	51	223872	Fuel shortage
50	Dohazari-Kabaha 100 MW Peaking	PDB	6*17	102	51	508887	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	10	655800	Low demand
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	50	1400640	Low demand
53	Barabkunda 22 MW PP (Regent)	SIIPP, PDB	8*2.90	22	21	482448	
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	995520	
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	21	790080	Low demand
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	34520	
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	65	973527	Low demand
57	Jodiac Power	IPP	3*18.55+1*3.8	54	54	1184362	
58	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	99	2104281	Engine problem
59	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	2303040	
60	Anilma Energy Ltd.	IPP	6*21.2	116	108	2521636	Engine problem
Chattogram area Total				2382	1030	22130542	
61	Ashuganj TPP Unit-3	APSCL	1*150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCL	1*150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	0	75000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	280	7523500	Under maint.
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	275	6076000	
65	Ashuganj 420 MW CCPP(East)	APSCL	284*1+136*1	0	0	95100	On test.
66	Ashuganj 50 MW PP (Precision)	APSCL	14*3.968	45	1	682448	Tripped at 19:45
66	Ashuganj 55 MW PP (Precision)	QRPP	15*4	55	0	1013280	Tripped at 19:45
67	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	185	4416000	
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1173342	
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	143	3020945	
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	153280	Reserve.
71	Chandpur 150 MW Peaking PP	PDB	1*108+1*157	163	105	3254560	Machine problem
72	Chandpur 200MW Dash energy)	IPP	12*18.4	200	200	3356160	
73	Feni 22MW PP (Doreen)	SIIPP, PDB	8*2.90	22	22	497952	
74	Feni 11 MW PP (Doreen)	SIIPP, REB	4*2.90	11	10	231840	
**	Impoort (Tripura)	Imported power	0	160	79	1827840	
75	Jangalia 33MW PP (Summit)	SIIPP, PDB	4*8.73	33	33	801400	
76	Jangalia 52 MW PP (Lidareaw)	IPP	6*9.92	43	43	365213	Engine problem
77	Cumilla 25 MW PP (Summit)	SIIPP, REB	3*3.67+2*6.97	25	20	456480	Engine problem
78	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	97	874380	Engine problem
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	111	846720	
81	Bhairab 54.5 MW	IPP	3*18.2	54	17	739080	33 KV feeder problem.
82	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	72	1797040	Fuel shortage
Cumilla Area Total				2885	1774	38559600	
83	RPCL 210MW CCPP	IPP	4*35+1*70	202	138	4345320	Tripped at 19:45
84	Tangail 22 MW PP (Doreen)	SIIPP, PDB	8*2.90	22	22	492480	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	17250	
87	Mymensingh 200 MW PP (United)	IPP	9.78*12	200	72	2793600	Tripped at 19:45
88	Jamalpur 115 MW PP (United)	IPP	9.78*12	115	100	1606800	Engine problem
89	Sutahali 50 MW Solar PP	IPP	50	0	0	412860	
90	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	7	492480	
Mymensingh Area Total				614	339	10161190	
91	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	44	1003000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	1014772	Machine problem
93	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	80	1974027	ST Under maint.
94	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	52	1237200	
	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	47	1107360	
96	Hobiganj 11MW PP Confidence-E	SIIPP, REB	4*2.90	11	0	218496	Engine problem
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	56	1281408	Engine problem
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	81	1910400	Engine problem
99	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1*142+1*88	220	139	2451770	Machine problem
101	Sylhet 20 MW GTPP	PDB	1*20	20	0	0	Gas shortage
	Sylhet 50MW PP (EPL)	NENP	27*2	50	26	545920	Engine problem
102	Shahjahanulla 25 MW PP	SIIPP, REB	3*9.34	25	22	533904	
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
104	Bibiyanar-II 400 MW CCPP	IPP	400 MW	400	280	6576000	
105	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	67	237000	
106	Bibiyanar South 400 MW	PDB	400 MW	383	390	3117400	
Sylhet Area Total				2477	1269	23209257	
107	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	747	16985454	
108	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	66	596160	Fuel shortage
109	Fairpur 50 MW Peaking PP	PDB	6*8.89	54	34	193440	Engine problem
110	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
111	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	37376	Reserve.
112	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	400	9387360	
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	8	35625	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve.
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	72	1076160	Engine problem
115	Madhumati 100 MW PP	NWPGCL	6*18	100	67	1750176	Low demand
116	Mongla Orion 100 MW Solar PP	IPP	100	0	0	704160	
	Khulna 330 MW CCPP (OIL)	BPDB	1*220+1*110	0	0	0	On test.
Khulna Area Total				2384	1394	30765911	
117	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	640512	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	35	673527	
119	Bhola 225 MW CCPP	PDB	2*63+1*68	194	87	1743118	Gas shortage
120	Bhola 95 MW PP (Aggreko)	QRPP	98*1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2*622	1244	800	23514000	Line O/L
122	Bhola Nutan Biddut BD LTD	IPP	220	220	220	4983682	
123	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	24000	Transformer O/L
Barisal Area Total				1958	1158	31578839	
124	Baghabari 71 MW GTPP	PDB	1*71	71	65	685000	
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage
125	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	128320	Reserve.
126	Bera 70 MW Peaking PP	IPP	9*8.29	71	0	101166	Reserve.
127	Amnura 50 MW PP(Sinha)	QRPP	7*7.79	0	0	0	Contract Expired
128	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	8	151488	High Voltage
129	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	105935	Reserve.
130	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	180	4683127	
131	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	155	4590018	
132	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	149	4682655	Gas shortage
133	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	414	9288654	
134	Santahar 50 MW Peaking PP	PDB	6*8.7	50	35	380848	Engine problem
135	Bogra 22 MW PP (GBB)	RPP	6*4	22	20	443280	
136	Bogra 20 MW PP (Energyprima)	NENP	5*3.3+5*2	0	0	0	
137</							