

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	180	180	3307500	Machine problem
3	Ghorasal 365 MW CCGP Unit-7	PDB	1'243+1'122	365	280	7093918	Machine problem
	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	89	2024000	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCGP	EGCB	1'273+1'139	412	408	9891840	
6	Haripur 360MW CCGP(HPL)	IPP	1'235+1'125	360	332	7428000	Machine problem
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1'150	450	420	9206050	
9	Meghnaghat 100 MW(LEL)	NENP	12'8.9	100	70	1615680	Engine problem
10	Meghnaghat CCGP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
11	Madanganj 102 PPI(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj 335 MW CCGP	IPP	3'17.08+1'11.3	55	30	737543	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	0	161136	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	149	3253000	FGMO
17	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12'8.9	100	60	818698	Engine problem
18	Siddhirgonj 335 MW CCGP	EGCB	1'217+118	335	338	7291630	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	64	846000	Engine problem
20	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	17	486000	Low demand
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	132	1613760	High Voltage
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	336557	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	385891	
25	Bosila 108MW PPI(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhadi+Ashulia)	SIPP, REB	3'3.674+18.73	80	35	938400	Engine problem
27	Maona 33 MW PPI(Summit)	SIPP,REB	4'8.73	33	25	508800	Engine problem
28	Rupganj 33 MW PPI(Summit)	SIPP,REB	4'8.73	33	30	617200	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	24	490080	#REF!
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	145	3472581	Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve.
33	Bramhanganj 100 MW PP (Aggreko)	IPP	114'0.959	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	104	1564272	Low demand
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2439600	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18'5.6	104	53	1795680	Low demand
38	Manikganj 162MW PPI(MPGL)	IPP	9'18	162	17	479520	Low demand
39	Spectra Solar Plant Ltd	IPP	35	35	0	228221	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	55	933840	
Dhaka area Total				5847	3272	70146797	
41	Chattogram TPP-1	PDB	1'210	180	100	2300000	Machine problem
	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	473603	Low demand
43	Taknai 20MW PP (Solartech)	IPP	20	20	0	81665	
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	44	1047360	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	125	2997905	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	34	1038763	Low demand
49	Hathazari 100 MW Peaking PP	PDB	11'8.9	98	51	567504	Fuel shortage
50	Dohazari-Kalash 100 MW Peaking	PDB	6'17	102	34	491514	Fuel shortage
51	Juldah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	55	850440	Low demand
52	Juldah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	50	1365120	Low demand
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	506064	
*	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	40	1028160	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	11	777600	Low demand
55	Kaptai 7 MW. Solar PP	PDB	7.4	7	0	30240	
56	Anwara 300 MW PP (United)	IPP	17'1+24	300	15	745200	Low demand
57	Jodiac Power	IPP	3'18.55+1'3.6	54	54	1012715	
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	92	2039045	Engine problem
59	Juldah unit-2 (Acorn)	IPP	8'13.6	100	100	2250240	Low demand
60	Anilma Energy Ltd.	IPP	6'21.2	116	108	2491527	Engine problem
Chattogram area Total				2382	959	22104965	
61	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0	Contract Expired
	Ashuganj TPP Unit-4	APSCL	1'150	0	0	0	Contract Expired
	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCGP	APSCL	1'142+1'75	221	139	3332000	#REF!
63	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	280	7408700	Gas shortage
64	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	275	6998000	FGMO
	Ashuganj 420 MW CCGP(East)	APSCL	284'1+136'1	0	0	0	On test.
65	Ashuganj 50 MW PP (Precision)	APSCL	14'3.98	45	35	808992	Engine problem
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	45	1104480	Engine problem
67	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	185	4468181	Engine problem
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1171867	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	100	2216363	Low demand
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	40	200536	Engine problem
71	Chandpur 150 MW CCGP	PDB	1'106+1'157	163	135	3126690	Machine problem
72	Chandpur 200MW (Dash energy)	IPP	12'18.4	200	200	3463200	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	510120	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	7	183240	
**	Imporpti (Tripura)	Imported power	0	160	80	1831680	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	809500	
76	Jangalia 52 MW PP (Kandrawa)	IPP	6'8.92	52	43	316810	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	520570	Engine problem
78	Daudkandi 200 MW PP (B. Trac)	IPP	154'1.4	200	0	0	Reserve.
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	424080	Low demand
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	1015560	
81	Bhairab 54.5 MW	IPP	3'18.2	54	17	490320	33 kV feeder problem
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	72	1075200	Engine problem
Cumilla Area Total				2885	1909	41474068	
83	RPCL 210MW CCGP	IPP	4'35+1'70	202	190	4487040	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	405036	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	15250	
87	Mymensingh 200 MW PP (United)	IPP	9.78'21	200	150	2817600	Low demand
88	Jamalpur 115 MW PP (United)	IPP	9.78'12	115	104	1461600	Engine problem
89	Sutahat 50 MW Solar PP	IPP	50	50	0	351340	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	22	437520	
Mymensingh Area Total				614	487	9975386	
91	Fenchugonj CCGP Phase-1	PDB	2'32+1'33	70	44	1018000	Machine problem
92	Fenchugonj CCGP Phase-2	PDB	2'35+1'35	90	42	1032660	Machine problem
93	Kushara 163 MW CCGP (KP)	IPP	1'109+1'54	163	80	1985318	ST Under maint.
94	Shahjibazar 330 MW CCGP	PDB	3'11.0	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	52	1224000	
	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	47	1136880	Engine problem
96	Hobiganj 11MW PP Colidence-E	SIPP, REB	4'2.90	11	11	264000	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	56	1280640	Engine problem
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	81	1917120	
99	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCGP	PDB	1'142+1'89	231	220	4882960	
101	Sylhet 20 MW GTTP	PDB	1'20	20	0	0	Gas shortage
	Sylhet 50MW PP (EPL)	NENP	27'2	50	26	602200	Engine problem
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	23	519384	
103	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	0	0	Under maint.
104	Bibiyanah-III 400 MW CCGP	PDB	400 MW	400	403	3388000	
105	Sylhet 10MW PP (Desh)	RPP	8'1.95	10	10	237420	
106	Bibiyanah South 400 MW	PDB	400 MW	383	380	8972000	
Sylhet Area Total				2477	1475	28460582	
107	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500	1000	868	19354909	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	63	911040	Fuel shortage
109	Fandpur 50 MW Peaking PP	PDB	8'8.69	54	0	30720	Reserve.
110	Khulna 225 MW CCGP	NWPGCL	1'150+1'75	230	0	0	Reserve.
111	Gopalganj 100 MW Peaking PP	PDB	16'6.88	109	0	17280	Reserve.
112	Bheramara 410 MW CCGP	NWPGCL	1'278+1'132	410	390	8479008	Machine problem
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	8	34125	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Reserve.
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	77	687360	Engine problem
115	Madhumati 100 MW PP	NWPGCL	6'18	105	105	1414844	Low demand
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	865280	
	Khulna 330 MW CCGP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
Khulna Area Total				2384	1511	31594666	
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	32	505728	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	26	550844	
119	Bhola 225 MW CCGP	PDB	2'63+1'68	194	86	2081199	Gas shortage
120	Bhola 95 MW PP (Aggreko)	QRPP	9'67.10	0	0	0	Contract Expired
121	Pay						