

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022					Day : Saturday					Date : 16.07.22					
Probable Maximum Demand : 13600 MW					Probable Maximum Generation : 15730 MW										
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 91.18 ft		Today = 91.27 ft		Rule Curve = 86.24 ft						
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.07.22 (Yesterday)		16.07.22 (Today)		15.07.22 (Yesterday)		16.07.22 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening						
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	280	300	300						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	89	89	90						
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.		
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired		
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	280	332	280	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	420	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling		
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	407	408	412	412						
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	130	149	190	190						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	300	338	335	335						
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	30	30						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	64	50	90						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	0	22	22						
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x4.73	80	80	35	35	40	40						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	24	50	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105						
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	132	130	132						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	54	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	145	280	280						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	52	104	130	132						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	200	300						
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100						
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100						
29	Nababganj 55 MW PP (Southern pow)	HFO (IPP)	3x19.3	55	55	17	55	55	55						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	53	104	104						
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	162	162						
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	28	0	30	0						
34	Kanchan Purbachal Power Generator	HFO (IPP)	3x19.404	55	55	19	55	55	55						
35	Siddhirganj 100 MW PP(Dutch Bangle	HFO (NENP)	12x8.9	100	100	8	60	40	85						
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	42	70	78	78						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0						
Dhaka Zone Total				6004	5847	2733	3272	3917	4382	335	660				
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	127	125	125	125				Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80			Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)		20	20	0	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	42	44	44	44						
44	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	17	34	105	105						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	15	15	200	265						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	30	50	80	80						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	0	51						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	51	0	52						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			35	40	26	30						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	42	11	70	90						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54						
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	92	110	110						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	100	100	100						
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	55	55	55						
57	Chattogram 116 MW PP (Anilma Ener	HFO (IPP)	6x21.06	116	116	108	108	108	108						
Chattogram Zone Total				2442	2382	748	959	1248	1415	80	555				
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	0	0	0	0	0				Contract Expired		
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134			Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	34	35	35	35						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	134	139	140	140						
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	275	320	320						
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	280	320	320						
	Ashuganj 420 MW CCPP(East)	Gas (APSCL)				0	0	0	0	300			Gas Shortage		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	47	45	51	51						
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+11'6	195	195	158	185	180	185						
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	105	100	132	140						
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	40	40	50						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	136	135	135	135						
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	200	120	200						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	11	11						
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20						
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.51x+15x1.08x	200	200	0	0	100	200						
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17						
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	7	113	30	113						
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35						
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	72	36	72						
**	Import (Tripura)	India		160	160	72	80	60	78						
Cumilla Zone Total				3059	2885	1593	1909	1896	2271	434	0				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	194	190	200	200	12			Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	21	22	22						
82	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	104	60	104						
83	Myemsingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	119	150	130	150						
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0						
85	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0						
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	5	22	22	22						
Myemsingh Zone Total				622	614	436	487	486	498	12	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.07.22 (Yesterday)		16.07.22 (Today)		15.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	52	51	51				
90	Kushiar 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	80	80	29	54	ST under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	56	60	62				
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	220	190	220				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas shortage	
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	23	24	24				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0				
100	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	82	403	350	400				
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	380	360	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	25	26	25	25	24		Gas Shortage	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	47	47	50	50				
Sylhet Zone Total						2522	2477	1144	1475	1378	1500	73	558
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	370	390	380	400				
107	Faridpur 50 MW Peaking PP	HFO (PDB)	6x6.98	54	54	0	0	0	42				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
109	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	220	220				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	77	75	80				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	105	105	105				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	63	32	66				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8				
**	Bheramara (HVDC)	India		1000	1000	763	868	896	880				
Khulna Zone Total						2388	2384	1255	1511	1858	1961	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	64	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	26	26	30				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	86	86	86	108		Gas Shortage	
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	850	1100	1100				
120	Polukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	35				
121	Bhola 220MW CCPP (Nutan Bidyut BI)	Gas/HSD (IPP)	2x75+1x70	220	220	217	222	220	220				
Barishal Zone Total						1958	1958	1079	1233	1513	1581	108	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	60	60	60	60				
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	24	34				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	150	170				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	16	30				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	85	88				
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	16	32				
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	150	165	180	180	45			
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	163	167	180	180	53			
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	166	168	180	180	52			
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	320	414	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	8	8				
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	76	113	95	113				
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	70	113				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	1047	1383	1551	1699	250	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	15	15				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	66	89	68	90				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
145	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	34	108	52	108				
Rangpur Zone Total						800	720	307	397	343	423	85	85
Sub-total: Plants in operation						21924	21396	10342.0	12626	14190	15730	1377	1858
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								10027	12241	13757	15250		
(B) Plants under long term maintenance/ contract expired													
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
149	Boxila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
152	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22348	21396	10342	12626	14190	15730	1377	1858
(C) Actual data of 15.07.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	12626	MW, at = 21:00 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12241	MW, at = 21:00 hrs			Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12818	MW, at = 23:00 hrs			MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	9724	MW, at = 9:00 hrs			Dhaka	3547	3547	0	Mymensingh	1133	1133
05.	Day-peak Generation (Generation end)	:	10342	MW, at = 12:00 hrs			Chattogram	1268	1268	0	Sylhet	590	590
06.	Evening-peak Generation (Generation end)	:	12626	MW, at = 21:00 hrs			Khulna	1660	1660	0	Barishal	393	393
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 21:00 hrs			Rajshahi	1462	1462	0	Rangpur	933	933
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10450	MW, at = 5:00 hrs			Cumilla	1255	1255	0			0
09.	Generation shortfall at evening peak due to :	:									Total	12241	12241
	a) Gas limitation	:	1292	MW							(a) Gas =	189821390	Taka
	d) Coal supply Limitation	:	85	MW							(c) Coal =	225793684	Taka
	b) Low water level in Kaptai lake	:	0	MW							(b) Oil =	788963156	Taka
	c) Plants under shut down/ maintenance	:	1858	MW							Total =	1204578230	Taka
10.	Total Energy (Generation + India Import)	:	272.49	MKWh			14.	Maximum Temperature in Dhaka was : 35.4° C					
	By Gas = 159.751 MKWH			By Oil = 60.025 MKWh			15.	Export through East-West interconnections :					
	By Coal = 27.056 MKWH			By Hydro = 2.998 MKWh				At evening peak-hour	:	10342	MW, at	21:00 hrs	
	By Solar= 1.473 MKWH							Maximum	:	-840	MW, at	20:00 hrs	
11.	Total Gas Supplied	:	1275.23	MMCFD				Energy	:	2.6645	MKWh		
(D) Forecast of 16.07.22 (Today) Saturday :													
01.	Maximum Demand	:	13600	MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	15730	MW (Generation end)		05.	Total Generation : 289.11 MKWh						
03.	Reserve / Shortage	:	2130	MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 35.6° C						