

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022										Day : Monday				Date : 18.07.22					
Probable Maximum Demand : 14500 MW										Probable Maximum Generation : 14919 MW									
Water Level of Kaptai Lake at 06:00 AM										Rule Curve = 86.56 ft.									
Sl. No.	Name of Power Station	Unit	Yesterday X Capacity (MW)	91.34 ft Installed Capacity (MW)	Derated/ Present Capacity (MW)	Today = 91.41 ft		17.07.22 (Yesterday)		18.07.22 (Today)		17.07.22 (Yesterday)		18.07.22 (Today)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Probable Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/water/Coal limitation MW		Machines shut down (MW)		Description/ Remarks	
						Day	Evening	Day	Evening	Day	Evening	Day	Evening	Day	Evening	Day	Evening	Day	Evening
(A) Plants in operation:																			
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	0	0	0	0	0	0	0	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	0	0	0	0	0	0	180	Under maint.		
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180	180	180	180	180	180	180	180			
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300	300	300	300	300	300	300	300			
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x4.3.35	108	108	88	89	89	90	90	90	90	90	90	90	90			
6	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	0	0	0	0	0	0	105	Under maint.		
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	0	0	0	0	0	0	0	Contract Expired		
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	343	223	330	330	330	330	330	330	330	330	137	Gas Shortage		
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	225	225	225	225	225	225	Gas Shortage		
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	0	0	0	0	0	0	115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	408	364	412	412	412	412	412	412	412	412	412			
12	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	0	0	0	0	0	0	0			
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	0	0	0	0	0	0	0	0	0	335	Under maint.		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	0	0	0	0	0	0	335	Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55	55	55	55	55	55	55	55			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	93	93	93	93	93	93	93	93	93			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22	22	22	22	22	22	22	22			
18	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+6x7.3	80	80	42	46	46	46	46	46	46	46	46	46	46			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	25	25	25	25	25	25	25	25	25	25			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	33	32	33	33	33	33	33	33	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	40	40	40	41	41	41	41	41	41	41			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105	105	105	105	105	105	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	132	125	130	132	132	132	132	132	132	132	132			
24	Karnaphuli 54 MW PP (Baraka Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54	54	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	265	273	280	280	280	280	280	280	280	280	280			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	132	149	135	149	135	149	135	149	135	149	135			
27	Karanga 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	10	195	200	300	300	300	300	300	300	300	300			
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	97	0	100	100	100	100	100	100	100	100			
29	Aurabadi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	27	100	0	100	100	100	100	100	100	100	100			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	55	55	55	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55	55	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	89	104	104	104	104	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPLG)	HFO (IPP)	9x18	162	162	144	144	144	144	144	144	144	144	144	144	144			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	36	0	30	0	30	0	30	0	30	0	30			
35	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55	55	55	55	55	55	55	55			
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	73	90	75	98	98	98	98	98	98	98	98			
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	70	86	78	78	78	78	78	78	78	78	78			
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0	0	0	0	0	0	0	0			
Dhaka Zone Total				6004	5847	3303	3378	3295	3661	697	995								
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	125	123	125	125	125	125	125	125	125	125	125	Unit 1 under rehabilitation		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	100	100	100	100	100	100	100	Gas Shortage		
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	0	0	0	0	0	0	180	Under maint.		
42	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0	5	0	5	0	5	0	5			
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25	25	25	25	25	25	25	25			
44	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0	20	0	20	0	20	0	20			
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	30	37	38	38	38	38	38	38	38	38	38			
46	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	101	87	105	105	105	105	105	105	105	105	105			
47	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	0	0	0	0	0	0	150	Under maint.		
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+ 1 x 75	225	225	0	0	0	0	0	0	0	0	0	0	225	Awaiting for HGPI		
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	265	278	200	285	285	285	285	285	285	285	285			
50	Judha 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	90	90	90	90	90	90	90	90	90			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51	51	51	51	51	51	51	51			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	46	0	52	52	52	52	52	52	52	52			
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	19	21	21	21	21	21	21	21	21	21			
54	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	16	7	20	20	20	20	20	20	20	20			
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	67	72	70	90	90	90	90	90	90	90	90			
56	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	54	54	54	54	54	54	54	54	54			
57	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	98	98	110	110	110	110	110	110	110	110			
58	Judha unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100	100	100	100	100	100	100	100			
59	Judha 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	55	55	55	55	55	55	55	55	55	55	55			
60	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	108	108	108	108	108	108	108	108	108	108			
Chattogram Zone Total				2442	2382	1223	1341	1233	1429	80	555								
61	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	0	0	0	0	0	0	0	0	0	0	0	0	Contract Expired		
62	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	0	0	0	0	0	0	134	Gas Shortage		
63	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	30	27	35	35	35	35	35	35	35	35	35			
64	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	209	210	220	220	220	220	220	220	220	220	220			
65	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	320	305	310	330	330	330	330	330	330	330	330			
66	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	330	310	310	330	330	330	330	330	330	330	330			
67	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)				0	0	0	0	0	0	0	0	0	0	300	Gas Shortage		
68	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	46	46	47	47	47	47	47	47	47	47	47			
69	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	187	187	160	187	187	187	187	187	187	187	187			
70	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51	51	51	51	51	51	51	51			
71	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	92	132	145	145	145	145	145	145	145	145	145			
72	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	46	41	41	41	41	41	41	41	41	41	41			
73	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	85	84	0	0	0	0	0	0	0					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.07.22 (Yesterday)		18.07.22 (Today)		17.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44	44		26	GT-1 Under maint.	
88	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		51	51	0	0	0	0			Gas Shortage	
90	Kushiyara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	51	109	54	ST under maint.
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	55	62	62				
93	Shajibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330		Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	81	81				
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	207	220	220	220				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20			Gas shortage
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0				
99	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	295	290	300				
100	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	403	402	400	400				
101	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	398	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100			Under project work
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50			Gas Shortage
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2522	2477	1455	1555	1549	1559	230	558
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 276+1 x 132	410	410	340	365	300	350	45			
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	42				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	60				
109	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	220	220				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	25	50	100				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	50	93	75	94				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	67	105	105				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	99	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	64	16	64				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	40	40	0	8				
**	Bheramara (HVDC)	India		1000	1000	881	860	892	876				
Khulna Zone Total						2388	2384	1441	1617	1758	1919	45	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	30	26	30				
118	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	87	87	87	87	107			Gas Shortage
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	800	1030	1100	1100				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	35				
121	Bhola 220MW CCGP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	183	222	220	220				
Barishal Zone Total						1958	1958	1107	1418	1466	1504	107	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0				
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	24	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	25	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	32	16	32				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	89	85	88				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	30				
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	178	179	180	190				
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	184	212	150	220				
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	187	210	190	210				
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	376	414	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22	22				
136	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	56	95	75	95				
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	94	113				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total						2129	2129	1124	1574	1425	1738	100	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	199	200	200				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	15	15				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	60	96	68	97				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
146	Majpara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	72	108	72	109				
Rangpur Zone Total						800	720	337	403	363	431	85	85
Sub-total: Plants in operation						21924	21396	12104.0	13765	13309	14919	1875	2193
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss								11557	13143	12707	14245		
(B) Plants under long term maintenance/ contract expired													
147	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired
148	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22348	21396	12104	13765	13309	14919	1875	2193
(C) Actual data of 17.07.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	13765	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13143	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13765	MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	10783	MW, at =	8:00 hrs	Dhaka	4411	4411	0	Mymensingh	989	989	0
05.	Day-peak Generation (Generation end)	:	12104	MW, at =	12:00 hrs	Chattogram	1300	1300	0	Sylhet	545	545	0
06.	Evening-peak Generation (Generation end)	:	13765	MW, at =	21:00 hrs	Khulna	1702	1702	0	Barisal	396	396	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Rajshahi	1536	1536	0	Rangpur	950	950	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11150	MW, at =	5:00 hrs	Cumilla	1313	1313	0				
09.	Generation shortfall at evening peak due to :	:								Total	13143	13143	0
	a) Gas limitation	:	1790	MW		13.	Fuel cost :	(a) Gas = 179585615 Taka	(c) Coal = 236377977 Taka				Taka
	d) Coal supply Limitation	:	85	MW				(b) Oil = 1185019278 Taka	Total = 1600982870 Taka				Taka
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2193	MW		14.	Maximum Temperature in Dhaka was : 35.1° C						
10.	Total Energy (Generation + India Import)	:	300.47	MKWh		15.	Export through East-West interconnections :						
	By Gas = 158,267 MKWh	By Oil =	86.303 MKWh				At evening peak-hour : 12104 MW, at 21:00 hrs						
	By Coal = 28,233 MKWh	By Hydro =	3,024 MKWh				Maximum : -30 MW, at 1:00 hrs						
	By Solar= 1.410 MKWh						Energy : 14654.702 MKWh						
11.	Total Gas Supplied	:	1115.80	MMCFD									
(D) Forecast of 18.07.22 (Today) Monday :													
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	14919	MW	(Generation end)	05.	Total Generation : 316.51 MKWh						
03.	Reserve / Shortage	:	419	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 35.1° C						
* Captive Power ** Imported Power													
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00													
(Md. Helalur Rahman) Deputy Secretary, Generation													