

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022				Day : Tuesday				Date : 19.07.22				
Probable Maximum Demand : 14400 MW				Probable Maximum Generation : 12482 MW				Rule Curve = 86.88 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 91.41 ft				Today = 91.93 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.07.22 (Yesterday)		19.07.22 (Today)		18.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/water/Coal limitation MW	Machines shut down (MW)		
												Day
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	88	89	89	89			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	238	152	180	180	208	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	180	180	180	270	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	358	249	270	270			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagarj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	93	93	88	93			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+1x4.73	80	80	46	48	48	48			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	31	33	33			
20	Gezpur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	50	41	50			
21	Gezpur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	114	125	125	132			
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	274	273	280	280			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	148	149	149	149			
26	Karangpur 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	300	301	0	0			
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	96	97	0	0			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	93	101	0	0			
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	3	0	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162			
33	Manikgonj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	22	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	0	55	55	55			
35	Siddhirgonj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	94	32	32	32			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	71	36	50	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	3287	3120	2767	2758	1023	995	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	126	119	125	125		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	38	38	38			
44	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	105	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	278	278	278	285			
48	Jaldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	76	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	51	0	52			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
*	Melancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	8	5	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	68	82	82	82			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	110	110	110			
55	Jaldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	76	100	100			
56	Jaldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	55	31	31	31			
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	108	96	108	108			
Chattogram Zone Total				2442	2382	1252	1315	1277	1367	80	555	
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	0	0	0	0	0		Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	40	35	35			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	208	124	154	154	97	Gas Shortage	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	315	280	280	280	80	Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	280	280	280	80	Gas Shortage	
	Ashuganj 420 MW CCPP(East)	Gas (APSCL)				0	0	0	0	300	Gas Shortage	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	47	47	5	5			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	158	8	8	8	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	103	132	140	140			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	49	40	49			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	200	120	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	19	19	19			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	27	32	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	59x1.4+40x1.315+15x1.358	200	200	50	200	0	0			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	0	0	0			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	115	9	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	95	71	95	95			
**	Import (Tripura)	India		160	160	66	82	60	79			
Cumilla Zone Total				3059	2885	1717	1803	1402	1614	878	0	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	92	105	105	105	97	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	105	60	105			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	115	170	116	200			
84	Sarishaban 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutikhabari 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24	23	22	22			
Mymensingh Zone Total				622	614	367	424	377	454	97	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.07.22 (Yesterday)		19.07.22 (Today)		18.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	30	30		40	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barkatullah)	Gas (RPP)	19x2.90	51	51	0	0	0		51	Gas Shortage	
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0		109	54	ST under maint.
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0		11		Gas Shortage
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	62	40		62		
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		0		330
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	40		81		
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220		220		
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0		0		Gas shortage
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10		10		
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8		8		Gas shortage
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	295	290		300		
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	402	400		400		
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400		400		
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0		0		100
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0		0		Gas Shortage
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0		0		Gas Shortage
Sylhet Zone Total					2522	2477	1503	1550	1480	1553	308	572
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0		0		
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	280	240	240		240		Gas Shortage
107	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0		42		
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0		70		
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0		0		
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	84	0		0		
111	Rupaha 105 MW PP (Orion rupaha)	HFO (IPP)	6x18.445	105	105	0	93	93		93		
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105		105		
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	100		0		
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	20	16		16		
115	Noapara 40 MW PP (Kharajahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	40		40		
**	Bheramara (HVDC)	India		1000	1000	876	858	890		875		
Khulna Zone Total					2388	2384	1372	1559	1484	1481	170	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16		32		
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	30	26		30		
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	87	87		107		Gas Shortage
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	840	1050	1100		1100		
120	Potlakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	35				
121	Bhola 220MW CCPP (Nutan Bidyut Bt)	Gas/HSD (IPP)	2x75+1x70	220	220	222	226	220		220		
Barishal Zone Total					1958	1958	1203	1442	1466	1504	107	0
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0		0		
122	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0		100		Gas Shortage
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	24		34		
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	1	178	0		0		
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	31	16		32		
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	85		88		
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16		32		
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34		34		
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0		30		
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	187	140	180		190		Gas Shortage
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	207	211	0		220		Gas Shortage
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	188	139	190		210		Gas Shortage
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	418	414	414		414		
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22		22		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11		11		
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8		43		
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	55	95	75		95		
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	107	94		113		
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6		0		
Rajshahi Zone Total					2129	2129	1200	1606	1175	1348	471	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		0		85
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		0		85
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200		200		
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	82	94	68		94		
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
145	Majpara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8		0		
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	72	108	109		109		
Rangpur Zone Total					800	720	357	402	385	403	85	85
Sub-total: Plants in operation					21924	21396	12258.0	13221	11813	12482	3219	2207
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							12678	12889	12217	12910		
(B) Plants under long term maintenance/ contract expired												
147	Jamalganj 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		Contract Expired
148	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0		0		Contract Expired
149	Bosila 108MW PP(CLO)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0		Forced Outage
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0		0		Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0		0		Contract Expired on 12/11/2020
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0		0		Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0		0		
Gross Total					22348	21396	12258	13221	11813	12482	3219	2207
(C) Actual data of 18.07.22 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	14006	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	13674	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	13281	MW, at =	22:00 hrs	Dhaka	4902	4804	98	Mymensingh	1195	902
04.	Minimum Generation (Generation end)	:	11150	MW, at =	8:00 hrs	Chattogram	1220	1120	100	Sylhet	490	470
05.	Day-peak Generation (Generation end)	:	12258	MW, at =	10:00 hrs	Khulna	1660	1660	0	Barishal	387	387
06.	Evening-peak Generation (Generation end)	:	13221	MW, at =	21:00 hrs	Rajshahi	1506	1506	0	Rangpur	1002	818
07.	Evening Peak Load-shed (Sub-station end)	:	785	MW, at =	21:00 hrs	Cumilla	1312	1222	90			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10633	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:										
a)	Gas limitation	:	3134	MW		13.	Fuel cost :	(a) Gas = 155986592 Taka	(c) Coal = 250313674 Taka			
d)	Coal supply Limitation	:	85	MW			(b) Oil = 1483934510 Taka	Total = 1890234776 Taka				
b)	Low water level in Kaptai lake	:	0	MW								
c)	Plants under shut down/ maintenance	:	2207	MW		14.	Maximum Temperature in Dhaka was : 33.8° C					
10.	Total Energy (Generation + India Import)	:	299.98	MKWh		15.	Export through East-West interconnections :					
	By Gas = 138.815 MKWh			By Oil = 104.053 MKWh			At evening peak-hour	:	12258	MW, at	21:00 hrs	
	By Coal = 29.798 MKWh			By Hydro = 2.782 MKWh			Maximum	:	212	MW, at	1:00 hrs	
	By Solar= 1.388 MKWh						Energy	:	0	MKWh		
11.	Total Gas Supplied	:	981.81	MMCFD								
(D) Forecast of 19.07.22 (Today) Tuesday :												
01.	Maximum Demand	:	14400	MW (Generation end)		04.	Maximum Load-shed : 2556.1938 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	12482	MW (Generation end)		05.	Total Generation : 325.25 MKWh					
03.	Reserve / Shortage	:	-1918	MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 32.6° C					

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation